

HTE# 07-500 18247

Harrison County Department of Public Health

24297

Improvement Permit

A building permit cannot be issued with only an Improvement Permit

ISSUED TO: Cumberland Homes

PROPERTY LOCATION: SR1210

SUBDIVISION: Pearson Hill

LOT # 34

NEW REPAIR EXPANSION

Site Improvements required prior to Construction Authorization Issuance:

Type of Structure: SFD-56x40-3BR

Proposed Wastewater System Type: Pump to 25% red. system

Projected Daily Flow: 360 GPD

Number of bedrooms: 3 Number of Occupants: 6 max

Basement Yes No

Pump Required: Yes No May be required based on final location and elevations of facilities

Type of Water Supply: Community Public Well Distance from well 50 feet

Permit valid for: Five years

Permit conditions: No expiration

meet onsite for final layout must bring in 8 to 12" of gravel cover soil maintain all set backs stub out plumbing & hollow at ground level or higher & if 12" ditch depth can be maintained pump may not be needed

Authorized State Agent: J. W. Lass

Date: 09-5-07

SEE ATTACHED SITE SKETCH

The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.

Construction Authorization

(Required for Building Permit)

The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout.

ISSUED TO: Cumberland Homes

PROPERTY LOCATION: 1210

SUBDIVISION: Pearson Hill

LOT # 34

Facility Type: SFD-56x40-3BR New

Expansion Repair

Basement? Yes No Basement Fixtures? Yes No

Type of Wastewater System** Pump to 25% red. soil (Initial)

Wastewater Flow: 360 GPD

(See note below, if applicable) 480 LF of LPP

(Repair)

Installation Requirements/Conditions

Septic Tank Size 1000 gallons

Exact length of each trench 1 x 300 feet

Trench Spacing: 9 Feet on Center

Pump Tank Size 1000 gallons

Trenches shall be installed on contour at a

Soil Cover: 6 inches

Maximum Trench Depth of: 12 inches

(Maximum soil cover shall not exceed

(Trench bottoms shall be level to +/- 1/4"

36" above the trench bottom)

in all directions)

Pump Requirements: _____ ft. TDH vs. _____ GPM

_____ inches below pipe

Aggregate Depth: _____ inches above pipe

Conditions: _____

_____ inches total

**If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.

Owner/Legal Representative Signature: _____ Date: _____

This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit.

Authorized State Agent: J. W. Lass

Date: 09-05-07

SEE ATTACHED SITE SKETCH

Construction Authorization Expiration Date: 09-05-2012

HTE# 07-500-18247

Permit # 24297

Harnett County Department of Public Health Site Sketch

ISSUED TO: Cumberland Homes


PROPERTY LOCATOR: 1210

SUBDIVISION Pearlman Hill

LOT # 34

Authorized State Agent: J. L. ...

Date: 09-05-07



Met onsite

Maintain All

Setbacks

Stub out Plumbing &

shallow at ground

level or higher

& if 12" O.D. etc

depths can be maintained

Then pump may not

be required

Install 1x300 &

25% Reduction System

at 12" Must bring

to 8 to 12" of approved

soil.