

ADDRESS . : 77 CAROLINA OAKS CIR  
CONTRACTOR : BILL CLARK HOMES LLC  
OWNER . . : BILL CLARK HOMES OF FAYETTEVIL  
PARCEL . . : 01-0544- - -0012- -44-  
APPL NUMBER: 07-50018351 CP NEW RESIDENTIAL (SFD)  
DIRECTIONS : CAROLINA OAKS #44-401 RT ON ELLIOTT  
BRIDGE RT ON WILL LUCAS RT INTO S/D.JD

SUBDIV: CAROLINA OAKS 64 LOTS  
PHONE : (252) 355-5805  
PHONE : (910) 426-2898

STRUCTURE: 000 000 65X40 3BR W/GARAGE  
FLOOD ZONE . . . . : FLOOD ZONE X

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	1/31/08	TI <i>AP JV</i>	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001555524 <i>T-pole passed</i> COMMENTS AND NOTES

-----  
ADDRESS . . : 77 CAROLINA OAKS CIR SUBDIV: CAROLINA OAKS 64 LOTS  
CONTRACTOR : BILL CLARK HOMES LLC PHONE : (252) 355-5805  
OWNER . . . : BILL CLARK HOMES OF FAYETTEVILLE PHONE : (910) 426-2898  
PARCEL . . . : 01-0544- - -0012- -44-  
APPL NUMBER: 07-50018351 CP NEW RESIDENTIAL (SFD)  
DIRECTIONS : CAROLINA OAKS #44-401 RT ON ELLIOTT  
BRIDGE RT ON WILL LUCAS RT INTO S/D.JD  
-----

STRUCTURE: 000 000 65X40 3BR W/GARAGE  
FLOOD ZONE . . . . : FLOOD ZONE X  
-----

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	1/31/08	JH	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001555524
	1/31/08	AP	t-pole passed
B103 01	2/07/08	TI	R*BLDG FOUND & TEMP SVC POLE VRU #: 001559432

*AP JH*

-----  
COMMENTS AND NOTES  
-----

-----  
ADDRESS . . : 77 CAROLINA OAKS CIR  
CONTRACTOR : BILL CLARK HOMES LLC  
OWNER . . . : BILL CLARK HOMES OF FAYETTEVIL  
PARCEL . . . : 01-0544- - -0012- -44-  
APPL NUMBER: 07-50018351 CP NEW RESIDENTIAL (SFD)  
DIRECTIONS : CAROLINA OAKS #44-401 RT ON ELLIOTT  
BRIDGE RT ON WILL LUCAS RT INTO S/D.JD  
-----

-----  
**STRUCTURE: 000 000 65X40 3BR W/GARAGE**  
FLOOD ZONE . . . . : FLOOD ZONE X  
# BEDROOMS . . . . . : 3.00 PROPOSED USE . . . . . : SFD  
SEPTIC - EXISTING? . . . . : NEW  
-----

**PERMIT: CPSF 00 CP \* SFD**

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	1/31/08	JH	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001555524
	1/31/08	AP	t-pole passed
B103 01	2/07/08	JH	R*BLDG FOUND & TEMP SVC POLE VRU #: 001559432
	2/07/08	AP	
P309 01	2/12/08	TI	R*PLUMB UNDER SLAB VRU #: 001561722

*CA JH*

-----  
COMMENTS AND NOTES  
-----

*JJ 910-263-9026*

ADDRESS : 77 CAROLINA OAKS CIR  
CONTRACTOR : BILL CLARK HOMES LLC  
OWNER : BILL CLARK HOMES OF FAYETTEVIL  
PARCEL : 01-0544- - -0012- -44-  
APPL NUMBER: 07-50018351 CP NEW RESIDENTIAL (SFD)  
DIRECTIONS : CAROLINA OAKS #44-401 RT ON ELLIOTT  
BRIDGE RT ON WILL LUCAS RT INTO S/D.JD

SUBDIV: CAROLINA OAKS 64 LOTS  
PHONE : (252) 355-5805  
PHONE : (910) 426-2898

STRUCTURE: 000 000 65X40 3BR W/GARAGE  
FLOOD ZONE . . . : FLOOD ZONE X

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	1/31/08	JH	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001555524
	1/31/08	AP	t-pole passed
B103 01	2/07/08	JH	R*BLDG FOUND & TEMP SVC POLE VRU #: 001559432
	2/07/08	AP	
P309 01	2/12/08	JH	R*PLUMB UNDER SLAB VRU #: 001561722
	2/12/08	CA	not ready
P309 02	2/13/08	TI	R*PLUMB UNDER SLAB VRU #: 001562516

*AP TH*

----- COMMENTS AND NOTES -----

ADDRESS : 77 CAROLINA OAKS CIR  
CONTRACTOR : BILL CLARK HOMES LLC  
OWNER : BILL CLARK HOMES OF FAYETTEVIL  
PARCEL : 01-0544- - -0012- -44-  
APPL NUMBER: 07-50018351 CP NEW RESIDENTIAL (SFD)  
DIRECTIONS : CAROLINA OAKS #44-401 RT ON ELLIOTT  
BRIDGE RT ON WILL LUCAS RT INTO S/D.JD

SUBDIV: CAROLINA OAKS 64 LOTS  
PHONE : (252) 355-5805  
PHONE : (910) 426-2898

STRUCTURE: 000 000 65X40 3BR W/GARAGE  
FLOOD ZONE . . . . : FLOOD ZONE X

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	1/31/08	JH	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001555524
	1/31/08	AP	t-pole passed
B103 01	2/07/08	JH	R*BLDG FOUND & TEMP SVC POLE VRU #: 001559432
	2/07/08	AP	
P309 01	2/12/08	JH	R*PLUMB UNDER SLAB VRU #: 001561722
	2/12/08	CA	not ready
P309 02	2/13/08	JH	R*PLUMB UNDER SLAB VRU #: 001562516
	2/13/08	AP	
B111 01	2/15/08	TI	R*BLDG SLAB INSP VRU #: 001563711

*AP JV*

COMMENTS AND NOTES

-----  
ADDRESS : 77 CAROLINA OAKS CIR SUBDIV: CAROLINA OAKS 64 LOTS  
CONTRACTOR : BILL CLARK HOMES LLC PHONE : (252) 355-5805  
OWNER : BILL CLARK HOMES OF FAYETTEVILLE PHONE : (910) 426-2898  
PARCEL : 01-0544- - -0012- -44-  
APPL NUMBER: 07-50018351 CP NEW RESIDENTIAL (SFD)  
DIRECTIONS : CAROLINA OAKS #44-401 RT ON ELLIOTT  
BRIDGE RT ON WILL LUCAS RT INTO S/D.JD  
-----

STRUCTURE: 000 000 65X40 3BR W/GARAGE  
FLOOD ZONE . . . . : FLOOD ZONE X  
-----

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	1/31/08	JH	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001555524
	1/31/08	AP	t-pole passed
B103 01	2/07/08	JH	R*BLDG FOUND & TEMP SVC POLE VRU #: 001559432
	2/07/08	AP	
P309 01	2/12/08	JH	R*PLUMB UNDER SLAB VRU #: 001561722
	2/12/08	CA	not ready
P309 02	2/13/08	JH	R*PLUMB UNDER SLAB VRU #: 001562516
	2/13/08	AP	
B111 01	2/15/08	JH	R*BLDG SLAB INSP VRU #: 001563711
	2/15/08	AP	
A814 01	2/21/08	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001564471
	2/20/08	AP	77 CAROLINA OAKS CIR LOT 44
R425 01	3/18/08	TI	FOUR TRADE ROUGH IN VRU #: 001578377

DA JH

----- COMMENTS AND NOTES -----

ADDRESS : 77 CAROLINA OAKS CIR SUBDIV: CAROLINA OAKS 64 LOTS  
CONTRACTOR : BILL CLARK HOMES LLC PHONE : (252) 355-5805  
OWNER : BILL CLARK HOMES OF FAYETTEVIL PHONE : (910) 426-2898  
PARCEL : 01-0544- - -0012- -44-  
APPL NUMBER: 07-50018351 CP NEW RESIDENTIAL (SFD)  
DIRECTIONS : CAROLINA OAKS #44-401 RT ON ELLIOTT  
BRIDGE RT ON WILL LUCAS RT INTO S/D.JD

STRUCTURE: 000 000 65X40 3BR W/GARAGE  
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	1/31/08	JH	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001555524
	1/31/08	AP	t-pole passed
B103 01	2/07/08	JH	R*BLDG FOUND & TEMP SVC POLE VRU #: 001559432
	2/07/08	AP	
P309 01	2/12/08	JH	R*PLUMB UNDER SLAB VRU #: 001561722
	2/12/08	CA	not ready
P309 02	2/13/08	JH	R*PLUMB UNDER SLAB VRU #: 001562516
	2/13/08	AP	
B111 01	2/15/08	JH	R*BLDG SLAB INSP VRU #: 001563711
	2/15/08	AP	
A814 01	2/21/08	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001564471
	2/20/08	AP	77 CAROLINA OAKS CIR LOT 44
R425 01	3/18/08	JH	FOUR TRADE ROUGH IN VRU #: 001578377
	3/18/08	DA	1)Missing nail guards throughout house on electrical within 1 1/4" from edge. 2)10psi on gas line. 3)Missing braces on A03 & B01 truss. 4)Need receptacle on back of house.
R425 02	3/20/08	TI	FOUR TRADE ROUGH IN VRU #: 001580104
	3/20/08	DA DT	

COMMENTS AND NOTES

-----  
ADDRESS . . : 77 CAROLINA OAKS CIR SUBDIV: CAROLINA OAKS 64 LOTS  
CONTRACTOR : BILL CLARK HOMES LLC PHONE : (252) 355-5805  
OWNER . . . : BILL CLARK HOMES OF FAYETTEVIL PHONE : (910) 426-2898  
PARCEL . . . : 01-0544- - -0012- -44-  
APPL NUMBER: 07-50018351 CP NEW RESIDENTIAL (SFD)  
-----

DIRECTIONS : CAROLINA OAKS #44-401 RT ON ELLIOTT  
BRIDGE RT ON WILL LUCAS RT INTO S/D.JD  
-----

STRUCTURE: 000 000 65X40 3BR W/GARAGE  
FLOOD ZONE . . . . : FLOOD ZONE X  
# BEDROOMS . . . . . : 3.00 PROPOSED USE . . . . . : SFD  
SEPTIC - EXISTING? . . . . : NEW  
-----

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	1/31/08	JH	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001555524
	1/31/08	AP	t-pole passed
B103 01	2/07/08	JH	R*BLDG FOUND & TEMP SVC POLE VRU #: 001559432
	2/07/08	AP	
P309 01	2/12/08	JH	R*PLUMB UNDER SLAB VRU #: 001561722
	2/12/08	CA	not ready
P309 02	2/13/08	JH	R*PLUMB UNDER SLAB VRU #: 001562516
	2/13/08	AP	
B111 01	2/15/08	JH	R*BLDG SLAB INSP VRU #: 001563711
	2/15/08	AP	
A814 01	2/21/08	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001564471
	2/20/08	AP	77 CAROLINA OAKS CIR LOT 44
R425 01	3/18/08	JH	FOUR TRADE ROUGH IN VRU #: 001578377
	3/18/08	DA	1)Missing nail guards throughout house on electrical within 1 1/4" from edge. 2)10psi on gas line. 3)Missing braces on A03 & B01 truss. 4)Need receptacle on back of house.
R425 02	3/20/08	DT	FOUR TRADE ROUGH IN VRU #: 001580104
	3/20/08	DA	1. A03 trusses still missing web bracing. Okay to side and insulate.
I129 01	3/25/08	TI	R*INSULATION INSPECTION VRU #: 001582022
		AP JH	
R425 03	3/25/08	TI	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 001582667
		AP JH	

----- COMMENTS AND NOTES -----



ADDRESS : 77 CAROLINA OAKS CIR SUBDIV: CAROLINA OAKS 64 LOTS  
 CONTRACTOR : BILL CLARK HOMES LLC PHONE : (252) 355-5805  
 OWNER : BILL CLARK HOMES OF FAYETTEVILLE PHONE : (910) 426-2898  
 PARCEL : 01-0544- - -0012- -44-  
 APPL NUMBER: 07-50018351 CP NEW RESIDENTIAL (SFD)  
 DIRECTIONS : CAROLINA OAKS #44-401 RT ON ELLIOTT  
 BRIDGE RT ON WILL LUCAS RT INTO S/D.JD

STRUCTURE: 000 000 65X40 3BR W/GARAGE  
 FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	1/31/08	JH	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001555524
	1/31/08	AP	t-pole passed
B103 01	2/07/08	JH	R*BLDG FOUND & TEMP SVC POLE VRU #: 001559432
	2/07/08	AP	
P309 01	2/12/08	JH	R*PLUMB UNDER SLAB VRU #: 001561722
	2/12/08	CA	not ready
P309 02	2/13/08	JH	R*PLUMB UNDER SLAB VRU #: 001562516
	2/13/08	AP	
B111 01	2/15/08	JH	R*BLDG SLAB INSP VRU #: 001563711
	2/15/08	AP	
A814 01	2/21/08	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001564471
	2/20/08	AP	77 CAROLINA OAKS CIR LOT 44
R425 01	3/18/08	JH	FOUR TRADE ROUGH IN VRU #: 001578377
	3/18/08	DA	1)Missing nail guards throughout house on electrical within 1 1/4" from edge. 2)10psi on gas line. 3)Missing braces on A03 & B01 truss. 4)Need receptacle on back of house.
R425 02	3/20/08	DT	FOUR TRADE ROUGH IN VRU #: 001580104
	3/20/08	DA	1. A03 trusses still missing web bracing. Okay to side and insulate.
I129 01	3/25/08	JH	R*INSULATION INSPECTION VRU #: 001582022
	3/25/08	AP	
R425 03	3/25/08	JH	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 001582667
	3/25/08	AP	
H824 01	4/10/08	OT	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001592757
	4/10/08	AP	
R429 01	5/22/08	TI	FOUR TRADE FINAL VRU #: 001613150

*DA JH*  
 protection for WH  
 Seal Holes w/ WH  
 Label AHU  
 COMMENTS AND NOTES

ADDRESS : 77 CAROLINA OAKS CIR SUBDIV: CAROLINA OAKS 64 LOTS  
CONTRACTOR : BILL CLARK HOMES LLC PHONE : (252) 355-5805  
OWNER : BILL CLARK HOMES OF FAYETTEVILLE PHONE : (910) 426-2898  
PARCEL : 01-0544- - -0012- -44-  
APPL NUMBER: 07-50018351 CP NEW RESIDENTIAL (SFD)  
DIRECTIONS : CAROLINA OAKS #44-401 RT ON ELLIOTT  
BRIDGE RT ON WILL LUCAS RT INTO S/D.JD

STRUCTURE: 000 000 65X40 3BR W/GARAGE  
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	1/31/08	JH	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001555524
	1/31/08	AP	t-pole passed
B103 01	2/07/08	JH	R*BLDG FOUND & TEMP SVC POLE VRU #: 001559432
	2/07/08	AP	
P309 01	2/12/08	JH	R*PLUMB UNDER SLAB VRU #: 001561722
	2/12/08	CA	not ready
P309 02	2/13/08	JH	R*PLUMB UNDER SLAB VRU #: 001562516
	2/13/08	AP	
B111 01	2/15/08	JH	R*BLDG SLAB INSP VRU #: 001563711
	2/15/08	AP	
A814 01	2/21/08	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001564471
	2/20/08	AP	77 CAROLINA OAKS CIR LOT 44
R425 01	3/18/08	JH	FOUR TRADE ROUGH IN VRU #: 001578377
	3/18/08	DA	1)Missing nail guards throughout house on electrical within 1 1/4" from edge. 2)10psi on gas line. 3)Missing braces on A03 & B01 truss. 4)Need receptacle on back of house.
R425 02	3/20/08	DT	FOUR TRADE ROUGH IN VRU #: 001580104
	3/20/08	DA	1. AO3 trusses still missing web bracing. Okay to side and insulate.
I129 01	3/25/08	JH	R*INSULATION INSPECTION VRU #: 001582022
	3/25/08	AP	
R425 03	3/25/08	JH	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 001582667
	3/25/08	AP	
H824 01	4/10/08	OT	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001592757
	4/10/08	AP	
R429 01	5/22/08	JH	FOUR TRADE FINAL VRU #: 001613150
	5/22/08	DA	✓ Protection for water heater in garage. ✓ Seal holes behind water heater. ✓ Label AHU in attic.
R429 02	5/23/08	TI	FOUR TRADE FINAL VRU #: 001614266

AP JV

COMMENTS AND NOTES

**COUNTY OF HARNETT  
DEPARTMENT OF BUILDING INSPECTION  
AND PLANNING/DEVELOPMENT  
CERTIFICATE OF OCCUPANCY**

This certificate issued pursuant to the requirements of Section 105 of the North Carolina State Building Code and the Harnett County Zoning Ordinance certifies at the time of issuance this structure was in compliance with the various ordinances of the County of Harnett regulating development and building construction or use. For the following:

Use Classification: SFD

Conditional Use Permit No.: \_\_\_\_\_

Type of Construction: V

Building Permit No.: \_\_\_\_\_

Owner of Building: Bill Clark Homes

Electrical Permit No.: \_\_\_\_\_

Building Address: 77 Carolina Oaks Cir

Insulation Permit No.: \_\_\_\_\_

Zoning District: \_\_\_\_\_

Plumbing Permit No.: \_\_\_\_\_

Zoning Permit No.: \_\_\_\_\_

Mech. Permit No.: \_\_\_\_\_

Date: 5-23-08

Envir. C.O. No.: \_\_\_\_\_

James Hill  
Building Official

Zoning Official

07-50016351