
ADDRESS . : 97 CAROLINA OAKS CIR
CONTRACTOR : BILL CLARK HOMES LLC
OWNER . . : BILL CLARK HOMES OF FAYETTEVIL
PARCEL . . : 01-0544- - -0012- -45-
APPL NUMBER: 07-50018352 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : CAROLINA OAKS #45-401 RT ON ELLIOTT
BRIDGE RT ON WILL LUCAS RT INTO S/D.JD

SUBDIV: CAROLINA OAKS 64 LOTS
PHONE : (252) 355-5805
PHONE : (910) 426-2898

STRUCTURE: 000 000 65X40 3BR W/GARAGE
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS	
B101 01	1/31/08	TI <i>AP JH</i>	R*BLDG FOOTING / TEMP SVC POLE <i>T-pole passed</i>	VRU #: 001555533
----- COMMENTS AND NOTES -----				

ADDRESS : 97 CAROLINA OAKS CIR
CONTRACTOR : BILL CLARK HOMES LLC
OWNER : BILL CLARK HOMES OF FAYETTEVIL
PARCEL : 01-0544- - -0012- -45-
APPL NUMBER: 07-50018352 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : CAROLINA OAKS #45-401 RT ON ELLIOTT
BRIDGE RT ON WILL LUCAS RT INTO S/D.JD

SUBDIV: CAROLINA OAKS 64 LOTS
PHONE : (252) 355-5805
PHONE : (910) 426-2898

STRUCTURE: 000 000 65X40 3BR W/GARAGE
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	1/31/08	JH	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001555533
	1/31/08	AP	t-pole passed
B103 01	2/07/08	TI	R*BLDG FOUND & TEMP SVC POLE VRU #: 001559423

AP JH

----- COMMENTS AND NOTES -----

ADDRESS . : 97 CAROLINA OAKS CIR SUBDIV: CAROLINA OAKS 64 LOTS
CONTRACTOR : BILL CLARK HOMES LLC PHONE : (252) 355-5805
OWNER . . : BILL CLARK HOMES OF FAYETTEVIL PHONE : (910) 426-2898
PARCEL . . : 01-0544- - -0012- -45-
APPL NUMBER: 07-50018352 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : CAROLINA OAKS #45-401 RT ON ELLIOTT
BRIDGE RT ON WILL LUCAS RT INTO S/D.JD

STRUCTURE: 000 000 65X40 3BR W/GARAGE
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	1/31/08	JH	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001555533
	1/31/08	AP	t-pole passed
B103 01	2/07/08	JH	R*BLDG FOUND & TEMP SVC POLE VRU #: 001559423
	2/07/08	AP	
P309 01	2/12/08	JH	R*PLUMB UNDER SLAB VRU #: 001561713
	2/12/08	AP	
B111 01	2/15/08	TI	R*BLDG SLAB INSP VRU #: 001563720

AP JD

----- COMMENTS AND NOTES -----

ADDRESS . : 97 CAROLINA OAKS CIR SUBDIV: CAROLINA OAKS 64 LOTS
CONTRACTOR : BILL CLARK HOMES LLC PHONE : (252) 355-5805
OWNER . . : BILL CLARK HOMES OF FAYETTEVILLE PHONE : (910) 426-2898
PARCEL . . : 01-0544- - -0012- -45-
APPL NUMBER: 07-50018352 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : CAROLINA OAKS #45-401 RT ON ELLIOTT
BRIDGE RT ON WILL LUCAS RT INTO S/D.JD

STRUCTURE: 000 000 65X40 3BR W/GARAGE
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	1/31/08	JH	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001555533
	1/31/08	AP	t-pole passed
B103 01	2/07/08	JH	R*BLDG FOUND & TEMP SVC POLE VRU #: 001559423
	2/07/08	AP	
P309 01	2/12/08	JH	R*PLUMB UNDER SLAB VRU #: 001561713
	2/12/08	AP	
B111 01	2/15/08	JH	R*BLDG SLAB INSP VRU #: 001563720
	2/15/08	AP	
A814 01	2/21/08	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001564462
	2/20/08	AP	97 CAROLINA OAKS CIR LOT 45
R425 01	3/18/08	TI	FOUR TRADE ROUGH IN VRU #: 001578386

DA JH

----- COMMENTS AND NOTES -----

ADDRESS . : 97 CAROLINA OAKS CIR SUBDIV: CAROLINA OAKS 64 LOTS
CONTRACTOR : BILL CLARK HOMES LLC PHONE : (252) 355-5805
OWNER . . : BILL CLARK HOMES OF FAYETTEVIL PHONE : (910) 426-2898
PARCEL . . : 01-0544- - -0012- -45-
APPL NUMBER: 07-50018352 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : CAROLINA OAKS #45-401 RT ON ELLIOTT
BRIDGE RT ON WILL LUCAS RT INTO S/D.JD

STRUCTURE: 000 000 65X40 3BR W/GARAGE
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	1/31/08	JH	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001555533
	1/31/08	AP	t-pole passed
B103 01	2/07/08	JH	R*BLDG FOUND & TEMP SVC POLE VRU #: 001559423
	2/07/08	AP	
P309 01	2/12/08	JH	R*PLUMB UNDER SLAB VRU #: 001561713
	2/12/08	AP	
B111 01	2/15/08	JH	R*BLDG SLAB INSP VRU #: 001563720
	2/15/08	AP	
A814 01	2/21/08	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001564462
	2/20/08	AP	97 CAROLINA OAKS CIR LOT 45
R425 01	3/18/08	JH	FOUR TRADE ROUGH IN VRU #: 001578386
	3/18/08	DA	1)Replace cut stud in back left corner of back left bedroom. 2)Replace damaged stud in spare bathroom behind toilet. 3)Flex duct for spare bath exhaust fan 14' max. 4)Missing nail guards throughout house on electrical within 1 1/4" of edge. 5)10psi on gas line.
R425 02	3/20/08	TI	FOUR TRADE ROUGH IN VRU #: 001580113
	<u>3/20/08</u>	<u>DA</u>	

----- COMMENTS AND NOTES -----

ADDRESS . . : 97 CAROLINA OAKS CIR SUBDIV: CAROLINA OAKS 64 LOTS
 CONTRACTOR : BILL CLARK HOMES LLC PHONE : (252) 355-5805
 OWNER . . : BILL CLARK HOMES OF FAYETTEVILLE PHONE : (910) 426-2898
 PARCEL . . : 01-0544- - -0012- -45-
 APPL NUMBER: 07-50018352 CP NEW RESIDENTIAL (SFD)

DIRECTIONS : CAROLINA OAKS #45-401 RT ON ELLIOTT
 BRIDGE RT ON WILL LUCAS RT INTO S/D.JD

STRUCTURE: 000 000 65X40 3BR W/GARAGE

FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	1/31/08	JH	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001555533
	1/31/08	AP	t-pole passed
B103 01	2/07/08	JH	R*BLDG FOUND & TEMP SVC POLE VRU #: 001559423
	2/07/08	AP	
P309 01	2/12/08	JH	R*PLUMB UNDER SLAB VRU #: 001561713
	2/12/08	AP	
B111 01	2/15/08	JH	R*BLDG SLAB INSP VRU #: 001563720
	2/15/08	AP	
A814 01	2/21/08	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001564462
	2/20/08	AP	97 CAROLINA OAKS CIR LOT 45
R425 01	3/18/08	JH	FOUR TRADE ROUGH IN VRU #: 001578386
	3/18/08	DA	1)Replace cut stud in back left corner of back left bedroom. 2)Replace damaged stud in spare bathroom behind toilet. 3)Flex duct for spare bath exhaust fan 14' max. 4)Missing nail guards throughout house on electrical within 1 1/4" of edge. 5)10psi on gas line.
R425 02	3/20/08	DT	FOUR TRADE ROUGH IN VRU #: 001580113
	3/20/08	DA	1. Need nail guard for phone between middle and mast bath at top plate. Okay to side and insulate.
I129 01	3/25/08	TI	R*INSULATION INSPECTION VRU #: 001582031
		<i>AP JV</i>	
R425 03	3/25/08	TI	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 001582659
		<i>AP JV</i>	

COMMENTS AND NOTES

ADDRESS : 97 CAROLINA OAKS CIR SUBDIV: CAROLINA OAKS 64 LOTS
 CONTRACTOR : BILL CLARK HOMES LLC PHONE : (252) 355-5805
 OWNER : BILL CLARK HOMES OF FAYETTEVILLE PHONE : (910) 426-2898
 PARCEL : 01-0544- - -0012- -45-
 APPL NUMBER: 07-50018352 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : CAROLINA OAKS #45-401 RT ON ELLIOTT
 BRIDGE RT ON WILL LUCAS RT INTO S/D.JD

STRUCTURE: 000 000 65X40 3BR W/GARAGE
 FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	1/31/08	JH	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001555533
	1/31/08	AP	t-pole passed
B103 01	2/07/08	JH	R*BLDG FOUND & TEMP SVC POLE VRU #: 001559423
	2/07/08	AP	
P309 01	2/12/08	JH	R*PLUMB UNDER SLAB VRU #: 001561713
	2/12/08	AP	
B111 01	2/15/08	JH	R*BLDG SLAB INSP VRU #: 001563720
	2/15/08	AP	
A814 01	2/21/08	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001564462
	2/20/08	AP	✓ 97 CAROLINA OAKS CIR LOT 45
R425 01	3/18/08	JH	FOUR TRADE ROUGH IN VRU #: 001578386
	3/18/08	DA	1)Replace cut stud in back left corner of back left bedroom. 2)Replace damaged stud in spare bathroom behind toilet. 3)Flex duct for spare bath exhaust fan 14' max. 4)Missing nail guards throughout house on electrical within 1 1/4" of edge. 5)10psi on gas line.
R425 02	3/20/08	DT	FOUR TRADE ROUGH IN VRU #: 001580113
	3/20/08	DA	1. Need nail guard for phone between middle and mast bath at top plate. Okay to side and insulate.
I129 01	3/25/08	JH	R*INSULATION INSPECTION VRU #: 001582031
	3/25/08	AP	
R425 03	3/25/08	JH	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 001582659
	3/25/08	AP	
H824 01	4/10/08	OT	✓ ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001592724
	4/10/08	AP	
R429 01	5/22/08	TI	FOUR TRADE FINAL VRU #: 001613169

DA JH protection on WH seals Holes @ WH
 COMMENTS AND NOTES

ADDRESS : 97 CAROLINA OAKS CIR SUBDIV: CAROLINA OAKS 64 LOTS
CONTRACTOR : BILL CLARK HOMES LLC PHONE : (252) 355-5805
OWNER : BILL CLARK HOMES OF FAYETTEVILLE PHONE : (910) 426-2898
PARCEL : 01-0544- - -0012- -45-
APPL NUMBER: 07-50018352 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : CAROLINA OAKS #45-401 RT ON ELLIOTT
BRIDGE RT ON WILL LUCAS RT INTO S/D.JD

STRUCTURE: 000 000 65X40 3BR W/GARAGE
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	1/31/08	JH	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001555533
	1/31/08	AP	t-pole passed
B103 01	2/07/08	JH	R*BLDG FOUND & TEMP SVC POLE VRU #: 001559423
	2/07/08	AP	
P309 01	2/12/08	JH	R*PLUMB UNDER SLAB VRU #: 001561713
	2/12/08	AP	
B111 01	2/15/08	JH	R*BLDG SLAB INSP VRU #: 001563720
	2/15/08	AP	
A814 01	2/21/08	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001564462
	2/20/08	AP	97 CAROLINA OAKS CIR LOT 45
R425 01	3/18/08	JH	FOUR TRADE ROUGH IN VRU #: 001578386
	3/18/08	DA	1)Replace cut stud in back left corner of back left bedroom. 2)Replace damaged stud in spare bathroom behind toilet. 3)Flex duct for spare bath exhaust fan 14' max. 4)Missing nail guards throughout house on electrical within 1 1/4" of edge. 5)10psi on gas line.
R425 02	3/20/08	DT	FOUR TRADE ROUGH IN VRU #: 001580113
	3/20/08	DA	1. Need nail guard for phone between middle and mast bath at top plate. Okay to side and insulate.
I129 01	3/25/08	JH	R*INSULATION INSPECTION VRU #: 001582031
	3/25/08	AP	
R425 03	3/25/08	JH	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 001582659
	3/25/08	AP	
H824 01	4/10/08	OT	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001592724
	4/10/08	AP	
R429 01	5/22/08	JH	FOUR TRADE FINAL VRU #: 001613169
	5/22/08	DA	1)Protection for water heater in garage. 2)Seal holes behind water heater.
R429 02	5/23/08	TI	FOUR TRADE FINAL VRU #: 001614373

AP JV

----- COMMENTS AND NOTES -----

**COUNTY OF HARNETT
DEPARTMENT OF BUILDING INSPECTION
AND PLANNING/DEVELOPMENT
CERTIFICATE OF OCCUPANCY**

This certificate issued pursuant to the requirements of Section 105 of the North Carolina State Building Code and the Harnett County Zoning Ordinance certifies at the time of issuance this structure was in compliance with the various ordinances of the County of Harnett regulating development and building construction or use. For the following:

Use Classification: SFD

Conditional Use Permit No.: _____

Type of Construction: V

Building Permit No.: _____

Owner of Building: Bill Clark Homes

Electrical Permit No.: _____

Building Address: 97 Carolina Oaks Cir

Insulation Permit No.: _____

Zoning District: _____

Plumbing Permit No.: _____

Zoning Permit No.: _____

Mech. Permit No.: _____

Envir. C.O. No.: _____

Date: 5-23-08

James T. Hall
Building Official

07-50018352
Zoning Official