
ADDRESS . : 86 CAROLINA OAKS CIR SUBDIV: CAROLINA OAKS 64 LOTS
CONTRACTOR : ELK RIDGE AT SOUTHVIEW LLC PHONE : (910) 323-4393
OWNER . . : RAM DEVELOPMENT INC #4 PHONE : (910) 323-4301
PARCEL . . : 01-0544- - -0012- -04-
APPL NUMBER: 07-50018372 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : CAROLINA OAKS #4-401 TO ELLIOTT BRIDGE
TO WILL LUCAS S/D ON RT.JD

STRUCTURE: 000 000 58X37 3BR W/GARAGE & DECK
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	12/04/07	TI <i>DA JH</i>	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001529585

----- COMMENTS AND NOTES -----

ADDRESS . . : 86 CAROLINA OAKS CIR
CONTRACTOR : ELK RIDGE AT SOUTHVIEW LLC
OWNER . . . : RAM DEVELOPMENT INC #4
PARCEL . . . : 01-0544- - -0012- -04-
APPL NUMBER: 07-50018372 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : CAROLINA OAKS #4-401 TO ELLIOTT BRIDGE
TO WILL LUCAS S/D ON RT.JD

SUBDIV: CAROLINA OAKS 64 LOTS
PHONE : (910) 323-4393
PHONE : (910) 323-4301

STRUCTURE: 000 000 58X37 3BR W/GARAGE & DECK
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	12/04/07 12/04/07	TH DA	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001529585 1)Depth of pier footings not marked with grade stakes. 2)Missing one pier on left side of house, circled on plans.
B101 02	12/06/07 <u>12/6/07</u>	TI <u>AP DJ</u>	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001530716

----- COMMENTS AND NOTES -----

ADDRESS . . : 86 CAROLINA OAKS CIR SUBDIV: CAROLINA OAKS 64 LOTS
CONTRACTOR : ELK RIDGE AT SOUTHVIEW LLC PHONE : (910) 323-4393
OWNER . . : RAM DEVELOPMENT INC #4 PHONE : (910) 323-4301
PARCEL . . : 01-0544- - -0012- -04-
APPL NUMBER: 07-50018372 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : CAROLINA OAKS #4-401 TO ELLIOTT BRIDGE
TO WILL LUCAS S/D ON RT.JD

STRUCTURE: 000 000 58X37 3BR W/GARAGE & DECK
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	12/04/07 12/04/07	JH DA	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001529585 1)Depth of pier footings not marked with grade stakes. 2)Missing one pier on left side of house, circled on plans.
B101 02	12/06/07 12/06/07	DT AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001530716
A814 01	12/31/07	TI	ADDRESS CONFIRMATION VRU #: 001540764
B103 01	12/31/07	TI	R*BLDG FOUND & TEMP SVC POLE VRU #: 001540772 <i>AP-MR</i>

COMMENTS AND NOTES

ADDRESS . : 86 CAROLINA OAKS CIR SUBDIV: CAROLINA OAKS 64 LOTS
CONTRACTOR : ELK RIDGE AT SOUTHVIEW LLC PHONE : (910) 323-4393
OWNER . . : RAM DEVELOPMENT INC #4 PHONE : (910) 323-4301
PARCEL . . : 01-0544- - -0012- -04-
APPL NUMBER: 07-50018372 CP NEW RESIDENTIAL (SFD)

DIRECTIONS : CAROLINA OAKS #4-401 TO ELLIOTT BRIDGE
TO WILL LUCAS S/D ON RT.JD

STRUCTURE: 000 000 58X37 3BR W/GARAGE & DECK
FLOOD ZONE . . . : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	12/04/07 12/04/07	JH DA	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001529585 1)Depth of pier footings not marked with grade stakes. 2)Missing one pier on left side of house, circled on plans.
B101 02	12/06/07 12/06/07	DT AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001530716
A814 01	12/31/07 12/31/07	MR AP	ADDRESS CONFIRMATION VRU #: 001540764
B103 01	12/31/07 12/31/07	MR AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001540772
B105 01	1/24/08	TT <i>AP JH</i>	R*OPEN FLOOR TIME: 17:00 VRU #: 001552017

----- COMMENTS AND NOTES -----

ADDRESS : 86 CAROLINA OAKS CIR
CONTRACTOR : ELK RIDGE AT SOUTHVUEW LLC
OWNER : RAM DEVELOPMENT INC #4
PARCEL : 01-0544- - -0012- -04-
APPL NUMBER: 07-50018372 CP NEW RESIDENTIAL (SFD)

SUBDIV: CAROLINA OAKS 64 LOTS
PHONE : (910) 323-4393
PHONE : (910) 323-4301

DIRECTIONS : CAROLINA OAKS #4-401 TO ELLIOTT BRIDGE
TO WILL LUCAS S/D ON RT.JD

STRUCTURE: 000 000 58X37 3BR W/GARAGE & DECK
FLOOD ZONE . . . : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	12/04/07 12/04/07	JH DA	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001529585 1)Depth of pier footings not marked with grade stakes. 2)Missing one pier on left side of house, circled on plans.
B101 02	12/06/07 12/06/07	DT AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001530716
A814 01	12/31/07 12/31/07	MR AP	ADDRESS CONFIRMATION VRU #: 001540764
B103 01	12/31/07 12/31/07	MR AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001540772
B105 01	1/24/08 1/24/08	JH AP	R*OPEN FLOOR TIME: 17:00 VRU #: 001552017
B101 03	2/01/08 2/01/08	TI CA	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001556328
E207 01	2/01/08	TI <i>AP JH</i>	R*ELEC TEMP SERVICE POLE TIME: 17:00 VRU #: 001557024

----- COMMENTS AND NOTES -----

ADDRESS : 86 CAROLINA OAKS CIR SUBDIV: CAROLINA OAKS 64 LOTS
CONTRACTOR : ELK RIDGE AT SOUTHVIEW LLC PHONE : (910) 323-4393
OWNER : RAM DEVELOPMENT INC #4 PHONE : (910) 323-4301
PARCEL : 01-0544- - -0012- -04-
APPL NUMBER: 07-50018372 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : CAROLINA OAKS #4-401 TO ELLIOTT BRIDGE
TO WILL LUCAS S/D ON RT.JD

STRUCTURE: 000 000 58X37 3BR W/GARAGE & DECK
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	12/04/07 12/04/07	JH DA	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001529585 1)Depth of pier footings not marked with grade stakes. 2)Missing one pier on left side of house, circled on plans.
B101 02	12/06/07 12/06/07	DT AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001530716
A814 01	12/31/07 12/31/07	MR AP	ADDRESS CONFIRMATION VRU #: 001540764
B103 01	12/31/07 12/31/07	MR AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001540772
B105 01	1/24/08 1/24/08	JH AP	R*OPEN FLOOR TIME: 17:00 VRU #: 001552017
B101 03	2/01/08 2/01/08	TI CA	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001556328
E207 01	2/01/08 2/01/08	JH AP	R*ELEC TEMP SERVICE POLE TIME: 17:00 VRU #: 001557024
R425 01	2/21/08 <u>2/21/08</u>	TI <u>DA DT</u>	FOUR TRADE ROUGH IN VRU #: 001566371

----- COMMENTS AND NOTES -----

ADDRESS : 86 CAROLINA OAKS CIR
CONTRACTOR : ELK RIDGE AT SOUTHVIEW LLC
OWNER : RAM DEVELOPMENT INC #4
PARCEL : 01-0544- - -0012- -04-
APPL NUMBER: 07-50018372 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : CAROLINA OAKS #4-401 TO ELLIOTT BRIDGE
TO WILL LUCAS S/D ON RT.JD

SUBDIV: CAROLINA OAKS 64 LOTS
PHONE : (910) 323-4393
PHONE : (910) 323-4301

STRUCTURE: 000 000 58X37 3BR W/GARAGE & DECK
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	12/04/07 12/04/07	JH DA	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001529585 1)Depth of pier footings not marked with grade stakes. 2)Missing one pier on left side of house, circled on plans.
B101 02	12/06/07 12/06/07	DT AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001530716
A814 01	12/31/07 12/31/07	MR AP	ADDRESS CONFIRMATION VRU #: 001540764
B103 01	12/31/07 12/31/07	MR AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001540772
B105 01	1/24/08 1/24/08	JH AP	R*OPEN FLOOR TIME: 17:00 VRU #: 001552017
B101 03	2/01/08 2/01/08	TI CA	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001556328
E207 01	2/01/08 2/01/08	JH AP	R*ELEC TEMP SERVICE POLE TIME: 17:00 VRU #: 001557024
R425 01	2/21/08 2/21/08	DT DA	FOUR TRADE ROUGH IN VRU #: 001566371 X . No gas pressure test. X . Leak on spare bath tub. Re test. Okay to side and insulate.
I129 01	2/26/08	TI AP JH	R*INSULATION INSPECTION VRU #: 001568179
R425 02	2/26/08	TI AP JH	FOUR TRADE ROUGH IN VRU #: 001568161

COMMENTS AND NOTES

ADDRESS : ✓ 86 CAROLINA OAKS CIR SUBDIV: CAROLINA OAKS 64 LOTS
CONTRACTOR : ELK RIDGE AT SOUTHVIEW LLC PHONE : (910) 323-4393
OWNER : RAM DEVELOPMENT INC #4 PHONE : (910) 323-4301
PARCEL : 01-0544- - -0012- -04-
APPL NUMBER: 07-50018372 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : CAROLINA OAKS #4-401 TO ELLIOTT BRIDGE
TO WILL LUCAS S/D ON RT.JD

STRUCTURE: 000 000 58X37 3BR W/GARAGE & DECK
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	12/04/07 12/04/07	JH DA	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001529585 1)Depth of pier footings not marked with grade stakes. 2)Missing one pier on left side of house, circled on plans.
B101 02	12/06/07 12/06/07	DT AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001530716
A814 01	12/31/07 12/31/07	MR AP	ADDRESS CONFIRMATION VRU #: 001540764
B103 01	12/31/07 12/31/07	MR AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001540772
B105 01	1/24/08 1/24/08	JH AP	R*OPEN FLOOR TIME: 17:00 VRU #: 001552017
B101 03	2/01/08 2/01/08	TI CA	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001556328
E207 01	2/01/08 2/01/08	JH AP	R*ELEC TEMP SERVICE POLE TIME: 17:00 VRU #: 001557024
R425 01	2/21/08 2/21/08	DT DA	FOUR TRADE ROUGH IN VRU #: 001566371 1, No gas pressure test. 2. Leak on spare bath tub. Re test. Okay to side and insulate.
I129 01	2/26/08 2/26/08	JH AP	R*INSULATION INSPECTION VRU #: 001568179
R425 02	2/26/08 2/26/08	JH AP	FOUR TRADE ROUGH IN VRU #: 001568161
H824 01	3/20/08 3/20/08	OT AP	✓ ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001581990
R429 01	6/02/08	TI	FOUR TRADE FINAL VRU #: 001618057

AP JH

COMMENTS AND NOTES

**COUNTY OF HARNETT
DEPARTMENT OF BUILDING INSPECTION
AND PLANNING/DEVELOPMENT
CERTIFICATE OF OCCUPANCY**

This certificate issued pursuant to the requirements of Section 105 of the North Carolina State Building Code and the Harnett County Zoning Ordinance certifies at the time of issuance this structure was in compliance with the various ordinances of the County of Harnett regulating development and building construction or use. For the following:

Use Classification: SFD Conditional Use Permit No.: _____
Type of Construction: V Building Permit No.: _____
Owner of Building: Ram Development Electrical Permit No.: _____
Building Address: 86 Caroline Oaks Cir Insulation Permit No.: _____
Zoning District: _____ Plumbing Permit No.: _____
Zoning Permit No.: _____ Mech. Permit No.: DT-50018378
Date: 6-2-08 Envir. C.O. No.: _____

James Hall
Building Official

Zoning Official