

ADDRESS . . : 302 CURRAGH CV
CONTRACTOR : HAMPTON CUSTOM BUILDERS INC
OWNER . . . : C & C PROPERTIES #12
PARCEL . . . : 08-0655- - -0067- -13-
APPL NUMBER: 07-50018386 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : MAGNOLIA CREST #9 - 401N TO RAWLS CLUB
RD RT THEN LEFT INTO S/D LOT ON LEFT IN
CULDESAC. JD

SUBDIV: MAGNOLIA CREST 29LOTS
PHONE : (919) 524-2915
PHONE :

STRUCTURE: 000 000 56X30 3BR CRAWL W/GARAGE & SCREEN PORCH
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	10/12/07	BS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001502590
	10/12/07	AP	could not locate a ground rod on t pole
A814 01	10/17/07	TI	ADDRESS CONFIRMATION VRU #: 001506112
E207 01	10/17/07	TI	R*ELEC TEMP SERVICE POLE VRU #: 001506138
B101 02	10/17/07	TI	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 001506120 WILL BE FOR THE PORCH FOOTINGS ***** *****

10-17-07
APBS

COMMENTS AND NOTES

ADDRESS : 302 CURRAGH CV SUBDIV: MAGNOLIA CREST 29LOTS
CONTRACTOR : HAMPTON CUSTOM BUILDERS INC PHONE : (919) 524-2915
OWNER : C & C PROPERTIES #12 PHONE :
PARCEL : 08-0655- - -0067- -13-
APPL NUMBER: 07-50018386 CP NEW RESIDENTIAL (SFD)

DIRECTIONS : MAGNOLIA CREST #9 - 401N TO RAWLS CLUB
RD RT THEN LEFT INTO S/D LOT ON LEFT IN
CULDESAC. JD

STRUCTURE: 000 000 56X30 3BR CRAWL W/GARAGE & SCREEN PORCH
FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3.00 PROPOSED USE : SFD
SEPTIC - EXISTING? : NEW

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	10/12/07	BS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001502590
	10/12/07	DA	could not locate a ground rod on t pole
E207 01	10/17/07	TI	R*ELEC TEMP SERVICE POLE VRU #: 001506138
	10/17/07	AP	APPROVED PER BRAD
			T/S: 10/17/2007 02:41 PM DJOHNSON -----
A814 01	10/17/07	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001506112
	10/17/07	AP	302 Curragh Cv Lot 12
B101 02	10/17/07	TI	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 001506120
	10/17/07	AP	WILL BE FOR THE PORCH FOOTINGS ***** *****
B103 01	10/18/07	TI	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 001507052
	<u>10-18-07</u>	<u>APBS</u>	

----- COMMENTS AND NOTES -----

ADDRESS : 302 CURRAGH CV
CONTRACTOR : HAMPTON CUSTOM BUILDERS INC
OWNER : C & C PROPERTIES #12
PARCEL : 08-0655- - -0067- -13-
APPL NUMBER: 07-50018386 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : MAGNOLIA CREST #9 - 401N TO RAWLS CLUB
RD RT THEN LEFT INTO S/D LOT ON LEFT IN
CULDESAC. JD

SUBDIV: MAGNOLIA CREST 29LOTS
PHONE : (919) 524-2915
PHONE :

STRUCTURE: 000 000 56X30 3BR CRAWL W/GARAGE & SCREEN PORCH
FLOOD ZONE . . . : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	10/12/07	BS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001502590
	10/12/07	DA	could not locate a ground rod on t pole
E207 01	10/17/07	TI	R*ELEC TEMP SERVICE POLE VRU #: 001506138
	10/17/07	AP	APPROVED PER BRAD
			T/S: 10/17/2007 02:41 PM DJOHNSON -----
A814 01	10/17/07	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001506112
	10/17/07	AP	302 Curragh Cv Lot 12
B101 02	10/17/07	TI	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 001506120
	10/17/07	AP	WILL BE FOR THE PORCH FOOTINGS ***** *****
B103 01	10/18/07	BS	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 001507052
	10/18/07	AP	
B105 01	10/22/07	BS	R*OPEN FLOOR VRU #: 001507870
	10/22/07	AP	
R427 01	11/09/07	TI	FOUR TRADE ROUGH IN >2500 VRU #: 001518257

11-9-07 ALBS

----- COMMENTS AND NOTES -----

ADDRESS . . : 302 CURRAGH CV
 CONTRACTOR : HAMPTON CUSTOM BUILDERS INC
 OWNER . . . : C & C PROPERTIES #12
 PARCEL . . . : 08-0655- - -0067- -13-
 APPL NUMBER: 07-50018386 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : MAGNOLIA CREST #9 - 401N TO RAWLS CLUB
 RD RT THEN LEFT INTO S/D LOT ON LEFT IN
 CULDESAC. JD

SUBDIV: MAGNOLIA CREST 29LOTS
 PHONE : (919) 524-2915
 PHONE :

STRUCTURE: 000 000 56X30 3BR CRAWL W/GARAGE & SCREEN PORCH

FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	10/12/07	BS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001502590
	10/12/07	DA	could not locate a ground rod on t pole
E207 01	10/17/07	TI	R*ELEC TEMP SERVICE POLE VRU #: 001506138
	10/17/07	AP	APPROVED PER BRAD
			T/S: 10/17/2007 02:41 PM DJOHNSON -----
A814 01	10/17/07	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001506112
	10/17/07	AP	302 Curragh Cv Lot 12
B101 02	10/17/07	TI	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 001506120
	10/17/07	AP	WILL BE FOR THE PORCH FOOTINGS ***** *****
B103 01	10/18/07	BS	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 001507052
	10/18/07	AP	
B105 01	10/22/07	BS	R*OPEN FLOOR VRU #: 001507870
	10/22/07	AP	
R427 01	11/09/07	BS	FOUR TRADE ROUGH IN >2500 VRU #: 001518257
	11/09/07	AP	sheet inside garage wall w/ osb
I129 01	11/14/07	TI	R*INSULATION INSPECTION VRU #: 001519537
	<u>11-14</u>	<u>AP</u>	
R127 01	11/14/07	TI	ONE TRADE ROUGH IN > 2500 VRU #: 001519545
	<u>11-14</u>	<u>AP</u>	

COMMENTS AND NOTES

ADDRESS : 302 CURRAGH CV
CONTRACTOR : HAMPTON CUSTOM BUILDERS INC
OWNER : C & C PROPERTIES #12
PARCEL : 08-0655- - -0067- -13-
APPL NUMBER: 07-50018386 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : MAGNOLIA CREST #9 - 401N TO RAWLS CLUB
RD RT THEN LEFT INTO S/D LOT ON LEFT IN
CULDESAC. JD

SUBDIV: MAGNOLIA CREST 29LOTS
PHONE : (919) 524-2915
PHONE :

56784131

STRUCTURE: 000 000 56X30 3BR CRAWL W/GARAGE & SCREEN PORCH
FLOOD ZONE . . . : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	10/12/07	BS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001502590
	10/12/07	DA	could not locate a ground rod on t pole
E207 01	10/17/07	TI	R*ELEC TEMP SERVICE POLE VRU #: 001506138
	10/17/07	AP	APPROVED PER BRAD
			T/S: 10/17/2007 02:41 PM DJOHNSON -----
A814 01	10/17/07	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001506112
	10/17/07	AP	✓302 Curragh Cv Lot 12
B101 02	10/17/07	TI	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 001506120
	10/17/07	AP	WILL BE FOR THE PORCH FOOTINGS ***** *****
B103 01	10/18/07	BS	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 001507052
	10/18/07	AP	
B105 01	10/22/07	BS	R*OPEN FLOOR VRU #: 001507870
	10/22/07	AP	
R427 01	11/09/07	BS	FOUR TRADE ROUGH IN >2500 VRU #: 001518257
	11/09/07	AP	sheet inside garage wall w/ osb
I129 01	11/14/07	KS	R*INSULATION INSPECTION VRU #: 001519537
	11/14/07	AP	Soil not suitable for footing. Need engineers corection prior to pouring,
R127 01	11/14/07	KS	ONE TRADE ROUGH IN > 2500 VRU #: 001519545
	11/14/07	AP	Soil not suitable for footing. Need engineers corection prior to pouring,
H824 01	11/28/07	JM	✓ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001527845
	11/28/07	AP	
R431 01	1/18/08	TI	FOUR TRADE FINAL >2500 VRU #: 001549492

1.18.08 APBS

----- COMMENTS AND NOTES -----

**COUNTY OF HARNETT
DEPARTMENT OF BUILDING INSPECTION
AND PLANNING/DEVELOPMENT
CERTIFICATE OF OCCUPANCY**

This certificate issued pursuant to the requirements of Section 105 of the North Carolina State Building Code and the Harnett County Zoning Ordinance certifies at the time of issuance this structure was in compliance with the various ordinances of the County of Harnett regulating development and building construction or use. For the following:

Use Classification: SFO Conditional Use Permit No.: _____
Type of Construction: V Building Permit No.: _____
Owner of Building: Hamilton Custom Bldgs Electrical Permit No.: _____
Building Address: 302 Currough CV Insulation Permit No.: _____
Zoning District: _____ Plumbing Permit No.: _____
Zoning Permit No.: N/A Mech. Permit No.: 075
Date: 1-18-08 Envir. C.O. No.: _____

Brad Smith
Building Official

Zoning Official