

HTE# 07-5-18394RR

Harnett County Department of Public Health

24140

Improvement Permit

A building permit cannot be issued with only an Improvement Permit

ISSUED TO: Larry Terhune
 NEW REPAIR EXPANSION
 Type of Structure: SFD 36'x38.5'
 Proposed Wastewater System Type: Accepted System
 Projected Daily Flow: 360 GPD
 Number of bedrooms: 3 Number of Occupants: 6 max
 Basement Yes No
 Pump Required: Yes No May be required based on final location and elevations of facilities
 Type of Water Supply: Community Public Well Distance from well _____ feet
 Permit conditions: _____

PROPERTY LOCATION: Truelove Rd
 SUBDIVISION Taylor Pointe LOT # 9
 Site Improvements required prior to Construction Authorization Issuance: _____

Permit valid for: Five years
 No expiration

Authorized State Agent: Bryan McSwain, R.S. Date: 12/3/2007 SEE ATTACHED SITE SKETCH
 The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.

Construction Authorization

(Required for Building Permit)

The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout.

ISSUED TO: Larry Terhune PROPERTY LOCATION: Truelove Rd
 SUBDIVISION Taylor Pointe LOT # 9
 Facility Type: SFD 36'x38.5' New Expansion Repair
 Basement? Yes No Basement Fixtures? Yes No
 Type of Wastewater System** Accepted System (Initial) Wastewater Flow: 360 GPD
 (See note below, if applicable Drip-No Pretreatment (Repair))

Installation Requirements/Conditions

Septic Tank Size 1000 gallons Exact length of each trench 1x260 feet Trench Spacing: 9 Feet on Center
 Pump Tank Size _____ gallons Trenches shall be installed on contour at a Soil Cover: 6 inches
 Maximum Trench Depth of: 18 inches (Maximum soil cover shall not exceed 36" above the trench bottom)
 (Trench bottoms shall be level to +/-1/4" in all directions)
 Pump Requirements: _____ ft. TDH vs. _____ GPM Aggregate Depth: _____ inches below pipe
 Conditions: Run ditches on contour _____ inches above pipe
 _____ inches total

**If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.
 Owner/Legal Representative Signature: _____ Date: _____

This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit.
 SEE ATTACHED SITE SKETCH
 Authorized State Agent: Bryan McSwain, R.S. Date: 12/3/2007
 Construction Authorization Expiration Date: 12/3/2012

HTE# 07-5-18394 RR

Permit # 24140

Harnett County Department of Public Health Site Sketch

ISSUED TO: Larry Terhune PROPERTY LOCATOR: Travelove Rd
SUBDIVISION: Taylor Pointe LOT # 9
Authorized State Agent: Bryan McSwain, R.S. Date: 12/3/2007

*Permit issued in accordance
w/ consultants proposal

