

Property ID:
 Lot #:
 File #:
 Code:

SOIL SITE EVALUATION for ON-SITE WASTEWATER SYSTEM

Owner:

Address:

Applicant:

Date Evaluated: 9/19/07

Proposed Facility:

Design Flow (.1949):

Property Size:

Location of Site:

Property Recorded:

Water Supply:

- Public Individual Well

- Spring Other

Evaluation Method:

- Auger Boring Pit

Cut

Type of Wastewater:

- Sewage Industrial Process

Mixed

P R O F I L E	SOIL MORPHOLOGY 1941				OTHER PROFILE FACTORS			CLASSIFICATION	
	1940 Landscape Position Slope%	Horizon Depth (IN)	1941 Structure Texture	1941 Consistence Mineralogy	1942 Soil Wetness Color	1943 Soil Depth (IN)	1944 Soil Saprolite Class		1945 Rock Depth Horiz.
LS 4-670	0-18	G/L5	Vf NSNP						PS-4
	18-32	SBK/SC1	Ff SS SP						
	0-21	G/L5	Vf NSNP						
	21-31	SBK/SC1	Ff SS SP						
	0-24	G/L5	Vf NSNP						PS-4
	24-29	SBK/SC1	Ff SS SP						

Description	Initial System	Repair System
available Space (.1945)	✓	✓
ystem Type(s)	Accepted	APP
to LTAR	✓	✓

Other Factors (.1946): _____
 Site Classification (.1948): PS
 Evaluated By: BM JOT


COMMENTS: _____

<u>LANDSCAPE POSITIONS</u>	<u>GROUP</u>	<u>TEXTURES</u>	<u>.1955 LTAR</u>	<u>CONSISTENCE MOIST</u>	<u>WET</u>
R-RIDGE S-SHOULDER SLOPE L-LINEAR SLOPE FS-FOOT SLOPE N-NOSE SLOPE H-HEAD SLOPE CC-CONCLAVE SLOPE CV-CONVEX SLOPE T-TERRACE FP-FLOOD PLAN	I	S-SAND LS-LOAMY SAND	1.2 - 0.8	VFR-VERY FRIABLE FR-FRIABLE	NS-NON-STICKY SS-SLIGHTLY STICK S-STICKY
	II	SL-SANDY LOAM L-LOAM	0.8 - 0.6	FI-FIRM VFI-VERY FIRM EFI-EXTREMELY FIRM	VS-VERY STICKY NF-NON-PLASTIC SP-SLIGHTLY STICK P-PLASTIC VP-VERY PLASTIC
	III	SI-SILT- SIL-SILT LOAM CL-CLAY LOAM SCL-SANDY CLAY LOAM SICL-SILTY CLAY LOAM	0.6 - 0.3		
	IV	SIC-SILTY CLAY C-CLAY SC-SANDY CLAY	0.4 - 0.1		

STRUCTURE
 SG-SINGLE GRAIN
 M-MASSIVE
 CR-CRUMB
 GR-GRANULAR
 SBK-SUBANGULAR BLOCKY
 ABK-ANGULAR BLOCKY
 PL-PLATY
 PR-PRISMATIC

MINERALOGY
 SLIGHTLY EXPANSIVE
 EXPANSIVE

Show profile locations and other site features (dimensions, reference or benchmark, and North).



MINIMUM BUILDING SETBACKS
 ZONING: RA-20M

FRONT.....35'
 SIDE.....
 REAR.....25'

SITE PLAN APPROVAL


DISTRICT RA20M USE SFD

#BEDROOMS 4

Date 9/16/07 Zoning Administrator [Signature]



ADRIAN STREET 50' R/W (PUBLIC)



DOES LOT HAVE STATE ROAD FRONTAGE? YES NO
 DOES LOT HAVE RECORDED EASEMENT? YES NO

DRIVEWAY OR ACCESS DRIVE DRAINAGE CULVERT
 TYPE AND SIZE _____

NOTES:

PUBLIC WATER SYSTEM YES NO
 WELL YES NO
 PUBLIC SEWER SYSTEM YES NO
 HOUSE DIMENSIONS: 77' x 44'

IMPERVIOUS SURFACE TABLE

HOUSE.....	879 SF
DRIVE & WALK.....	2434 SF
TOTAL.....	3313 SF