

ADDRESS . : 26 CAROLINA OAKS CIR
CONTRACTOR : ELK RIDGE AT SOUTHVIEW LLC
OWNER . . : RAM DEVELOPMENT INC
PARCEL . . : 01-0544- - -0012- -01-
APPL NUMBER: 07-50018461 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : SOUTH 401 TO ELLIOTT BRIDGE RD TO WILL
LUCUS RD S/D ON RIGHT LOT 1 JB

SUBDIV: CAROLINA OAKS 64 LOTS
PHONE : (910) 323-4393
PHONE :

STRUCTURE: 000 000 62X50 3BDR
FLOOD ZONE . . . : FLOOD ZONE X

PERMIT: CPSF 01 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	10/23/07	TI <i>AP JH</i>	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001508563 <i>No T-pole</i>

COMMENTS AND NOTES

ADDRESS . . : 26 CAROLINA OAKS CIR SUBDIV: CAROLINA OAKS 64 LOTS
CONTRACTOR : ELK RIDGE AT SOUTHVIEW LLC PHONE : (910) 323-4393
OWNER . . : RAM DEVELOPMENT INC PHONE :
PARCEL . . : 01-0544- - -0012- -01-
APPL NUMBER: 07-50018461 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : SOUTH 401 TO ELLIOTT BRIDGE RD TO WILL
LUCUS RD S/D ON RIGHT LOT 1 JB

STRUCTURE: 000 000 62X50 3BDR
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 01 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	10/23/07	JH	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001508563
	10/23/07	AP	no t-pole
A814 01	11/02/07	TI	ADDRESS CONFIRMATION VRU #: 001514389
B103 01	11/02/07	TI	R*BLDG FOUND & TEMP SVC POLE VRU #: 001514397

AP JH

----- COMMENTS AND NOTES -----

ADDRESS . : 26 CAROLINA OAKS CIR SUBDIV: CAROLINA OAKS 64 LOTS
CONTRACTOR : ELK RIDGE AT SOUTHVIEW LLC PHONE : (910) 323-4393
OWNER . . : RAM DEVELOPMENT INC PHONE :
PARCEL . . : 01-0544- - -0012- -01-
APPL NUMBER: 07-50018461 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : SOUTH 401 TO ELLIOTT BRIDGE RD TO WILL
LUCUS RD S/D ON RIGHT LOT 1 JB

STRUCTURE: 000 000 62X50 3BDR
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 01 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	10/23/07	JH	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001508563
	10/23/07	AP	no t-pole
B103 01	11/02/07	JH	R*BLDG FOUND & TEMP SVC POLE VRU #: 001514397
	11/02/07	AP	
A814 01	11/02/07	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001514389
	11/02/07	AP	26 Carolina Oaks Cir
P309 01	11/15/07	TI	R*PLUMB UNDER SLAB VRU #: 001520477

DA JH

----- COMMENTS AND NOTES -----

ADDRESS . : 26 CAROLINA OAKS CIR SUBDIV: CAROLINA OAKS 64 LOTS
CONTRACTOR : ELK RIDGE AT SOUTHVIEW LLC PHONE : (910) 323-4393
OWNER . . : RAM DEVELOPMENT INC PHONE :
PARCEL . . : 01-0544- - -0012- -01-
APPL NUMBER: 07-50018461 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : SOUTH 401 TO ELLIOTT BRIDGE RD TO WILL
LUCUS RD S/D ON RIGHT LOT 1 JB

STRUCTURE: 000 000 62X50 3BDR
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 01 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	10/23/07	JH	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001508563
	10/23/07	AP	no t-pole
B103 01	11/02/07	JH	R*BLDG FOUND & TEMP SVC POLE VRU #: 001514397
	11/02/07	AP	
A814 01	11/02/07	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001514389
	11/02/07	AP	26 Carolina Oaks Cir
P309 01	11/15/07	JH	R*PLUMB UNDER SLAB VRU #: 001520477
	11/15/07	DA	Need to remove dryer vent pipe it can not be pvc.
P309 02	11/16/07	JH	R*PLUMB UNDER SLAB VRU #: 001521665

AP JH

----- COMMENTS AND NOTES -----

ADDRESS . . : 26 CAROLINA OAKS CIR
CONTRACTOR : ELK RIDGE AT SOUTHVIEW LLC
OWNER . . : RAM DEVELOPMENT INC
PARCEL . . : 01-0544- - -0012- -01-
APPL NUMBER: 07-50018461 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : SOUTH 401 TO ELLIOTT BRIDGE RD TO WILL
LUCUS RD S/D ON RIGHT LOT 1 JB

SUBDIV: CAROLINA OAKS 64 LOTS
PHONE : (910) 323-4393
PHONE :

STRUCTURE: 000 000 62X50 3BDR
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 01 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	10/23/07	JH	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001508563
	10/23/07	AP	no t-pole
B103 01	11/02/07	JH	R*BLDG FOUND & TEMP SVC POLE VRU #: 001514397
	11/02/07	AP	
A814 01	11/02/07	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001514389
	11/02/07	AP	26 Carolina Oaks Cir
P309 01	11/15/07	JH	R*PLUMB UNDER SLAB VRU #: 001520477
	11/15/07	DA	Need to remove dryer vent pipe it can not be pvc.
P309 02	11/16/07	JH	R*PLUMB UNDER SLAB VRU #: 001521665
	11/16/07	AP	
B111 01	11/21/07	TI	R*BLDG SLAB INSP TIME: 17:00 VRU #: 001523463
		<i>AP JH</i>	THIS WAS SCHEDULED AS A PLUMBING/UNDER SLAB BUT HAD ALREADY BE INSPECTED AND APPROVED. I CANCELLED AND RAN AS A SLAB.
P309 03	11/21/07	TI	R*PLUMB UNDER SLAB TIME: 17:00 VRU #: 001523372
	11/20/07	CA	

----- COMMENTS AND NOTES -----

ADDRESS . : 26 CAROLINA OAKS CIR SUBDIV: CAROLINA OAKS 64 LOTS
CONTRACTOR : ELK RIDGE AT SOUTHVIEW LLC PHONE : (910) 323-4393
OWNER . . : RAM DEVELOPMENT INC PHONE :
PARCEL . . : 01-0544- - -0012- -01-
APPL NUMBER: 07-50018461 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : SOUTH 401 TO ELLIOTT BRIDGE RD TO WILL
LUCUS RD S/D ON RIGHT LOT 1 JB

STRUCTURE: 000 000 62X50 3BDR
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 01 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	10/23/07	JH	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001508563
	10/23/07	AP	no t-pole
B103 01	11/02/07	JH	R*BLDG FOUND & TEMP SVC POLE VRU #: 001514397
	11/02/07	AP	
A814 01	11/02/07	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001514389
	11/02/07	AP	26 Carolina Oaks Cir
P309 01	11/15/07	JH	R*PLUMB UNDER SLAB VRU #: 001520477
	11/15/07	DA	Need to remove dryer vent pipe it can not be pvc.
P309 02	11/16/07	JH	R*PLUMB UNDER SLAB VRU #: 001521665
	11/16/07	AP	
B111 01	11/21/07	JH	R*BLDG SLAB INSP TIME: 17:00 VRU #: 001523463
	11/21/07	AP	THIS WAS SCHEDULED AS A PLUMBING/UNDER SLAB BUT HAD ALREADY BE INSPECTED AND APPROVED. I CANCELLED AND RAN AS A SLAB.
P309 03	11/21/07	TI	R*PLUMB UNDER SLAB TIME: 17:00 VRU #: 001523372
	11/20/07	CA	
R425 01	1/10/08	TI	FOUR TRADE ROUGH IN VRU #: 001544831
	1/10/08	CA	
R425 02	1/24/08	TI	FOUR TRADE ROUGH IN VRU #: 001551617

AP JH

----- COMMENTS AND NOTES -----

ADDRESS . : 26 CAROLINA OAKS CIR SUBDIV: CAROLINA OAKS 64 LOTS
CONTRACTOR : ELK RIDGE AT SOUTHVIEW LLC PHONE : (910) 323-4393
OWNER . . : RAM DEVELOPMENT INC PHONE :
PARCEL . . : 01-0544- - -0012- -01-
APPL NUMBER: 07-50018461 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : SOUTH 401 TO ELLIOTT BRIDGE RD TO WILL
LUCUS RD S/D ON RIGHT LOT 1 JB

STRUCTURE: 000 000 62X50 3BDR
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 01 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	10/23/07	JH	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001508563
	10/23/07	AP	no t-pole
B103 01	11/02/07	JH	R*BLDG FOUND & TEMP SVC POLE VRU #: 001514397
	11/02/07	AP	
A814 01	11/02/07	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001514389
	11/02/07	AP	26 Carolina Oaks Cir
P309 01	11/15/07	JH	R*PLUMB UNDER SLAB VRU #: 001520477
	11/15/07	DA	Need to remove dryer vent pipe it can not be pvc.
P309 02	11/16/07	JH	R*PLUMB UNDER SLAB VRU #: 001521665
	11/16/07	AP	
B111 01	11/21/07	JH	R*BLDG SLAB INSP TIME: 17:00 VRU #: 001523463
	11/21/07	AP	THIS WAS SCHEDULED AS A PLUMBING/UNDER SLAB BUT HAD ALREADY BE INSPECTED AND APPROVED. I CANCELLED AND RAN AS A SLAB.
P309 03	11/21/07	TI	R*PLUMB UNDER SLAB TIME: 17:00 VRU #: 001523372
	11/20/07	CA	
R425 01	1/10/08	TI	FOUR TRADE ROUGH IN VRU #: 001544831
	1/10/08	CA	
R425 02	1/24/08	JH	FOUR TRADE ROUGH IN VRU #: 001551617
	1/24/08	AP	
I129 01	1/28/08	TI	R*INSULATION INSPECTION VRU #: 001553312
		AP JH	

----- COMMENTS AND NOTES -----

ADDRESS . : 26 CAROLINA OAKS CIR SUBDIV: CAROLINA OAKS 64 LOTS
CONTRACTOR : ELK RIDGE AT SOUTHVIEW LLC PHONE : (910) 323-4393
OWNER . . : RAM DEVELOPMENT INC PHONE :
PARCEL . . : 01-0544- - -0012- -01-
APPL NUMBER: 07-50018461 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : SOUTH 401 TO ELLIOTT BRIDGE RD TO WILL
LUCUS RD S/D ON RIGHT LOT 1 JB

STRUCTURE: 000 000 62X50 4BDR
FLOOD ZONE . . . : FLOOD ZONE X

PERMIT: CPSF 01 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	10/23/07	JH	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001508563
	10/23/07	AP	no t-pole
B103 01	11/02/07	JH	R*BLDG FOUND & TEMP SVC POLE VRU #: 001514397
	11/02/07	AP	
A814 01	11/02/07	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001514389
	11/02/07	AP	✓26 Carolina Oaks Cir
P309 01	11/15/07	JH	R*PLUMB UNDER SLAB VRU #: 001520477
	11/15/07	DA	Need to remove dryer vent pipe it can not be pvc.
P309 02	11/16/07	JH	R*PLUMB UNDER SLAB VRU #: 001521665
	11/16/07	AP	
B111 01	11/21/07	JH	R*BLDG SLAB INSP TIME: 17:00 VRU #: 001523463
	11/21/07	AP	THIS WAS SCHEDULED AS A PLUMBING/UNDER SLAB BUT HAD ALREADY BE INSPECTED AND APPROVED. I CANCELLED AND RAN AS A SLAB.
P309 03	11/21/07	TI	R*PLUMB UNDER SLAB TIME: 17:00 VRU #: 001523372
	11/20/07	CA	
R425 01	1/10/08	TI	FOUR TRADE ROUGH IN VRU #: 001544831
	1/10/08	CA	
R425 02	1/24/08	JH	FOUR TRADE ROUGH IN VRU #: 001551617
	1/24/08	AP	
I129 01	1/28/08	JH	R*INSULATION INSPECTION VRU #: 001553312
	1/28/08	AP	
H824 01	3/10/08	OT	✓ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001575505
	3/10/08	AP	
R429 01	3/27/08	TI	FOUR TRADE FINAL VRU #: 001583558

AP JH

COMMENTS AND NOTES

**COUNTY OF HARNETT
DEPARTMENT OF BUILDING INSPECTION
AND PLANNING/DEVELOPMENT
CERTIFICATE OF OCCUPANCY**

This certificate issued pursuant to the requirements of Section 105 of the North Carolina State Building Code and the Harnett County Zoning Ordinance certifies at the time of issuance this structure was in compliance with the various ordinances of the County of Harnett regulating development and building construction or use. For the following:

Use Classification: <u>SFD</u>	Conditional Use Permit No.: _____
Type of Construction: <u>V</u>	Building Permit No.: _____
Owner of Building: <u>Ram Development</u>	Electrical Permit No.: _____
Building Address: <u>26 Carolina Oaks Cir</u>	Insulation Permit No.: _____
Zoning District: _____	Plumbing Permit No.: _____
Zoning Permit No.: _____	Mech. Permit No.: _____
Date: <u>3-27-08</u>	Envir. C.O. No.: _____

James Hall
Building Official

DT-5007464
Zoning Official