
ADDRESS . . : 106 CAROLINA OAKS CIR SUBDIV: CAROLINA OAKS 64 LOTS
CONTRACTOR : ELK RIDGE AT SOUTHVIEW LLC PHONE : (910) 323-4393
OWNER . . . : RAM DEVELOPMENT INC PHONE :
PARCEL . . . : 01-0544- - -0012- -05-
APPL NUMBER: 07-50018462 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : SOUTH 401 TO ELLIOTT BRIDGE RD TO WILL
LUCUS RD S/D ON RIGHT LOT 5 JB

STRUCTURE: 000 000 64X43 4BDR
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	12/04/07	JH	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001529601
	12/04/07	AP	
A814 01	12/12/07	TI	ADDRESS CONFIRMATION VRU #: 001533421
B103 01	12/12/07	TI	R*BLDG FOUND & TEMP SVC POLE VRU #: 001533439

AP JH

T-pole passed

COMMENTS AND NOTES

ADDRESS . . : 106 CAROLINA OAKS CIR SUBDIV: CAROLINA OAKS 64 LOTS
CONTRACTOR : ELK RIDGE AT SOUTHVIEW LLC PHONE : (910) 323-4393
OWNER . . : RAM DEVELOPMENT INC PHONE :
PARCEL . . : 01-0544- - -0012- -05-
APPL NUMBER: 07-50018462 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : SOUTH 401 TO ELLIOTT BRIDGE RD TO WILL
LUCUS RD S/D ON RIGHT LOT 5 JB

STRUCTURE: 000 000 64X43 4BDR
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	12/04/07 12/04/07	JH AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001529601
B103 01	12/12/07 12/12/07	JH AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001533439 t-pole
A814 01	12/12/07 12/18/07	TI AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001533421 106 CAROLINA OAKS CIR
P309 01	12/19/07	TI	R*PLUMB UNDER SLAB VRU #: 001537174

DA JH

----- COMMENTS AND NOTES -----

ADDRESS : 106 CAROLINA OAKS CIR
CONTRACTOR : ELK RIDGE AT SOUTHVIEW LLC
OWNER : RAM DEVELOPMENT INC
PARCEL : 01-0544- - -0012- -05-
APPL NUMBER: 07-50018462 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : SOUTH 401 TO ELLIOTT BRIDGE RD TO WILL
LUCUS RD S/D ON RIGHT LOT 5 JB

SUBDIV: CAROLINA OAKS 64 LOTS
PHONE : (910) 323-4393
PHONE :

STRUCTURE: 000 000 64X43 4BDR

FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 4.00 PROPOSED USE : SFD
SEPTIC - EXISTING? : NEW

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	12/04/07	JH	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001529601
	12/04/07	AP	
B103 01	12/12/07	JH	R*BLDG FOUND & TEMP SVC POLE VRU #: 001533439
	12/12/07	AP	t-pole
A814 01	12/12/07	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001533421
	12/18/07	AP	106 CAROLINA OAKS CIR
P309 01	12/19/07	JH	R*PLUMB UNDER SLAB VRU #: 001537174
	12/19/07	DA	1)10' head of water on underslab plumbing. 2) water in test frozen.
P309 02	12/21/07	TI	R*PLUMB UNDER SLAB VRU #: 001538578

AP JH

----- COMMENTS AND NOTES -----

ADDRESS . : 106 CAROLINA OAKS CIR
CONTRACTOR : ELK RIDGE AT SOUTHVIEW LLC
OWNER . . : RAM DEVELOPMENT INC
PARCEL . . : 01-0544- - -0012- -05-
APPL NUMBER: 07-50018462 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : SOUTH 401 TO ELLIOTT BRIDGE RD TO WILL
LUCUS RD S/D ON RIGHT LOT 5 JB

SUBDIV: CAROLINA OAKS 64 LOTS
PHONE : (910) 323-4393
PHONE :

STRUCTURE: 000 000 64X43 4BDR
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	12/04/07 12/04/07	JH AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001529601
B103 01	12/12/07 12/12/07	JH AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001533439 t-pole
A814 01	12/12/07 12/18/07	TI AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001533421 106 CAROLINA OAKS CIR
P309 01	12/19/07 12/19/07	JH DA	R*PLUMB UNDER SLAB VRU #: 001537174 1)10' head of water on underslab plumbing. 2) water in test frozen.
P309 02	12/21/07 12/21/07	JH AP	R*PLUMB UNDER SLAB VRU #: 001538578
B111 01	12/28/07 <u>12/28/07</u>	TI <u>AP DT</u>	R*BLDG SLAB INSP VRU #: 001539964

----- COMMENTS AND NOTES -----

ADDRESS : 106 CAROLINA OAKS CIR SUBDIV: CAROLINA OAKS 64 LOTS
CONTRACTOR : ELK RIDGE AT SOUTHVIEW LLC PHONE : (910) 323-4393
OWNER : RAM DEVELOPMENT INC #5 PHONE :
PARCEL : 01-0544- - -0012- -05-
APPL NUMBER: 07-50018462 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : SOUTH 401 TO ELLIOTT BRIDGE RD TO WILL
LUCUS RD S/D ON RIGHT LOT 5 JB

STRUCTURE: 000 000 64X43 4BDR
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	12/04/07 12/04/07	JH AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001529601
B103 01	12/12/07 12/12/07	JH AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001533439 t-pole
A814 01	12/12/07 12/18/07	TI AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001533421 106 CAROLINA OAKS CIR
P309 01	12/19/07 12/19/07	JH DA	R*PLUMB UNDER SLAB VRU #: 001537174 1) 10' head of water on underslab plumbing. 2) water in test frozen.
P309 02	12/21/07 12/21/07	JH AP	R*PLUMB UNDER SLAB VRU #: 001538578
B111 01	12/28/07 12/28/07	DT AP	R*BLDG SLAB INSP VRU #: 001539964
R425 01	2/01/08	TI <i>AP JH</i>	FOUR TRADE ROUGH IN VRU #: 001556337

COMMENTS AND NOTES

ADDRESS : 106 CAROLINA OAKS CIR
CONTRACTOR : ELK RIDGE AT SOUTHVIEW LLC
OWNER : RAM DEVELOPMENT INC #5
PARCEL : 01-0544- - -0012- -05-
APPL NUMBER: 07-50018462 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : SOUTH 401 TO ELLIOTT BRIDGE RD TO WILL
LUCUS RD S/D ON RIGHT LOT 5 JB

SUBDIV: CAROLINA OAKS 64 LOTS
PHONE : (910) 323-4393
PHONE :

STRUCTURE: 000 000 64X43 4BDR
FLOOD ZONE . . . : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	12/04/07 12/04/07	JH AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001529601
B103 01	12/12/07 12/12/07	JH AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001533439 t-pole
A814 01	12/12/07 12/18/07	TI AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001533421 106 CAROLINA OAKS CIR
P309 01	12/19/07 12/19/07	JH DA	R*PLUMB UNDER SLAB VRU #: 001537174 1)10' head of water on underslab plumbing. 2) water in test frozen.
P309 02	12/21/07 12/21/07	JH AP	R*PLUMB UNDER SLAB VRU #: 001538578
B111 01	12/28/07 12/28/07	DT AP	R*BLDG SLAB INSP VRU #: 001539964
R425 01	2/01/08 2/01/08	JH AP	FOUR TRADE ROUGH IN VRU #: 001556337
I129 01	2/06/08	TI <i>AP JH</i>	R*INSULATION INSPECTION VRU #: 001558675

COMMENTS AND NOTES

ADDRESS : 106 CAROLINA OAKS CIR SUBDIV: CAROLINA OAKS 64 LOTS
CONTRACTOR : ELK RIDGE AT SOUTHVIEW LLC PHONE : (910) 323-4393
OWNER : RAM DEVELOPMENT INC #5 PHONE :
PARCEL : 01-0544- - -0012- -05-
APPL NUMBER: 07-50018462 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : SOUTH 401 TO ELLIOTT BRIDGE RD TO WILL
LUCUS RD S/D ON RIGHT LOT 5 JB

STRUCTURE: 000 000 64X43 4BDR
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	12/04/07	JH	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001529601
	12/04/07	AP	
B103 01	12/12/07	JH	R*BLDG FOUND & TEMP SVC POLE VRU #: 001533439
	12/12/07	AP	t-pole
A814 01	12/12/07	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001533421
	12/18/07	AP	106 CAROLINA OAKS CIR
P309 01	12/19/07	JH	R*PLUMB UNDER SLAB VRU #: 001537174
	12/19/07	DA	1) 10' head of water on underslab plumbing. 2) water in test frozen.
P309 02	12/21/07	JH	R*PLUMB UNDER SLAB VRU #: 001538578
	12/21/07	AP	
B111 01	12/28/07	DT	R*BLDG SLAB INSP VRU #: 001539964
	12/28/07	AP	
R425 01	2/01/08	JH	FOUR TRADE ROUGH IN VRU #: 001556337
	2/01/08	AP	
I129 01	2/06/08	JH	R*INSULATION INSPECTION VRU #: 001558675
	2/06/08	AP	
H824 01	2/29/08	OT	✓ ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001570779
	2/29/08	AP	
R429 01	5/05/08	JH	FOUR TRADE FINAL VRU #: 001602910
	5/05/08	CA	per Wayne
R429 02	5/19/08	TI	FOUR TRADE FINAL VRU #: 001611318

5/19/08 [Signature]

COMMENTS AND NOTES

**COUNTY OF HARNETT
DEPARTMENT OF BUILDING INSPECTION
AND PLANNING/DEVELOPMENT
CERTIFICATE OF OCCUPANCY**

This certificate issued pursuant to the requirements of Section 105 of the North Carolina State Building Code and the Harnett County Zoning Ordinance certifies at the time of issuance this structure was in compliance with the various ordinances of the County of Harnett regulating development and building construction or use. For the following:

Use Classification: Residential

Owner: Ram Development

911 Address: 106 Carolina Oaks

State: NC Zip Code: _____

Date: 5-19-08

[Signature]
Building Official

PERMIT NUMBERS

Building Permit No.: _____

Electrical Permit No.: _____


Insulation Permit No.: _____

Plumbing Permit No.: _____

Mech. Permit No.: 07-50018462

MFG. Home: _____

SITE PLAN APPROVAL DISTRICT *M* #BEDROOMS *9* DATE *9/13/07*



CAROLINA OAKS CIRCLE
60' Right-of-Way - Public

PLOT PLAN

PROPERTY OF: DWAYNE MAXWELL

ADDRESS: LOT 5, "CAROLINA OAKS"

CITY OF: NEAR LILLINGTON, NC

COUNTY OF: HARNETT

TOWNSHIP OF: ANDERSON CREEK

DATE: 3 SEPTEMBER 2007

SCALE: 1"=40'

REFERENCE: MAP NUMBER 2007-595


****NOTE** THIS PLAT CAN NOT BE USED FOR RECORDATION OR ATTACHED TO A DEED TO BE RECORDED.
THIS MAP IS NOT A CERTIFIED SURVEY AND NO RELIANCE MAY BE PLACED IN ITS ACCURACY.**

HOUSE PLAN: BY MAXWELL

GRAPHIC SCALE



(IN FEET)
1 inch = 40 ft.



Denver Lee McCullough
DENVER LEE McCULLOUGH, PLS L-4182

RAM Rev.

DENVER McCULLOUGH & "C"
404 HOPE MILLS RD, SUITE 4A
FAYETTEVILLE, NC 28304
PHONE: (910)867-6024
FAX: (910)429-2500