

ADDRESS : 104 SWORD LOOP
CONTRACTOR : WYNN CONSTRUCTION, INC.
OWNER : THE HARNETT LAND GROUP II LLC
PARCEL : 03-9576- - -0088- -07-
APPL NUMBER: 07-50018602 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : HWY 27 WEST S/D ON LEFT 4 MILES BEFORE
HWY 87 LOT 7 JB

SUBDIV: TINGEN POINTE 86LOTS
PHONE : (919) 528-1347
PHONE :

STRUCTURE: 000 000 49X39 3BDR CRAWL
FLOOD ZONE . . . : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	1/04/08 1/04/08	TI CA	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001542209
B101 02	1/07/08 <u>1/7/08</u>	TI <u>AP DJ</u>	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001543084

COMMENTS AND NOTES

ADDRESS . : 104 SWORD LOOP
CONTRACTOR : WYNN CONSTRUCTION, INC.
OWNER . . : THE HARNETT LAND GROUP II LLC
PARCEL . . : 03-9576- - -0088- -07-
APPL NUMBER: 07-50018602 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : HWY 27 WEST S/D ON LEFT 4 MILES BEFORE
HWY 87 LOT 7 JB

SUBDIV: TINGEN POINTE 86LOTS
PHONE : (919) 528-1347
PHONE :

STRUCTURE: 000 000 49X39 3BDR CRAWL
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	1/04/08 1/04/08	TI CA	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001542209
B101 02	1/07/08 1/07/08	DT AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001543084
B103 01	1/23/08 <i>1/23/08</i>	TI <i>IP DT</i>	R*BLDG FOUND & TEMP SVC POLE VRU #: 001550903

----- COMMENTS AND NOTES -----

ADDRESS . . : 104 SWORD LOOP
CONTRACTOR : WYNN CONSTRUCTION, INC.
OWNER . . . : THE HARNETT LAND GROUP II LLC
PARCEL . . . : 03-9576- - -0088- -07-
APPL NUMBER: 07-50018602 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : HWY 27 WEST S/D ON LEFT 4 MILES BEFORE
HWY 87 LOT 7 JB

SUBDIV: TINGEN POINTE 86LOTS
PHONE : (919) 528-1347
PHONE :

STRUCTURE: 000 000 49X39 3BDR CRAWL

FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3.00 PROPOSED USE : SFD
SEPTIC - EXISTING? : NEW

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	1/04/08	TI	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001542209
	1/04/08	CA	
B101 02	1/07/08	DT	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001543084
	1/07/08	AP	
B103 01	1/23/08	DT	R*BLDG FOUND & TEMP SVC POLE VRU #: 001550903
	1/23/08	AP	
A814 01	1/28/08	TI	ADDRESS CONFIRMATION VRU #: 001550912
B105 01	1/29/08	TI	R*OPEN FLOOR VRU #: 001553991
	<u>1/29/08</u>	<u>DA DT</u>	

COMMENTS AND NOTES

ADDRESS . : 104 SWORD LOOP
CONTRACTOR : WYNN CONSTRUCTION, INC.
OWNER . . : THE HARNETT LAND GROUP II LLC
PARCEL . . : 03-9576- - -0088- -07-
APPL NUMBER: 07-50018602 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : HWY 27 WEST S/D ON LEFT 4 MILES BEFORE
HWY 87 LOT 7 JB

SUBDIV: TINGEN POINTE 86LOTS
PHONE : (919) 528-1347
PHONE :

STRUCTURE: 000 000 49X39 3BDR CRAWL
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	1/04/08 1/04/08	TI CA	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001542209
B101 02	1/07/08 1/07/08	DT AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001543084
B103 01	1/23/08 1/23/08	DT AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001550903
A814 01	1/28/08	TI	ADDRESS CONFIRMATION VRU #: 001550912
B105 01	1/29/08 1/29/08	DT DA	R*OPEN FLOOR VRU #: 001553991 1. Work not finished. 2. Several bolts missing nuts or nuts were not tight.
B105 02	1/31/08 1/31/08	TI AP DT	R*OPEN FLOOR VRU #: 001555383

----- COMMENTS AND NOTES -----

ADDRESS . . : 104 SWORD LOOP
CONTRACTOR : WYNN CONSTRUCTION, INC.
OWNER . . . : THE HARNETT LAND GROUP II LLC
PARCEL . . . : 03-9576- - -0088- -07-
APPL NUMBER: 07-50018602 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : HWY 27 WEST S/D ON LEFT 4 MILES BEFORE
HWY 87 LOT 7 JB

SUBDIV: TINGEN POINTE 86LOTS
PHONE : (919) 528-1347
PHONE :

STRUCTURE: 000 000 49X39 3BDR CRAWL
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	1/04/08	TI	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001542209
	1/04/08	CA	
B101 02	1/07/08	DT	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001543084
	1/07/08	AP	
B103 01	1/23/08	DT	R*BLDG FOUND & TEMP SVC POLE VRU #: 001550903
	1/23/08	AP	
A814 01	1/28/08	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001550912
	2/14/08	AP	104 SWORD LOOP LOT 7
B105 01	1/29/08	DT	R*OPEN FLOOR VRU #: 001553991
	1/29/08	DA	1. Work not finished. 2. Several bolts missing nuts or nuts were not tight.
B105 02	1/31/08	DT	R*OPEN FLOOR VRU #: 001555383
	1/31/08	AP	
R425 01	2/28/08	TI	FOUR TRADE ROUGH IN VRU #: 001569494

28.5 *AP*

COMMENTS AND NOTES

FS

*140 PSI
BRAKE TEST*

ADDRESS . : 104 SWORD LOOP SUBDIV: TINGEN POINTE 86LOTS
CONTRACTOR : WYNN CONSTRUCTION, INC. PHONE : (919) 528-1347
OWNER . . : THE HARNETT LAND GROUP II LLC PHONE :
PARCEL . . : 03-9576- - -0088- -07-
APPL NUMBER: 07-50018602 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : HWY 27 WEST S/D ON LEFT 4 MILES BEFORE
HWY 87 LOT 7 JB

STRUCTURE: 000 000 49X39 3BDR CRAWL
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	1/04/08 1/04/08	TI CA	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001542209
B101 02	1/07/08 1/07/08	DT AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001543084
B103 01	1/23/08 1/23/08	DT AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001550903
A814 01	1/28/08 2/14/08	TI AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001550912 104 SWORD LOOP LOT 7
B105 01	1/29/08 1/29/08	DT DA	R*OPEN FLOOR VRU #: 001553991 1. Work not finished. 2. Several bolts missing nuts or nuts were not tight.
B105 02	1/31/08 1/31/08	DT AP	R*OPEN FLOOR VRU #: 001555383
R425 01	2/28/08 2/28/08	FS AP	FOUR TRADE ROUGH IN VRU #: 001569494
I129 01	3/03/08 <u>3/3/08</u>	TI <u>APDT</u>	R*INSULATION INSPECTION VRU #: 001570801

COMMENTS AND NOTES

ADDRESS : 104 SWORD LOOP SUBDIV: TINGEN POINTE 86LOTS
CONTRACTOR : WYNN CONSTRUCTION, INC. PHONE : (919) 528-1347
OWNER : THE HARNETT LAND GROUP II LLC PHONE :
PARCEL : 03-9576- - -0088- -07-
APPL NUMBER: 07-50018602 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : HWY 27 WEST S/D ON LEFT 4 MILES BEFORE
HWY 87 LOT 7 JB

STRUCTURE: 000 000 49X39 3BDR CRAWL
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	1/04/08	TI	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001542209
	1/04/08	CA	
B101 02	1/07/08	DT	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001543084
	1/07/08	AP	
B103 01	1/23/08	DT	R*BLDG FOUND & TEMP SVC POLE VRU #: 001550903
	1/23/08	AP	
A814 01	1/28/08	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001550912
	2/14/08	AP	✓ 104 SWORD LOOP LOT 7
B105 01	1/29/08	DT	R*OPEN FLOOR VRU #: 001553991
	1/29/08	DA	1. Work not finished. 2. Several bolts missing nuts or nuts were not tight.
B105 02	1/31/08	DT	R*OPEN FLOOR VRU #: 001555383
	1/31/08	AP	
R425 01	2/28/08	FS	FOUR TRADE ROUGH IN VRU #: 001569494
	2/28/08	AP	
I129 01	3/03/08	DT	R*INSULATION INSPECTION VRU #: 001570801
	3/03/08	AP	
H824 01	4/03/08	JW	✓ ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001588805
	4/03/08	AP	
R429 01	5/06/08	TI	FOUR TRADE FINAL VRU #: 001604419

AP-mp

----- COMMENTS AND NOTES -----

**COUNTY OF HARNETT
DEPARTMENT OF BUILDING INSPECTION
AND PLANNING/DEVELOPMENT
CERTIFICATE OF OCCUPANCY**

This certificate issued pursuant to the requirements of Section 105 of the North Carolina State Building Code and the Harnett County Zoning Ordinance certifies at the time of issuance this structure was in compliance with the various ordinances of the County of Harnett regulating development and building construction or use. For the following:

Use Classification: R-3
Type of Construction: I
Owner of Building: Harnett Land Group
Building Address: 104 Sward Loop
Zoning District: _____
Zoning Permit No.: _____
Date: 5-6-8
Mike Beam

Conditional Use Permit No.: _____
Building Permit No.: 07-50018602
Electrical Permit No.: _____
Insulation Permit No.: _____
Plumbing Permit No.: _____
Mech. Permit No.: _____
Envir. C.O. No.: _____

Building Official

Zoning Official

03793421