

HTE# 07-5-18687

Harnell County Department of Public Health

24406

Improvement Permit

A building permit cannot be issued with only an Improvement Permit

ISSUED TO: KEN DAWSON/HOMES INC

PROPERTY LOCATION: SR1707 NEIGHBORLY RD

SUBDIVISION: BENNETT PLACE

LOT # 34

NEW [x] REPAIR [ ] EXPANSION [ ]

Site Improvements required prior to Construction Authorization Issuance:

Type of Structure: SFD

Proposed Wastewater System Type: 25% REDUCTION

Projected Daily Flow: 360 GPD

Number of bedrooms: 3 Number of Occupants: 6 max

Basement [ ] Yes [x] No

Pump Required: [ ] Yes [ ] No [x] May be required based on final location and elevations of facilities

Type of Water Supply: [ ] Community [x] Public [ ] Well Distance from well \_\_\_\_\_ feet

Permit valid for: [x] Five years

Permit conditions: \_\_\_\_\_ [ ] No expiration

Authorized State Agent: James E. Manhart

Date: 11-1-07

SEE ATTACHED SITE SKETCH

The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.

Construction Authorization

(Required for Building Permit)

The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout.

ISSUED TO: KEN DAWSON/HOMES INC

PROPERTY LOCATION: SR1707 NEIGHBORLY RD

SUBDIVISION: BENNETT PLACE

LOT # 34

Facility Type: SFD [x] New [ ] Expansion [ ] Repair

Basement? [ ] Yes [x] No Basement Fixtures? [ ] Yes [x] No

Type of Wastewater System\*\* 25% REDUCTION SYSTEM (Initial)

Wastewater Flow: 360 GPD

(See note below, if applicable [ ])

25% REDUCTION SYSTEM (Repair)

Installation Requirements/Conditions

Septic Tank Size 1000 gallons

Pump Tank Size \_\_\_\_\_ gallons

Exact length of each trench 100 feet

Trenches shall be installed on contour at a Maximum Trench Depth of: 24" max inches

(Trench bottoms shall be level to +/-1/4"

in all directions)

Trench Spacing: 9 Feet on Center

Soil Cover: 6 inches

(Maximum soil cover shall not exceed 36" above the trench bottom)

Pump Requirements: \_\_\_\_\_ ft. TDH vs. \_\_\_\_\_ GPM

Aggregate Depth: 6 inches below pipe

2 inches above pipe

12 inches total

Conditions: \_\_\_\_\_

\*\*If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.

Owner/Legal Representative Signature: \_\_\_\_\_ Date: \_\_\_\_\_

This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit.

Authorized State Agent: James E. Manhart

Date: 11-1-07

SEE ATTACHED SITE SKETCH

Construction Authorization Expiration Date: 11-1-12

HTE# 07-5-18687

Permit # 24406

# Harnett County Department of Public Health Site Sketch

PROPERTY LOCATION: SR 1707 NEIGHBORS RD


ISSUED TO: KEN DAWSON Homes

SUBDIVISION Bennett Place


LOT # 34

Authorized State Agent: James E. Martin

Date: 11-1-07



SR 1707 NEIGHBORS RD



\* DECK TO BE  
MOVED UP  
BACK OF HOME  
TO ACCOMODATE  
DRAINLINE PLACEMENT  
1ST LINE ALREADY  
FLAGGED.

BEAVER CREEK DR