

HTE# 07-5-18687

# Harnett County Department of Public Health 19839

PERMIT # 24406

## Operation Permit

New Installation  Septic Tank  Repair  Nitrification Line  Expansion

PROPERTY LOCATION: SR 1707 N STATE ST RD

Name: (owner) KEN DAWSON HOMES

SUBDIVISION BEAVER PLACE

LOT # 34

System Installer: \_\_\_\_\_ Registration # \_\_\_\_\_

Basement with plumbing:  Garage  Number of Bedrooms 3

Type of Water Supply:  Community  Public  Well Distance from well \_\_\_\_\_ feet


System Type: 25% REDUCTION System Type III G Types V and VI Systems expire in 5 years.

(In accordance with Table V a)

Owner must contact Health Department 6 months prior to expiration for permit renewal.

SR 1707 N STATE ST.

This system has been installed in compliance with applicable North Carolina General Statutes, Rules for Sewage Treatment and Disposal, and all conditions of the Improvement Permit and Construction Authorization.



- \* 1 1/2" Fall from Tank to D-BOX
- \* Full 12" STORAGE AND NITRIFICATION TANKS Exceeds new requirement "Full Area D-BOX to LENS"
- \* ~~DO NOT~~ INSTALL DONE WITHOUT CORNER IRON PERMISS
- \* NO IRON ON Front Left CORNER AT TIME OF INSPECT
- \* IRON FOUND ON Recall to inspect ON 5-14-08.

### PERMIT CONDITIONS:

- I. Performance: System shall perform in accordance with Rule .1961.
- II. Monitoring: As required by Rule .1961.
- III. Maintenance: As required by Rule .1961. Other: \_\_\_\_\_  
Subsurface system operator required? Yes  No   
If yes, see attached sheet for additional operation conditions, maintenance and reporting.
- IV. Operation: \_\_\_\_\_
- V. Other: \_\_\_\_\_

Following are the specifications for the sewage disposal system on the above captioned property.

Type of system:  Conventional  Other 25% REDUCTION Size of tank: Septic Tank: 1000 gallons Pump Tank: \_\_\_\_\_ gallons

Subsurface No. of exact length width of depth of

Drainage Field ditches 3 of each ditch 100 feet ditches 3 feet ditches 24 inches

French Drain Required: \_\_\_\_\_ Linear feet

Authorized State Agent James E. Manhart @ 198 Date 1-14-08  
5-15-08