HTE# 07-5-18781

## Harnest County Department of Public smalth 24504

## Improvement Permit

A building permit cannot be issued with only an Improvement Permit PROPERTY LOCATION: OLD US 42) SUBDIVISION MAMIE BELL RIOCE ISSUED TO: HUGH MICHAEL RAY LOT # 72 Site Improvements required prior to Construction Authorization Issuance: Type of Structure: SED (68 X52 Proposed Wastewater System Type: Pume To 25% REDUCTION Projected Daily Flow: 360 GPD Number of bedrooms: 3 Number of Occupants: Basement Tyes No Pump Required: XYes □ No
□ May be required based on final location and elevations of facilities Type of Water Supply: 

Community 

Public 

Well Distance from well 100 feet Permit valid for: ☐ No expiration Permit conditions: The issuance of this permit by the Health Department in no way guarantee the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit. Construction Authorization (Required for Building Permit) The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958. and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout. ISSUED TO: HUGH MICHEL RAY PROPERTY LOCATION: OLO US42 SUBDIVISION MAMIE BELL RIOGE LOT # 72 Facility Type: SFO (68'x5%) New 🗆 Expansion 🗆 Repair Basement? ☐ Yes ⋈ No Basement Fixtures? ☐ Yes ⋈ No Type of Wastewater System\*\* PUMP TO 25% REDUCTION (Initial) Wastewater Flow: 360 GPD (See note below, if applicable 

) Prime To 25% REDUCTION (Repair) Installation Requirements/Conditions 3 TRENCHES Exact length of each trench 75 feet Trench Spacing: 9 Feet on Center Septic Tank Size 1000 gallons Trenches shall be installed on contour at a Soil Cover: Pump Tank Size \_\_\_\_\_ gallons Maximum Trench Depth of: 18 inches (Maximum soil cover shall not exceed (Trench bottoms shall be level to +/-1/4" 36" above the trench bottom) in all directions) Pump Requirements: ft. TDH vs. inches below pipe inches above pipe Conditions: inches total \*\* If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit. Owner/Legal Representative Signature: This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit. SEE ATTACHED SITE SKETCH Authorized State Agent: Construction Authorization Expiration Date: 1/20/2

## Harnett County Department of Public Health Site Sketch

Authorized State Agent:

PROPERTY LOCATON: OLD US-421

SUBDIVISION MAMIE BELL RICCE LOT # 72

Authorized State Agent:

Date: 11 21 07

