

ADDRESS : 360 VALLEY OAK DR SUBDIV: FOREST OAKS PH 3 99LOTS  
CONTRACTOR : H & H CONSTRUCTORS INC PHONE : (910) 486-4864  
OWNER : WOODSHIRE PARTNERS LLC PHONE :  
PARCEL : 01-0536-05- -0028- -41-  
APPL NUMBER: 07-50018792 CP NEW RESIDENTIAL (SFD)

DIRECTIONS : HWY 27 W TO NURSERY RD TURN LEFT ON  
NURESEY RD LEFT ON LEMUEL BLACK RD LEFT  
ON VALLEY OAK INTO FOREST OAKS S/D LOT  
154 JB

STRUCTURE: 000 000 35X47 3BDR  
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
P309 01	2/07/08	TI <i>APJW</i>	R*PLUMB UNDER SLAB VRU #: 001559301
E207 01	2/07/08	TI <i>APJW</i>	R*ELEC TEMP SERVICE POLE TIME: 17:00 VRU #: 001560085

COMMENTS AND NOTES

SCANNED  
*5/21/08*  
DATE

-----  
ADDRESS . . : 360 VALLEY OAK DR  
CONTRACTOR : H & H CONSTRUCTORS INC  
OWNER . . . : WOODSHIRE PARTNERS LLC  
PARCEL . . . : 01-0536-05- -0028- -41-  
APPL NUMBER: 07-50018792 CP NEW RESIDENTIAL (SFD)  
DIRECTIONS : HWY 27 W TO NURSERY RD TURN LEFT ON  
NURESEY RD LEFT ON LEMUEL BLACK RD LEFT  
ON VALLEY OAK INTO FOREST OAKS S/D LOT  
154 JB  
-----

SUBDIV: FOREST OAKS PH 3 99LOTS  
PHONE : (910) 486-4864  
PHONE :

-----  
**STRUCTURE: 000 000 35X47 3BDR**

FLOOD ZONE . . . . . : FLOOD ZONE X  
# BEDROOMS . . . . . : 3.00 PROPOSED USE . . . . . : SFD  
SEPTIC - EXISTING? . . . . . : NEW  
-----

**PERMIT: CPSF 00 CP \* SFD**

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
P309 01	2/07/08	JH	R*PLUMB UNDER SLAB VRU #: 001559301
	2/07/08	AP	
E207 01	2/07/08	JH	R*ELEC TEMP SERVICE POLE TIME: 17:00 VRU #: 001560085
	2/07/08	AP	
B111 01	2/11/08	TI	R*BLDG SLAB INSP VRU #: 001560986
	2/11/08	CA	
B111 02	2/12/08	TI	R*BLDG SLAB INSP VRU #: 001561224

*CA JH per mat*

-----  
COMMENTS AND NOTES  
-----

ADDRESS : 360 VALLEY OAK DR  
CONTRACTOR : H & H CONSTRUCTORS INC  
OWNER : WOODSHIRE PARTNERS LLC  
PARCEL : 01-0536-05- -0028- -41-  
APPL NUMBER: 07-50018792 CP NEW RESIDENTIAL (SFD)  
DIRECTIONS : HWY 27 W TO NURSERY RD TURN LEFT ON  
NURESEY RD LEFT ON LEMUEL BLACK RD LEFT  
ON VALLEY OAK INTO FOREST OAKS S/D LOT  
154 JB

SUBDIV: FOREST OAKS PH 3 99LOTS  
PHONE : (910) 486-4864  
PHONE :

STRUCTURE: 000 000 35X47 3BDR  
FLOOD ZONE . . . : FLOOD ZONE X

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
P309 01	2/07/08	JH	R*PLUMB UNDER SLAB VRU #: 001559301
	2/07/08	AP	
E207 01	2/07/08	JH	R*ELEC TEMP SERVICE POLE TIME: 17:00 VRU #: 001560085
	2/07/08	AP	
B111 01	2/11/08	TI	R*BLDG SLAB INSP VRU #: 001560986
	2/11/08	CA	
B111 02	2/12/08	JH	R*BLDG SLAB INSP VRU #: 001561224
	2/12/08	CA	per Mat
B111 03	2/13/08	TI	R*BLDG SLAB INSP VRU #: 001562198

*DA JH*

*Reid bar does not match drawings & water in footing*

COMMENTS AND NOTES

ADDRESS : 360 VALLEY OAK DR  
CONTRACTOR : H & H CONSTRUCTORS INC  
OWNER : WOODSHIRE PARTNERS LLC  
PARCEL : 01-0536-05- -0028- -41-  
APPL NUMBER: 07-50018792 CP NEW RESIDENTIAL (SFD)  
DIRECTIONS : HWY 27 W TO NURSERY RD TURN LEFT ON  
NURESEY RD LEFT ON LEMUEL BLACK RD LEFT  
ON VALLEY OAK INTO FOREST OAKS S/D LOT  
154 JB

SUBDIV: FOREST OAKS PH 3 99LOTS  
PHONE : (910) 486-4864  
PHONE :

STRUCTURE: 000 000 35X47 3BDR  
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
P309 01	2/07/08	JH	R*PLUMB UNDER SLAB VRU #: 001559301
	2/07/08	AP	
E207 01	2/07/08	JH	R*ELEC TEMP SERVICE POLE TIME: 17:00 VRU #: 001560085
	2/07/08	AP	
B111 01	2/11/08	TI	R*BLDG SLAB INSP VRU #: 001560986
	2/11/08	CA	
B111 02	2/12/08	JH	R*BLDG SLAB INSP VRU #: 001561224
	2/12/08	CA	per Mat
B111 03	2/13/08	JH	R*BLDG SLAB INSP VRU #: 001562198
	2/13/08	DA	Reid bar does not match plans & water in footings.
B111 04	2/14/08	TI	R*BLDG SLAB INSP VRU #: 001563030

AP JH

COMMENTS AND NOTES

ADDRESS : 360 VALLEY OAK DR  
CONTRACTOR : H & H CONSTRUCTORS INC  
OWNER : WOODSHIRE PARTNERS LLC  
PARCEL : 01-0536-05- -0028- -41-  
APPL NUMBER: 07-50018792 CP NEW RESIDENTIAL (SFD)  
DIRECTIONS : HWY 27 W TO NURSERY RD TURN LEFT ON  
NURESEY RD LEFT ON LEMUEL BLACK RD LEFT  
ON VALLEY OAK INTO FOREST OAKS S/D LOT  
154 JB

SUBDIV: FOREST OAKS PH 3 99LOTS  
PHONE : (910) 486-4864  
PHONE :

STRUCTURE: 000 000 35X47 3BDR  
FLOOD ZONE . . . . : FLOOD ZONE X

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
P309 01	2/07/08	JH	R*PLUMB UNDER SLAB VRU #: 001559301
	2/07/08	AP	
E207 01	2/07/08	JH	R*ELEC TEMP SERVICE POLE TIME: 17:00 VRU #: 001560085
	2/07/08	AP	
B111 01	2/11/08	TI	R*BLDG SLAB INSP VRU #: 001560986
	2/11/08	CA	
B111 02	2/12/08	JH	R*BLDG SLAB INSP VRU #: 001561224
	2/12/08	CA	per Mat
B111 03	2/13/08	JH	R*BLDG SLAB INSP VRU #: 001562198
	2/13/08	DA	Reid bar does not match plans & water in footings.
B111 04	2/14/08	JH	R*BLDG SLAB INSP VRU #: 001563030
	2/14/08	AP	
A814 01	2/18/08	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001564442
	2/20/08	AP	360 VALLEY OAK DR LOT 154
R425 01	3/05/08	TI	FOUR TRADE ROUGH IN VRU #: 001572031

~~AP-IVR~~  
DA-MR

COMMENTS AND NOTES

ADDRESS : 360 VALLEY OAK DR SUBDIV: FOREST OAKS PH 3 99LOTS  
CONTRACTOR : H & H CONSTRUCTORS INC PHONE : (910) 486-4864  
OWNER : WOODSHIRE PARTNERS LLC PHONE :  
PARCEL : 01-0536-05- -0028- -41-  
APPL NUMBER: 07-50018792 CP NEW RESIDENTIAL (SFD)

DIRECTIONS : HWY 27 W TO NURSERY RD TURN LEFT ON  
NURESEY RD LEFT ON LEMUEL BLACK RD LEFT  
ON VALLEY OAK INTO FOREST OAKS S/D LOT  
154 JB

STRUCTURE: 000 000 35X47 3BDR  
FLOOD ZONE . . . : FLOOD ZONE X

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
P309 01	2/07/08 2/07/08	JH AP	R*PLUMB UNDER SLAB VRU #: 001559301
E207 01	2/07/08 2/07/08	JH AP	R*ELEC TEMP SERVICE POLE TIME: 17:00 VRU #: 001560085
B111 01	2/11/08 2/11/08	TI CA	R*BLDG SLAB INSP VRU #: 001560986
B111 02	2/12/08 2/12/08	JH CA	R*BLDG SLAB INSP VRU #: 001561224 per Mat
B111 03	2/13/08 2/13/08	JH DA	R*BLDG SLAB INSP VRU #: 001562198 Reid bar does not match plans & water in footings.
B111 04	2/14/08 2/14/08	JH AP	R*BLDG SLAB INSP VRU #: 001563030
A814 01	2/18/08 2/20/08	TI AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001564442 360 VALLEY OAK DR LOT 154
R425 01	3/05/08 3/05/08	MR DA	FOUR TRADE ROUGH IN VRU #: 001572031 1. strap lam beam 2nd fl. where supporting trusses 2. draft stop sat trunk lines 3. spliceplate needed at ac cut in top plates 4. ok to side and insul.
I129 01	3/14/08	TI	R*INSULATION INSPECTION VRU #: 001576669
R425 03	3/14/08	TI	FOUR TRADE ROUGH IN VRU #: 001576651
R425 02	3/14/08 3/13/08	TI CA	FOUR TRADE ROUGH IN VRU #: 001576644

COMMENTS AND NOTES

ADDRESS : 360 VALLEY OAK DR  
 CONTRACTOR : H & H CONSTRUCTORS INC  
 OWNER : WOODSHIRE PARTNERS LLC  
 PARCEL : 01-0536-05- -0028- -41-  
 APPL NUMBER: 07-50018792 CP NEW RESIDENTIAL (SFD)  
 DIRECTIONS : HWY 27 W TO NURSERY RD TURN LEFT ON  
 NURESEY RD LEFT ON LEMUEL BLACK RD LEFT  
 ON VALLEY OAK INTO FOREST OAKS S/D LOT  
 154 JB

SUBDIV: FOREST OAKS PH 3 99LOTS  
 PHONE : (910) 486-4864  
 PHONE :

STRUCTURE: 000 000 35X47 3BDR  
 FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
P309 01	2/07/08	JH	R*PLUMB UNDER SLAB VRU #: 001559301
	2/07/08	AP	
E207 01	2/07/08	JH	R*ELEC TEMP SERVICE POLE TIME: 17:00 VRU #: 001560085
	2/07/08	AP	
B111 01	2/11/08	TI	R*BLDG SLAB INSP VRU #: 001560986
	2/11/08	CA	
B111 02	2/12/08	JH	R*BLDG SLAB INSP VRU #: 001561224
	2/12/08	CA	per Mat
B111 03	2/13/08	JH	R*BLDG SLAB INSP VRU #: 001562198
	2/13/08	DA	Reid bar does not match plans & water in footings.
B111 04	2/14/08	JH	R*BLDG SLAB INSP VRU #: 001563030
	2/14/08	AP	
A814 01	2/18/08	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001564442
	2/20/08	AP	360 VALLEY OAK DR LOT 154
R425 01	3/05/08	MR	FOUR TRADE ROUGH IN VRU #: 001572031
	3/05/08	DA	1. strap lam beam 2nd fl. where supporting trusses 2. draft stop sat trunk lines 3. spliceplate needed at ac cut in top plates 4. ok to side and insul.
I129 01	3/14/08	MR	R*INSULATION INSPECTION VRU #: 001576669
	3/14/08	AP	
R425 03	3/14/08	MR	FOUR TRADE ROUGH IN VRU #: 001576651
	3/14/08	AP	
R425 02	3/14/08	TI	FOUR TRADE ROUGH IN VRU #: 001576644
	3/13/08	CA	
H824 01	3/18/08	JW	✓ ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001580232
	3/18/08	AP	
R427 01	3/20/08	TI	FOUR TRADE ROUGH IN >2500 VRU #: 001579929
	3/19/08	CA	
R429 01	4/30/08	TI	FOUR TRADE FINAL VRU #: 001601095

4/30/08 DADT

COMMENTS AND NOTES

ADDRESS : 360 VALLEY OAK DR  
CONTRACTOR : H & H CONSTRUCTORS INC  
OWNER : WOODSHIRE PARTNERS LLC  
PARCEL : 01-0536-05- -0028- -41-  
APPL NUMBER: 07-50018792 CP NEW RESIDENTIAL (SFD)

SUBDIV: FOREST OAKS PH 3 99LOTS  
PHONE : (910) 486-4864  
PHONE :

DIRECTIONS : HWY 27 W TO NURSERY RD TURN LEFT ON  
NURESEY RD LEFT ON LEMUEL BLACK RD LEFT  
ON VALLEY OAK INTO FOREST OAKS S/D LOT  
154 JB

STRUCTURE: 000 000 35X47 3BDR  
FLOOD ZONE . . . : FLOOD ZONE X

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
P309 01	2/07/08	JH	R*PLUMB UNDER SLAB VRU #: 001559301
	2/07/08	AP	
E207 01	2/07/08	JH	R*ELEC TEMP SERVICE POLE TIME: 17:00 VRU #: 001560085
	2/07/08	AP	
B111 01	2/11/08	TI	R*BLDG SLAB INSP VRU #: 001560986
	2/11/08	CA	
B111 02	2/12/08	JH	R*BLDG SLAB INSP VRU #: 001561224
	2/12/08	CA	per Mat
B111 03	2/13/08	JH	R*BLDG SLAB INSP VRU #: 001562198
	2/13/08	DA	Reid bar does not match plans & water in footings.
B111 04	2/14/08	JH	R*BLDG SLAB INSP VRU #: 001563030
	2/14/08	AP	
A814 01	2/18/08	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001564442
	2/20/08	AP	✓ 360 VALLEY OAK DR LOT 154
R425 01	3/05/08	MR	FOUR TRADE ROUGH IN VRU #: 001572031
	3/05/08	DA	1. strap lam beam 2nd fl. where supporting trusses 2. draft stop sat trunk lines 3. spliceplate needed at ac cut in top plates 4. ok to side and insul.
I129 01	3/14/08	MR	R*INSULATION INSPECTION VRU #: 001576669
	3/14/08	AP	
R425 03	3/14/08	MR	FOUR TRADE ROUGH IN VRU #: 001576651
	3/14/08	AP	
R425 02	3/14/08	TI	FOUR TRADE ROUGH IN VRU #: 001576644
	3/13/08	CA	
H824 01	3/18/08	JW	✓ ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001580232
	3/18/08	AP	
R427 01	3/20/08	TI	FOUR TRADE ROUGH IN >2500 VRU #: 001579929
	3/19/08	CA	
R429 01	4/30/08	DT	FOUR TRADE FINAL VRU #: 001601095
	4/30/08	DA	Downstairs toilet not installed. Handrails not up.
R429 03	5/01/08	TI	FOUR TRADE FINAL VRU #: 001601731
	<u>5/1/08</u>	<u>AP DW</u>	
R429 02	5/01/08	TI	FOUR TRADE FINAL VRU #: 001601715
	4/30/08	CA	

----- COMMENTS AND NOTES -----



**COUNTY OF HARNETT  
DEPARTMENT OF BUILDING INSPECTION  
AND PLANNING/DEVELOPMENT  
CERTIFICATE OF OCCUPANCY**

This certificate issued pursuant to the requirements of Section 105 of the North Carolina State Building Code and the Harnett County Zoning Ordinance certifies at the time of issuance this structure was in compliance with the various ordinances of the County of Harnett regulating development and building construction or use. For the following:

Use Classification: Residential Conditional Use Permit No.: \_\_\_\_\_  
Type of Construction: F Building Permit No.: \_\_\_\_\_  
Owner of Building: Woodshire Partners LLC Electrical Permit No.: \_\_\_\_\_  
Building Address: 360 Valley Oak Dr. Insulation Permit No.: \_\_\_\_\_  
Zoning District: \_\_\_\_\_ Plumbing Permit No.: 0750018792  
Zoning Permit No.: \_\_\_\_\_ Mech. Permit No.: \_\_\_\_\_  
Date: 5/1/08 Envir. C.O. No.: \_\_\_\_\_  
[Signature] Building Official \_\_\_\_\_ Zoning Official