

ADDRESS : 398 VALLEY OAK DR  
CONTRACTOR : H & H CONSTRUCTORS INC.  
OWNER : WOODSHIRE PARTNERS LLC  
PARCEL : 01-0536-05- -0028- -43-  
APPL NUMBER: 07-50018794 CP NEW RESIDENTIAL (SFD)

SUBDIV: FOREST OAKS PH 3 99LOTS  
PHONE : (910) 486-4864  
PHONE :

DIRECTIONS : HWY 27 W TO NURSERY RD TURN LEFT ON  
NURESEY RD LEFT ON LEMUEL BLACK RD LEFT  
ON VALLEY OAK INTO FOREST OAKS S/D LOT  
156 JB

STRUCTURE: 000 000 35X47 3BDR  
FLOOD ZONE . . . . : FLOOD ZONE X

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
P309 01	2/07/08	TI <i>APJH</i>	R*PLUMB UNDER SLAB VRU #: 001559319
E207 01	2/07/08	TI <i>APJH</i>	R*ELEC TEMP SERVICE POLE TIME: 17:00 VRU #: 001560093

COMMENTS AND NOTES

-----  
ADDRESS . . : 398 VALLEY OAK DR  
CONTRACTOR : H & H CONSTRUCTORS INC  
OWNER . . . : WOODSHIRE PARTNERS LLC  
PARCEL . . . : 01-0536-05- -0028- -43-  
APPL NUMBER: 07-50018794 CP NEW RESIDENTIAL (SFD)  
DIRECTIONS : HWY 27 W TO NURSERY RD TURN LEFT ON  
NURSEY RD LEFT ON LEMUEL BLACK RD LEFT  
ON VALLEY OAK INTO FOREST OAKS S/D LOT  
156 JB  
-----

SUBDIV: FOREST OAKS PH 3 99LOTS  
PHONE : (910) 486-4864  
PHONE :

-----  
**STRUCTURE: 000 000 35X47 3BDR**

FLOOD ZONE . . . . : FLOOD ZONE X  
# BEDROOMS . . . . . : 3.00 PROPOSED USE . . . . . : SFD  
SEPTIC - EXISTING? . . . . : NEW  
-----

**PERMIT: CPSF 00 CP \* SFD**

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
P309 01	2/07/08	JH	R*PLUMB UNDER SLAB VRU #: 001559319
	2/07/08	AP	
E207 01	2/07/08	JH	R*ELEC TEMP SERVICE POLE TIME: 17:00 VRU #: 001560093
	2/07/08	AP	
B111 01	2/11/08	TI	R*BLDG SLAB INSP VRU #: 001561000
	2/11/08	CA	
B111 02	2/12/08	TI	R*BLDG SLAB INSP VRU #: 001561232

*CA JH per mat*

----- COMMENTS AND NOTES -----  
-----

ADDRESS : 398 VALLEY OAK DR  
CONTRACTOR : H & H CONSTRUCTORS INC  
OWNER : WOODSHIRE PARTNERS LLC  
PARCEL : 01-0536-05- -0028- -43-  
APPL NUMBER: 07-50018794 CP NEW RESIDENTIAL (SFD)  
DIRECTIONS : HWY 27 W TO NURSERY RD TURN LEFT ON  
NURESEY RD LEFT ON LEMUEL BLACK RD LEFT  
ON VALLEY OAK INTO FOREST OAKS S/D LOT  
156 JB

SUBDIV: FOREST OAKS PH 3 99LOTS  
PHONE : (910) 486-4864  
PHONE :

STRUCTURE: 000 000 35X47 3BDR  
FLOOD ZONE . . . : FLOOD ZONE X

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
P309 01	2/07/08	JH	R*PLUMB UNDER SLAB VRU #: 001559319
	2/07/08	AP	
E207 01	2/07/08	JH	R*ELEC TEMP SERVICE POLE TIME: 17:00 VRU #: 001560093
	2/07/08	AP	
B111 01	2/11/08	TI	R*BLDG SLAB INSP VRU #: 001561000
	2/11/08	CA	
B111 02	2/12/08	JH	R*BLDG SLAB INSP VRU #: 001561232
	2/12/08	CA	per Mat
B111 03	2/13/08	TI	R*BLDG SLAB INSP VRU #: 001562180

*DA JH* Slab does not match plans in footings & rebar  
in wrong place

COMMENTS AND NOTES

ADDRESS : 398 VALLEY OAK DR SUBDIV: FOREST OAKS PH 3 99LOTS  
CONTRACTOR : H & H CONSTRUCTORS INC PHONE : (910) 486-4864  
OWNER : WOODSHIRE PARTNERS LLC PHONE :  
PARCEL : 01-0536-05- -0028- -43-  
APPL NUMBER: 07-50018794 CP NEW RESIDENTIAL (SFD)  
DIRECTIONS : HWY 27 W TO NURSERY RD TURN LEFT ON  
NURESEY RD LEFT ON LEMUEL BLACK RD LEFT  
ON VALLEY OAK INTO FOREST OAKS S/D LOT  
156 JB

STRUCTURE: 000 000 35X47 3BDR  
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
P309 01	2/07/08	JH	R*PLUMB UNDER SLAB VRU #: 001559319
	2/07/08	AP	
E207 01	2/07/08	JH	R*ELEC TEMP SERVICE POLE TIME: 17:00 VRU #: 001560093
	2/07/08	AP	
B111 01	2/11/08	TI	R*BLDG SLAB INSP VRU #: 001561000
	2/11/08	CA	
B111 02	2/12/08	JH	R*BLDG SLAB INSP VRU #: 001561232
	2/12/08	CA	per Mat
B111 03	2/13/08	JH	R*BLDG SLAB INSP VRU #: 001562180
	2/13/08	DA	Slab does not match plans, lug footings & reid bar in wrong place.
B111 04	2/14/08	TI	R*BLDG SLAB INSP VRU #: 001563048

DA

AP JA

COMMENTS AND NOTES

ADDRESS : 398 VALLEY OAK DR  
CONTRACTOR : H & H CONSTRUCTORS INC  
OWNER : WOODSHIRE PARTNERS LLC  
PARCEL : 01-0536-05- -0028- -43-  
APPL NUMBER: 07-50018794 CP NEW RESIDENTIAL (SFD)  
DIRECTIONS : HWY 27 W TO NURSERY RD TURN LEFT ON  
NURESEY RD LEFT ON LEMUEL BLACK RD LEFT  
ON VALLEY OAK INTO FOREST OAKS S/D LOT  
156 JB

SUBDIV: FOREST OAKS PH 3 99LOTS  
PHONE : (910) 486-4864  
PHONE :

STRUCTURE: 000 000 35X47 3BDR  
FLOOD ZONE . . . . : FLOOD ZONE X

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
E309 01	2/07/08	JH	R*PLUMB UNDER SLAB VRU #: 001559319
	2/07/08	AP	
E207 01	2/07/08	JH	R*ELEC TEMP SERVICE POLE TIME: 17:00 VRU #: 001560093
	2/07/08	AP	
B111 01	2/11/08	TI	R*BLDG SLAB INSP VRU #: 001561000
	2/11/08	CA	
B111 02	2/12/08	JH	R*BLDG SLAB INSP VRU #: 001561232
	2/12/08	CA	per Mat
B111 03	2/13/08	JH	R*BLDG SLAB INSP VRU #: 001562180
	2/13/08	DA	Slab does not match plans, lug footings & reid bar in wrong place.
B111 04	2/14/08	JH	R*BLDG SLAB INSP VRU #: 001563048
	2/14/08	AP	
A814 01	2/18/08	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001564459
	2/20/08	AP	398 VALLEY OAK DR LCT 156
R425 01	3/05/08	TI	FOUR TRADE ROUGH IN VRU #: 001572049

DA-MR

COMMENTS AND NOTES

Stop Lath, beam

ADDRESS : 398 VALLEY OAK DR SUBDIV: FOREST OAKS PH 3 99LOTS  
CONTRACTOR : H & H CONSTRUCTORS INC PHONE : (910) 486-4864  
OWNER : WOODSHIRE PARTNERS LLC PHONE :  
PARCEL : 01-0536-05- -0028- -43-  
APPL NUMBER: 07-50018794 CP NEW RESIDENTIAL (SFD)

DIRECTIONS : HWY 27 W TO NURSERY RD TURN LEFT ON  
NURESEY RD LEFT ON LEMUEL BLACK RD LEFT  
ON VALLEY OAK INTO FOREST OAKS S/D LOT  
156 JB

STRUCTURE: 000 000 35X47 3BDR  
FLOOD ZONE . . . : FLOOD ZONE X

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
P309 01	2/07/08	JH	R*PLUMB UNDER SLAB VRU #: 001559319
	2/07/08	AP	
E207 01	2/07/08	JH	R*ELEC TEMP SERVICE POLE TIME: 17:00 VRU #: 001560093
	2/07/08	AP	
B111 01	2/11/08	TI	R*BLDG SLAB INSP VRU #: 001561000
	2/11/08	CA	
B111 02	2/12/08	JH	R*BLDG SLAB INSP VRU #: 001561232
	2/12/08	CA	per Mat
B111 03	2/13/08	JH	R*BLDG SLAB INSP VRU #: 001562180
	2/13/08	DA	Slab does not match plans, lug footings & reid bar in wrong place.
B111 04	2/14/08	JH	R*BLDG SLAB INSP VRU #: 001563048
	2/14/08	AP	
A814 01	2/18/08	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001564459
	2/20/08	AP	398 VALLEY OAK DR LOT 156
R425 01	3/05/08	MR	FOUR TRADE ROUGH IN VRU #: 001572049
	3/05/08	DA	1, strap beam supporting trusses ok to side and insul.
I129 01	3/14/08	TI	R*INSULATION INSPECTION VRU #: 001576719
		<i>AP-MR</i>	
R425 03	3/14/08	TI	FOUR TRADE ROUGH IN VRU #: 001576701
		<i>AP-MR</i>	
R425 02	3/14/08	TI	FOUR TRADE ROUGH IN VRU #: 001576685
	3/13/08	CA	

----- COMMENTS AND NOTES -----

ADDRESS : 398 VALLEY OAK DR SUBDIV: FOREST OAKS PH 3 99LOTS  
 CONTRACTOR : H & H CONSTRUCTORS INC PHONE : (910) 486-4864  
 OWNER : WOODSHIRE PARTNERS LLC PHONE :  
 PARCEL : 01-0536-05- -0028- -43-  
 APPL NUMBER: 07-50018794 CP NEW RESIDENTIAL (SFD)  
 DIRECTIONS : HWY 27 W TO NURSERY RD TURN LEFT ON  
 NURESEY RD LEFT ON LEMUEL BLACK RD LEFT  
 ON VALLEY OAK INTO FOREST OAKS S/D LOT  
 156 JB

STRUCTURE: 000 000 35X47 3BDR  
 FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
P309 01	2/07/08	JH	R*PLUMB UNDER SLAB VRU #: 001559319
	2/07/08	AP	
E207 01	2/07/08	JH	R*ELEC TEMP SERVICE POLE TIME: 17:00 VRU #: 001560093
	2/07/08	AP	
B111 01	2/11/08	TI	R*BLDG SLAB INSP VRU #: 001561000
	2/11/08	CA	
B111 02	2/12/08	JH	R*BLDG SLAB INSP VRU #: 001561232
	2/12/08	CA	per Mat
B111 03	2/13/08	JH	R*BLDG SLAB INSP VRU #: 001562180
	2/13/08	DA	Slab does not match plans, lug footings & reid bar in wrong place.
B111 04	2/14/08	JH	R*BLDG SLAB INSP VRU #: 001563048
	2/14/08	AP	
A814 01	2/18/08	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001564459
	2/20/08	AP	398 VALLEY OAK DR LOT 156
R425 01	3/05/08	MR	FOUR TRADE ROUGH IN VRU #: 001572049
	3/05/08	DA	1, strap beam supporting trusses ok to side and insul.
I129 01	3/14/08	MR	R*INSULATION INSPECTION VRU #: 001576719
	3/14/08	AP	
R425 03	3/14/08	MR	FOUR TRADE ROUGH IN VRU #: 001576701
	3/14/08	AP	
R425 02	3/14/08	TI	FOUR TRADE ROUGH IN VRU #: 001576685
	3/13/08	CA	
H824 01	3/20/08	JW	✓ ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001581966
	3/20/08	AP	
R429 01	5/07/08	TI	FOUR TRADE FINAL VRU #: 001605005

AP-MR

COMMENTS AND NOTES

**COUNTY OF HARNETT  
DEPARTMENT OF BUILDING INSPECTION  
AND PLANNING/DEVELOPMENT  
CERTIFICATE OF OCCUPANCY**

This certificate issued pursuant to the requirements of Section 105 of the North Carolina State Building Code and the Harnett County Zoning Ordinance certifies at the time of issuance this structure was in compliance with the various ordinances of the County of Harnett regulating development and building construction or use. For the following:

Use Classification: R-3

Conditional Use Permit No.: \_\_\_\_\_

Type of Construction: I

Building Permit No.: 07-50018794

Owner of Building: Woodshire Partners

Electrical Permit No.: 11

Building Address: 398 Valley Oak

Insulation Permit No.: 11

Zoning District: \_\_\_\_\_

Plumbing Permit No.: 11

Zoning Permit No.: \_\_\_\_\_

Mech. Permit No.: 11

Envir. C.O. No.: \_\_\_\_\_

Date: 5-7-8

Mula Ream

Building Official

Zoning Official