
ADDRESS . : 39 GREAT OAK CT
CONTRACTOR : H & H CONSTRUCTORS INC
OWNER . . : WOODSHIRE PARTNERS LLC
PARCEL . . : 01-0536-05- -0028- -91-
APPL NUMBER: 07-50018800 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : HWY 27 W TO NURSERY RD TURN LEFT ON
NURESEY RD LEFT ON LEMUEL BLACK RD LEFT
ON VALLEY OAK INTO FOREST OAKS S/D LOT
204 JB

SUBDIV: FOREST OAKS PH 3 99LOTS
PHONE : (910) 486-4864
PHONE :

STRUCTURE: 000 000 48X48 4BDR
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED	INSP	DESCRIPTION
	COMPLETED	RESULT	RESULTS/COMMENTS
P309 01	8/06/08	TI <i>APJH</i>	R*PLUMB UNDER SLAB VRU #: 001656743

COMMENTS AND NOTES

ADDRESS . . : 39 GREAT OAK CT
CONTRACTOR : H & H CONSTRUCTORS INC
OWNER . . . : WOODSHIRE PARTNERS LLC
PARCEL . . . : 01-0536-05- -0028- -91-
APPL NUMBER: 07-50018800 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : HWY 27 W TO NURSERY RD TURN LEFT ON
NURESEY RD LEFT ON LEMUEL BLACK RD LEFT
ON VALLEY OAK INTO FOREST OAKS S/D LOT
204 JB

SUBDIV: FOREST OAKS PH 3 99LOTS
PHONE : (910) 486-4864
PHONE :

STRUCTURE: 000 000 48X48 4BDR
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
P309 01	8/06/08	JH	R*PLUMB UNDER SLAB VRU #: 001656743
	8/06/08	AP	
B111 01	8/11/08	TI	R*BLDG SLAB INSP VRU #: 001659648

AP JH

----- COMMENTS AND NOTES -----

ADDRESS : 39 GREAT OAK CT
CONTRACTOR : H & H CONSTRUCTORS INC
OWNER : WOODSHIRE PARTNERS LLC
PARCEL : 01-0536-05- -0028- -91-
APPL NUMBER: 07-50018800 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : HWY 27 W TO NURSERY RD TURN LEFT ON
NURESEY RD LEFT ON LEMUEL BLACK RD LEFT
ON VALLEY OAK INTO FOREST OAKS S/D LOT
204 JB

SUBDIV: FOREST OAKS PH 3 99LOTS
PHONE : (910) 486-4864
PHONE :

STRUCTURE: 000 000 48X48 4BDR

FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 4.00 PROPOSED USE : SFD
SEPTIC - EXISTING? : NEW

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
P309 01	8/06/08	JH	R*PLUMB UNDER SLAB VRU #: 001656743
	8/06/08	AP	
B111 01	8/11/08	JH	R*BLDG SLAB INSP VRU #: 001659648
	8/11/08	AP	
A814 01	10/03/08	TI	ADDRESS CONFIRMATION VRU #: 001686112
R425 01	10/03/08 <i>10/3/08</i>	TI <i>DA DT</i>	FOUR TRADE ROUGH IN VRU #: 001686120

COMMENTS AND NOTES

ADDRESS : 39 GREAT OAK CT
CONTRACTOR : H & H CONSTRUCTORS INC
OWNER : WOODSHIRE PARTNERS LLC
PARCEL : 01-0536-05- -0028- -91-
APPL NUMBER: 07-50018800 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : HWY 27 W TO NURSERY RD TURN LEFT ON
NURSEY RD LEFT ON LEMUEL BLACK RD LEFT
ON VALLEY OAK INTO FOREST OAKS S/D LOT
204 JB

SUBDIV: FOREST OAKS PH 3 99LOTS
PHONE : (910) 486-4864
PHONE :

STRUCTURE: 000 000 48X48 4BDR

FLOOD ZONE : FLOOD ZONE X

BEDROOMS : 4.00

PROPOSED USE : SFD

SEPTIC - EXISTING? : NEW

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
P309 01	8/06/08	JH	R*PLUMB UNDER SLAB VRU #: 001656743
	8/06/08	AP	
B111 01	8/11/08	JH	R*BLDG SLAB INSP VRU #: 001659648
	8/11/08	AP	
R425 01	10/03/08	DT	FOUR TRADE ROUGH IN VRU #: 001686120
	10/03/08	DA	<ol style="list-style-type: none"> 1. Need engineer repair for truss above stairs 2. Need larger nail guard for plumbing at stairs. 3. Need web brace for bonus room trusses. 4. 2 ply truss in bonus not nailed at webs. 5. Upstairs bath exhaust fans too long for flex. Okay to side.
A814 01	10/03/08	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001686112
	10/03/08	AP	39 GREAT OAK CT LOT 204
R425 02	10/07/08	TI	FOUR TRADE ROUGH IN VRU #: 001687581

AP-MR

COMMENTS AND NOTES

ADDRESS : 39 GREAT OAK CT
CONTRACTOR : H & H CONSTRUCTORS INC
OWNER : WOODSHIRE PARTNERS LLC
PARCEL : 01-0536-05- -0028- -91-
APPL NUMBER: 07-50018800 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : HWY 27 W TO NURSERY RD TURN LEFT ON
NURESEY RD LEFT ON LEMUEL BLACK RD LEFT
ON VALLEY OAK INTO FOREST OAKS S/D LOT
204 JB

SUBDIV: FOREST OAKS PH 3 99LOTS
PHONE : (910) 486-4864
PHONE :

STRUCTURE: 000 000 48X48 4BDR

FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 4.00 PROPOSED USE : SFD
SEPTIC - EXISTING? : NEW

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
P309 01	8/06/08	JH	R*PLUMB UNDER SLAB VRU #: 001656743
	8/06/08	AP	
B111 01	8/11/08	JH	R*BLDG SLAB INSP VRU #: 001659648
	8/11/08	AP	
R425 01	10/03/08	DT	FOUR TRADE ROUGH IN VRU #: 001686120
	10/03/08	DA	1. Need engineer repair for truss above stairs 2. Need larger nail guard for plumbing at stairs. 3. Need web brace for bonus room trusses. 4. 2 ply truss in bonus not nailed at webs. 5. Upstairs bath exhaust fans too long for flex. Okay to side.
A814 01	10/03/08	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001686112
	10/03/08	AP	✓ 39 GREAT OAK CT LOT 204
R425 02	10/07/08	MR	FOUR TRADE ROUGH IN VRU #: 001687581
	10/07/08	AP	
I129 01	10/09/08	DT	R*INSULATION INSPECTION VRU #: 001689348
	10/09/08	AP	
H824 01	10/21/08	JW	✓ ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001696129
	10/21/08	AP	
R429 01	12/01/08	TI	FOUR TRADE FINAL VRU #: 001711076

AP-MR

COMMENTS AND NOTES

**COUNTY OF HARNETT
DEPARTMENT OF BUILDING INSPECTION
AND PLANNING/DEVELOPMENT
CERTIFICATE OF OCCUPANCY**

This certificate issued pursuant to the requirements of Section 105 of the North Carolina State Building Code and the Harnett County Zoning Ordinance certifies at the time of issuance this structure was in compliance with the various ordinances of the County of Harnett regulating development and building construction or use. For the following:

Use Classification: R-3

Conditional Use Permit No.: _____

Type of Construction: I

Building Permit No.: 07-50018800

Owner of Building: Woodshire Partners.

Electrical Permit No.: _____

Building Address: 39 Great Oak

Insulation Permit No.: _____

Zoning District: _____

Plumbing Permit No.: _____

Zoning Permit No.: _____

Mech. Permit No.: _____

Date: 12-1-8

Envir. C.O. No.: _____

Milko Reovic

Building Official

Zoning Official