
ADDRESS : 411 VALLEY OAK DR SUBDIV: FOREST OAKS PH 3 99LOTS
CONTRACTOR : H & H CONSTRUCTORS INC PHONE : (910) 486-4864
OWNER : WOODSHIRE PARTNERS LLC #206 PHONE :
PARCEL : 01-0536-05- -0028- -93-
APPL NUMBER: 07-50018802 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : HWY 27 W TO NURSERY RD TURN LEFT ON
NURESEY RD LEFT ON LEMUEL BLACK RD LEFT
ON VALLEY OAK INTO FOREST OAKS S/D LOT
206 JB

STRUCTURE: 000 000 59X53 5BDR
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
P309 01	4/02/08	JH	R*PLUMB UNDER SLAB VRU #: 001586742
	4/02/08	CA	per Mat
P309 02	4/04/08	TI	R*PLUMB UNDER SLAB VRU #: 001588441

AP TH

T-pole passed

COMMENTS AND NOTES

ADDRESS . : 411 VALLEY OAK DR SUBDIV: FOREST OAKS PH 3 99LOTS
CONTRACTOR : H & H CONSTRUCTORS INC PHONE : (910) 486-4864
OWNER . . : WOODSHIRE PARTNERS LLC #206 PHONE :
PARCEL . . : 01-0536-05- -0028- -93-
APPL NUMBER: 07-50018802 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : HWY 27 W TO NURSERY RD TURN LEFT ON
NURESEY RD LEFT ON LEMUEL BLACK RD LEFT
ON VALLEY OAK INTO FOREST OAKS S/D LOT
206 JB

STRUCTURE: 000 000 59X53 5BDR
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
P309 01	4/02/08	JH	R*PLUMB UNDER SLAB VRU #: 001586742
	4/02/08	CA	per Mat
P309 02	4/04/08	JH	R*PLUMB UNDER SLAB VRU #: 001588441
	4/04/08	AP	t-pole passed
B111 01	4/08/08	TI	R*BLDG SLAB INSP VRU #: 001588870

DA JA

----- COMMENTS AND NOTES -----

ADDRESS : 411 VALLEY OAK DR
CONTRACTOR : H & H CONSTRUCTORS INC
OWNER : WOODSHIRE PARTNERS LLC #206
PARCEL : 01-0536-05- -0028- -93-
APPL NUMBER: 07-50018802 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : HWY 27 W TO NURSERY RD TURN LEFT ON
NURESEY RD LEFT ON LEMUEL BLACK RD LEFT
ON VALLEY OAK INTO FOREST OAKS S/D LOT
206 JB

SUBDIV: FOREST OAKS PH 3 99LOTS
PHONE : (910) 486-4864
PHONE :

STRUCTURE: 000 000 59X53 5BDR
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
P309 01	4/02/08	JH	R*PLUMB UNDER SLAB VRU #: 001586742
	4/02/08	CA	per Mat
P309 02	4/04/08	JH	R*PLUMB UNDER SLAB VRU #: 001588441
	4/04/08	AP	t-pole passed
B111 01	4/08/08	JH	R*BLDG SLAB INSP VRU #: 001588870
	4/08/08	DA	1) Footing needs to be 12" below grade. 2) Garage footing does not match plan details, 16".
B111 02	4/09/08	TI	R*BLDG SLAB INSP VRU #: 001590090

~~DP-MR~~

DP-MR

COMMENTS AND NOTES

ADDRESS : 411 VALLEY OAK DR
CONTRACTOR : H & H CONSTRUCTORS INC
OWNER : WOODSHIRE PARTNERS LLC #206
PARCEL : 01-0536-05- -0028- -93-
APPL NUMBER: 07-50018802 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : HWY 27 W TO NURSERY RD TURN LEFT ON
NURESEY RD LEFT ON LEMUEL BLACK RD LEFT
ON VALLEY OAK INTO FOREST OAKS S/D LOT
206 JB

SUBDIV: FOREST OAKS PH 3 99LOTS
PHONE : (910) 486-4864
PHONE :

STRUCTURE: 000 000 59X53 5BDR
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
P309 01	4/02/08	JH	R*PLUMB UNDER SLAB VRU #: 001586742
	4/02/08	CA	per Mat
P309 02	4/04/08	JH	R*PLUMB UNDER SLAB VRU #: 001588441
	4/04/08	AP	t-pole passed
B111 01	4/08/08	JH	R*BLDG SLAB INSP VRU #: 001588870
	4/08/08	DA	1)Footing needs to be 12" below grade. 2)Garage footing does not match plan details, 16".
B111 02	4/09/08	MR	R*BLDG SLAB INSP VRU #: 001590090
	4/09/08	DP	1. footin must be 8' x 16' at garage walls it appears that when you tear out the form stakes you will only have 10 to 12" ? 2. the footing is only 5 to 6" in spots
B111 03	4/10/08	TI	R*BLDG SLAB INSP VRU #: 001591155

MR
DP

TI
AE-MR

COMMENTS AND NOTES

checks Footing at Garage

ADDRESS : 411 VALLEY OAK DR
CONTRACTOR : H & H CONSTRUCTORS INC
OWNER : WOODSHIRE PARTNERS LLC #206
PARCEL : 01-0536-05- -0028- -93-
APPL NUMBER: 07-50018802 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : HWY 27 W TO NURSERY RD TURN LEFT ON
NURESEY RD LEFT ON LEMUEL BLACK RD LEFT
ON VALLEY OAK INTO FOREST OAKS S/D LOT
206 JB

SUBDIV: FOREST OAKS PH 3 99LOTS
PHONE : (910) 486-4864
PHONE :

STRUCTURE: 000 000 59X53 5BDR
FLOOD ZONE . . . : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
P309 01	4/02/08	JH	R*PLUMB UNDER SLAB VRU #: 001586742
	4/02/08	CA	per Mat
P309 02	4/04/08	JH	R*PLUMB UNDER SLAB VRU #: 001588441
	4/04/08	AP	t-pole passed
B111 01	4/08/08	JH	R*BLDG SLAB INSP VRU #: 001588870
	4/08/08	DA	1)Footing needs to be 12" below grade. 2)Garage footing does not match plan details, 16".
B111 02	4/09/08	MR	R*BLDG SLAB INSP VRU #: 001590090
	4/09/08	DP	1. footin must be 8' x 16' at garage walls it appears that when you tear out the form stakes you will only have 10 to 12" ? 2. the footing is only 5 to 6" in spots
B111 03	4/10/08	MR	R*BLDG SLAB INSP VRU #: 001591155
	4/10/08	AE	check footing
A814 01	4/29/08	TI	ADDRESS CONFIRMATION VRU #: 001600535
R425 01	4/29/08	TI	FOUR TRADE ROUGH IN VRU #: 001600543

AP JH

COMMENTS AND NOTES

ADDRESS : 411 VALLEY OAK DR
CONTRACTOR : H & H CONSTRUCTORS INC
OWNER : WOODSHIRE PARTNERS LLC #206
PARCEL : 01-0536-05- -0028- -93-
APPL NUMBER: 07-50018802 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : HWY 27 W TO NURSERY RD TURN LEFT ON
NURESEY RD LEFT ON LEMUEL BLACK RD LEFT
ON VALLEY OAK INTO FOREST OAKS S/D LOT
206 JB

SUBDIV: FOREST OAKS PH 3 99LOTS
PHONE : (910) 486-4864
PHONE :

STRUCTURE: 000 000 59X53 5BDR
FLOOD ZONE . . . : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
P309 01	4/02/08	JH	R*PLUMB UNDER SLAB VRU #: 001586742
	4/02/08	CA	per Mat
P309 02	4/04/08	JH	R*PLUMB UNDER SLAB VRU #: 001588441
	4/04/08	AP	t-pole passed
B111 01	4/08/08	JH	R*BLDG SLAB INSP VRU #: 001588870
	4/08/08	DA	1)Footing needs to be 12" below grade. 2)Garage footing does not match plan details, 16".
B111 02	4/09/08	MR	R*BLDG SLAB INSP VRU #: 001590090
	4/09/08	DP	1. footin must be 8' x 16' at garage walls it appears that when you tear out the form stakes you will only have 10 to 12" ? 2. the footing is only 5 to 6" in spots
B111 03	4/10/08	MR	R*BLDG SLAB INSP VRU #: 001591155
	4/10/08	AE	check footing
R425 01	4/29/08	JH	FOUR TRADE ROUGH IN VRU #: 001600543
	4/29/08	AP	
A814 01	4/29/08	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001600535
	4/29/08	AP	411 VALLEY OAK DR LOT 206
I129 01	5/05/08	TI	R*INSULATION INSPECTION VRU #: 001602861

5/5/08 AP DT

----- COMMENTS AND NOTES -----

ADDRESS : 411 VALLEY OAK DR
CONTRACTOR : H & H CONSTRUCTORS INC
OWNER : WOODSHIRE PARTNERS LLC #206
PARCEL : 01-0536-05- -0028- -93-
APPL NUMBER: 07-50018802 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : HWY 27 W TO NURSERY RD TURN LEFT ON
NURESEY RD LEFT ON LEMUEL BLACK RD LEFT
ON VALLEY OAK INTO FOREST OAKS S/D LOT
206 JB

SUBDIV: FOREST OAKS PH 3 99LOTS
PHONE : (910) 486-4864
PHONE :

STRUCTURE: 000 000 59X53 5BDR
FLOOD ZONE . . . : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
P309 01	4/02/08	JH	R*PLUMB UNDER SLAB VRU #: 001586742
	4/02/08	CA	per Mat
P309 02	4/04/08	JH	R*PLUMB UNDER SLAB VRU #: 001588441
	4/04/08	AP	t-pole passed
B111 01	4/08/08	JH	R*BLDG SLAB INSP VRU #: 001588870
	4/08/08	DA	1)Footing needs to be 12" below grade. 2)Garage footing does not match plan details, 16".
B111 02	4/09/08	MR	R*BLDG SLAB INSP VRU #: 001590090
	4/09/08	DP	1. footin must be 8' x 16' at garage walls it appears that when you tear out the form stakes you will only have 10 to 12" ? 2. the footing is only 5 to 6" in spots
B111 03	4/10/08	MR	R*BLDG SLAB INSP VRU #: 001591155
	4/10/08	AE	check footing
R425 01	4/29/08	JH	FOUR TRADE ROUGH IN VRU #: 001600543
	4/29/08	AP	
A814 01	4/29/08	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001600535
	4/29/08	AP	411 VALLEY OAK DR LOT 206
I129 01	5/05/08	DT	R*INSULATION INSPECTION VRU #: 001602861
	5/05/08	AP	
H824 01	5/15/08	JW	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001611128
	5/15/08	AP	
R429 01	6/24/08	TI	FOUR TRADE FINAL VRU #: 001630649

APJW

COMMENTS AND NOTES

**COUNTY OF HARNETT
DEPARTMENT OF BUILDING INSPECTION
AND PLANNING/DEVELOPMENT
CERTIFICATE OF OCCUPANCY**

This certificate issued pursuant to the requirements of Section 105 of the North Carolina State Building Code and the Harnett County Zoning Ordinance certifies at the time of issuance this structure was in compliance with the various ordinances of the County of Harnett regulating development and building construction or use. For the following:

Use Classification: SFD

Owner: H & H Contractors

911 Address: 411 Valley Oaks Dr

State: _____ Zip Code: _____

Date: 6-24-08

James [Signature]
Building Official

PERMIT NUMBERS

Building Permit No.: _____

Electrical Permit No.: _____

Insulation Permit No.: _____

Plumbing Permit No.: _____

Mech. Permit No.: _____

MFG. Home: _____

01501800