

ADDRESS . : 25 VIOLA LN
CONTRACTOR : C M A BUILDERS LLC
OWNER . : : SMITH KATHERINE U #14
PARCEL . . : 04-0672- - -0209- -32-
APPL NUMBER: 07-50018830 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : SANDY GROVE #14-210N RT ON OLD COATS RD
LEFT ON OLD BUIES CREEK RD LEFT ON
VIOLA LN LOT ON CORNER, DRIVEWAY OFF
VIOLA LN.JD

SUBDIV:
PHONE : (910) 893-8858
PHONE :

STRUCTURE: 000 000 46X50 3BR CRAWL W/DECK

FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3.00 PROPOSED USE : SFD
SEPTIC - EXISTING? : NEW

PERMIT: CPSF 00 CP * SFD

| TYP/SQ | REQUESTED COMPLETED | INSP RESULT | DESCRIPTION RESULTS/COMMENTS |
|---------|-----------------------------|-------------------|---|
| B101 01 | 12/21/07 <u>12.21.07</u> | TI <u>APBS</u> | R*BLDG FOOTING / TEMP SVC POLE VRU #: 001537778 As early as possible. Thank you, Chris |

COMMENTS AND NOTES

47586884

SCANNED
DATE 12/19/08

ADDRESS . : 25 VIOLA LN
CONTRACTOR : C M A BUILDERS LLC
OWNER . . : SMITH KATHERINE U #14
PARCEL . . : 04-0672- - -0209- -32-
APPL NUMBER: 07-50018830 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : SANDY GROVE #14-210N RT ON OLD COATS RD
LEFT ON OLD BUIES CREEK RD LEFT ON
VIOLA LN LOT ON CORNER, DRIVEWAY OFF
VIOLA LN.JD

SUBDIV:
PHONE : (910) 893-8858
PHONE :

STRUCTURE: 000 000 46X50 3BR CRAWL W/DECK
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

| TYP/SQ | REQUESTED COMPLETED | INSP RESULT | DESCRIPTION RESULTS/COMMENTS |
|---------|-------------------------------|-----------------|---|
| B101 01 | 12/21/07 12/21/07 | BS AP | R*BLDG FOOTING / TEMP SVC POLE VRU #: 001537778 As early as possible. Thank you, Chris 47586884 |
| B103 01 | <u>1/11/08</u> <u>1-11</u> | TI <u>AT</u> | R*BLDG FOUND & TEMP SVC POLE VRU #: 001545821 |

COMMENTS AND NOTES

ADDRESS . : 25 VIOLA LN SUBDIV:
CONTRACTOR : C M A BUILDERS LLC PHONE : (910) 893-8858
OWNER . . : SMITH KATHERINE U #14 PHONE :
PARCEL . . : 04-0672- - -0209- -32-
APPL NUMBER: 07-50018830 CP NEW RESIDENTIAL (SFD)

DIRECTIONS : SANDY GROVE #14-210N RT ON OLD COATS RD
LEFT ON OLD BUIES CREEK RD LEFT ON
VIOLA LN LOT ON CORNER, DRIVEWAY OFF
VIOLA LN.JD

STRUCTURE: 000 000 46X50 3BR CRAWL W/DECK
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

| TYP/SQ | REQUESTED COMPLETED | INSP RESULT | DESCRIPTION RESULTS/COMMENTS |
|---------|---------------------------|------------------|---|
| B101 01 | 12/21/07 12/21/07 | BS AP | R*BLDG FOOTING / TEMP SVC POLE VRU #: 001537778 As early as possible. Thank you, Chris 47586884 |
| B103 01 | 1/11/08 1/11/08 | KS AP | R*BLDG FOUND & TEMP SVC POLE VRU #: 001545821 1. Need longitudinal ties 2. Need test on plumbing. 3. Wire service with 4/0 |
| B105 01 | 1/17/08 <u>1-17-08</u> | TI <u>DIA</u> | R*OPEN FLOOR VRU #: 001548437 Early as possible. Thanks, Chris |

----- COMMENTS AND NOTES -----

ADDRESS . : 25 VIOLA LN SUBDIV:
CONTRACTOR : C M A BUILDERS LLC PHONE : (910) 893-8858
OWNER . . : SMITH KATHERINE U #14 PHONE :
PARCEL . . : 04-0672- - -0209- -32-
APPL NUMBER: 07-50018830 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : SANDY GROVE #14-210N RT ON OLD COATS RD
LEFT ON OLD BUIES CREEK RD LEFT ON
VIOLA LN LOT ON CORNER, DRIVEWAY OFF
VIOLA LN.JD

STRUCTURE: 000 000 46X50 3BR CRAWL W/DECK
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

| TYP/SQ | REQUESTED COMPLETED | INSP RESULT | DESCRIPTION RESULTS/COMMENTS |
|---------|------------------------|-----------------|---|
| B101 01 | 12/21/07 12/21/07 | BS AP | R*BLDG FOOTING / TEMP SVC POLE VRU #: 001537778 As early as possible. Thank you, Chris 47586884 |
| B103 01 | 1/11/08 1/11/08 | KS AP | R*BLDG FOUND & TEMP SVC POLE VRU #: 001545821 1. Need longitudinal ties 2. Need test on plumbing. 3. Wire service with 4/0 |
| B105 01 | 1/17/08 1/17/08 | KS AP | R*OPEN FLOOR VRU #: 001548437 Early as possible. Thanks, Chris |
| A814 01 | 2/06/08 | TI | ADDRESS CONFIRMATION VRU #: 001558246 |
| R427 01 | <u>2/06/08</u> 2-6 | <u>TI</u> DA | FOUR TRADE ROUGH IN >2500 VRU #: 001558253 |

----- COMMENTS AND NOTES -----

**Violation Notice
Do Not Remove**

**arnett County Inspection Department
102 East Front St P.O. Box 65
Lillington, NC 27546
Phone (910) 893-4876 Fax (910) 893-2793**

App #07-50018830

1. Valley rafters not supported back to load point. See plan.
2. Need protection plate at wire going thru bottom plate feeding receptacle on front porch.
fire caulk seam in top and bottom plate and vent where wall was doubled for bathroom plumbing

Ok to insulate

Code Enforcement Official

Signature Ken Slattum

ADDRESS . : 25 VIOLA LN
CONTRACTOR : C M A BUILDERS LLC
OWNER . . : SMITH KATHERINE U #14
PARCEL . . : 04-0672- - -0209- -32-
APPL NUMBER: 07-50018830 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : SANDY GROVE #14-210N RT ON OLD COATS RD
LEFT ON OLD BUIES CREEK RD LEFT ON
VIOLA LN LOT ON CORNER, DRIVEWAY OFF
VIOLA LN.JD

SUBDIV:
PHONE : (910) 893-8858
PHONE :

STRUCTURE: 000 000 46X50 3BR CRAWL W/DECK
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

| TYP/SQ | REQUESTED COMPLETED | INSP RESULT | DESCRIPTION RESULTS/COMMENTS | VRU #: |
|---------|------------------------|----------------|---|------------------------------|
| B101 01 | 12/21/07 12/21/07 | BS AP | R*BLDG FOOTING / TEMP SVC POLE As early as possible. Thank you, Chris 47586884 | 001537778 |
| B103 01 | 1/11/08 1/11/08 | KS AP | R*BLDG FOUND & TEMP SVC POLE 1. Need longitudinal ties 2. Need test on plumbing. 3. Wire service with 4/0 | 001545821 |
| B105 01 | 1/17/08 1/17/08 | KS AP | R*OPEN FLOOR Early as possible. Thanks, Chris | 001548437 |
| A814 01 | 2/06/08 | TI | ADDRESS CONFIRMATION | 001558246 |
| R427 01 | 2/06/08 2/06/08 | KS DA | FOUR TRADE ROUGH IN >2500 1-VALLEY RAFTERS NOT SUPPORTED BACK TO LOAD POINT. *SEE PLAN. 2-NEED PROTECTION PLATE AT WIRE GOING THRU BOTTOM PLATE FEEDING RECEPTACLE ON FRONT PORCH. 3-FIRE CAULK SEAM IN TOP AND BOTTOM PLATE AND VENT WHERE WALL WAS DOUBLED FOR BATHROOM PLUMBING. | 001558253 |
| A814 02 | 2/08/08 | TI | ADDRESS CONFIRMATION | 001560291 |
| R227 01 | 2/08/08 | TI | TWO TRADE ROUGH IN >2500 | 001559871 |
| I129 01 | 2-8 2/08/08 | AP TI AP | R*INSULATION INSPECTION | TIME: 17:00 VRU #: 001560358 |

COMMENTS AND NOTES

ADDRESS : 25 VIOLA LN
CONTRACTOR : C M A BUILDERS LLC
OWNER : SMITH KATHERINE U #14
PARCEL : 04-0672- - -0209- -32-
APPL NUMBER: 07-50018830 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : SANDY GROVE #14-210N RT ON OLD COATS RD
LEFT ON OLD BUIES CREEK RD LEFT ON
VIOLA LN LOT ON CORNER, DRIVEWAY OFF
VIOLA LN.JD

SUBDIV:
PHONE : (910) 893-8858
PHONE :

STRUCTURE: 000 000 46X50 3BR CRAWL W/DECK
FLOOD ZONE . . . : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

| TYP/SQ | REQUESTED COMPLETED | INSP RESULT | DESCRIPTION RESULTS/COMMENTS |
|---------|------------------------|----------------|--|
| B101 01 | 12/21/07 12/21/07 | BS AP | R*BLDG FOOTING / TEMP SVC POLE VRU #: 001537778 As early as possible. Thank you, Chris 47586884 |
| B103 01 | 1/11/08 1/11/08 | KS AP | R*BLDG FOUND & TEMP SVC POLE VRU #: 001545821 1. Need longitudinal ties 2. Need test on plumbing. 3. Wire service with 4/0 |
| B105 01 | 1/17/08 1/17/08 | KS AP | R*OPEN FLOOR VRU #: 001548437 Early as possible. Thanks, Chris |
| R427 01 | 2/06/08 2/06/08 | KS DA | FOUR TRADE ROUGH IN >2500 VRU #: 001558253 1-VALLEY RAFTERS NOT SUPPORTED BACK TO LOAD POINT. *SEE PLAN. 2-NEED PROTECTION PLATE AT WIRE GOING THRU BOTTOM PLATE FEEDING RECEPTACLE ON FRONT PORCH. 3-FIRE CAULK SEAM IN TOP AND BOTTOM PLATE AND VENT WHERE WALL WAS DOUBLED FOR BATHROOM PLUMBING. |
| A814 01 | 2/06/08 2/08/08 | TI AP | ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001558246 ✓ 25 viola ln |
| R227 01 | 2/08/08 2/08/08 | KS AP | TWO TRADE ROUGH IN >2500 VRU #: 001559871 |
| I129 01 | 2/08/08 2/08/08 | KS AP | R*INSULATION INSPECTION TIME: 17:00 VRU #: 001560358 |
| H824 01 | 3/04/08 3/04/08 | JM AP | ✓ ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001572700 |
| R429 01 | 4/01/08 | TI | FOUR TRADE FINAL VRU #: 001586224 |

AP-MR

----- COMMENTS AND NOTES -----

**COUNTY OF HARNETT
DEPARTMENT OF BUILDING INSPECTION
AND PLANNING/DEVELOPMENT
CERTIFICATE OF OCCUPANCY**

This certificate issued pursuant to the requirements of Section 105 of the North Carolina State Building Code and the Harnett County Zoning Ordinance certifies at the time of issuance this structure was in compliance with the various ordinances of the County of Harnett regulating development and building construction or use. For the following:

Use Classification: R-3

Owner: CMA Builders

911 Address: _____

25 Viola Ln.

State: _____ Zip Code: _____

Date: 5-8-8

M. J. Ream
Building Official

PERMIT NUMBERS

Building Permit No.: 07-50018830

Electrical Permit No.: 11

Insulation Permit No.: 11

Plumbing Permit No.: 11

Mech. Permit No.: 11

MFG. Home: _____