

Improvement Permit

A building permit cannot be issued with only an Improvement Permit

ISSUED TO: CMA BUILDERS LLC
PROPERTY LOCATION: SR1542 OLD BUEBS CREEK RD
SUBDIVISION: Sandy Grove Sec II
LOT # 14
Type of Structure: SFD
Proposed Wastewater System Type: 25% REDUCTION System
Projected Daily Flow: GPD
Number of bedrooms: 3
Number of Occupants: 6 max
Basement: No
Pump Required: May be required based on final location and elevations of facilities
Type of Water Supply: Public
Permit valid for: Five years

Authorized State Agent: James E. Manhart Date: 11-21-07 SEE ATTACHED SITE SKETCH
The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.

Construction Authorization

(Required for Building Permit)

The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout.

ISSUED TO: CMA BUILDERS LLC
PROPERTY LOCATION: SR1542 OLD BUEBS CREEK RD
SUBDIVISION: Sandy Grove Sec II
LOT # 14
Facility Type: SFD
Basement? No
Type of Wastewater System: 25% REDUCTION System (Initial)
Wastewater Flow: 360 GPD
(See note below, if applicable) 25% REDUCTION System (Repair)

Installation Requirements/Conditions

Septic Tank Size 1000 gallons
Pump Tank Size gallons
Exact length of each trench 3x 80 feet
Trenches shall be installed on contour at a Maximum Trench Depth of: 28-318 inches
Trench Spacing: 9 Feet on Center
Soil Cover: 6 inches
Aggregate Depth: 12 inches total

**If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.

Owner/Legal Representative Signature: Date:

This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit.

Authorized State Agent: James E. Manhart Date: 11-21-07
Construction Authorization Expiration Date: 11-21-12
SEE ATTACHED SITE SKETCH

HTE# 07-5-18830

Permit # 24413

Harnett County Department of Public Health Site Sketch

PROPERTY LOCATOR: SR1542 OLD BUEBS CREEK RD

ISSUED TO: CMA BUEIDERS SUBDIVISION Sandy Grove Sec III LOT # 14

Authorized State Agent: James E. Manhart Date: 11-21-07

