
ADDRESS . . : 275 BASKET OAK DR
CONTRACTOR : CAVINESS LAND DEVELOPMENT
OWNER . . . : WOODSHIRE PARTNERS LLC #142
PARCEL . . . : 01-0536-05- -0028- -29-
APPL NUMBER: 07-50018900 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : FOREST OAKS #142-27W LEFT ON NURSERY
LEFT ON LEMEUL BLACK RD LEFT INTO
S/D.JD

STRUCTURE: 000 000 58X44 3BR W/GARAGE
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
R127 01	1/02/08	DT	ONE TRADE ROUGH IN > 2500 VRU #: 001541267
	1/02/08	AP	Inspection was for plumbing under slab.
B101 01	1/03/08	TI	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001541820
	<u>1/3/08</u>	<u>AP DT</u>	Monolithic slab inspection

----- COMMENTS AND NOTES -----

SCANNED
6/30/08
DATE

ADDRESS : 275 BASKET OAK DR
CONTRACTOR : CAVINESS LAND DEVELOPMENT
OWNER : WOODSHIRE PARTNERS LLC #142
PARCEL : 01-0536-05- -0028- -29-
APPL NUMBER: 07-50018900 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : FOREST OAKS #142-27W LEFT ON NURSERY
LEFT ON LEMEUL BLACK RD LEFT INTO
S/D.JD

SUBDIV: FOREST OAKS PH 3 99LOTS
PHONE : (919) 481-0503
PHONE :

STRUCTURE: 000 000 58X44 3BR W/GARAGE
FLOOD ZONE . . . : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
R127 01	1/02/08	DT	ONE TRADE ROUGH IN > 2500 VRU #: 001541267
	1/02/08	AP	Inspection was for plumbing under slab.
B101 01	1/03/08	DT	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001541820
	1/03/08	AP	Monolithic slab inspection
A814 01	1/09/08	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001542575
	1/09/08	AP	275 BASKET OAK DR
R427 01	1/28/08	TI	FOUR TRADE ROUGH IN >2500 VRU #: 001553278

DA JH

COMMENTS AND NOTES

ADDRESS : 275 BASKET OAK DR
CONTRACTOR : CAVINESS LAND DEVELOPMENT
OWNER : WOODSHIRE PARTNERS LLC #142
PARCEL : 01-0536-05- -0028- -29-
APPL NUMBER: 07-50018900 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : FOREST OAKS #142-27W LEFT ON NURSERY
LEFT ON LEMEUL BLACK RD LEFT INTO
S/D.JD

SUBDIV: FOREST OAKS PH 3 99LOTS
PHONE : (919) 481-0503
PHONE :

STRUCTURE: 000 000 58X44 3BR W/GARAGE
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
R127 01	1/02/08	DT	ONE TRADE ROUGH IN > 2500 VRU #: 001541267
	1/02/08	AP	Inspection was for plumbing under slab.
B101 01	1/03/08	DT	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001541820
	1/03/08	AP	Monolithic slab inspection
A814 01	1/09/08	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001542575
	1/09/08	AP	275 BASKET OAK DR
R427 01	1/28/08	DT	FOUR TRADE ROUGH IN >2500 VRU #: 001553278
	1/28/08	DA	1) Fire box needs to be in @ rough in. 2) Nail all 2ply truss per truss drawings. 3) 3' head of water on drain lines. 4) Missing nails in roof truss hangers @ each end hanger in master bedroom. 5) Missing uplift clips on 2ply truss in master bedroom on point #1 & #5 and bedroom #3 on point #2 & #4.
R427 02	1/31/08	TI	FOUR TRADE ROUGH IN >2500 VRU #: 001554963

AP-14K

COMMENTS AND NOTES

Insul. for

ADDRESS : 275 BASKET OAK DR SUBDIV: FOREST OAKS PH 3 99LOTS
CONTRACTOR : CAVINESS LAND DEVELOPMENT PHONE : (919) 481-0503
OWNER : WOODSHIRE PARTNERS LLC #142 PHONE :
PARCEL : 01-0536-05- -0028- -29-
APPL NUMBER: 07-50018900 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : FOREST OAKS #142-27W LEFT ON NURSERY
LEFT ON LEMEUL BLACK RD LEFT INTO
S/D.JD

STRUCTURE: 000 000 58X44 3BR W/GARAGE
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
R127 01	1/02/08	DT	ONE TRADE ROUGH IN > 2500 VRU #: 001541267
	1/02/08	AP	Inspection was for plumbing under slab.
B101 01	1/03/08	DT	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001541820
	1/03/08	AP	Monolithic slab inspection
A814 01	1/09/08	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001542575
	1/09/08	AP	275 BASKET OAK DR
R427 01	1/28/08	JH	FOUR TRADE ROUGH IN >2500 VRU #: 001553278
	1/28/08	DA	1)Fire box needs to be in @ rough in. 2)Nail all 2ply truss per truss drawings. 3)3' head of water on drain lines. 4)Missing nails in roof truss hangers @ each end hanger in master bedroom. 5)Missing uplift clips on 2ply truss in master bedroom on point #1 & #5 and bedroom #3 on point #2 & #4.
R427 02	1/31/08	MR	FOUR TRADE ROUGH IN >2500 VRU #: 001554963
	1/31/08	AP	ins. also
I129 01	2/01/08	TI	R*INSULATION INSPECTION TIME: 17:00 VRU #: 001556513

AP-IVR

COMMENTS AND NOTES

ADDRESS . . : 275 BASKET OAK DR
CONTRACTOR : CAVINESS LAND DEVELOPMENT
OWNER . . . : WOODSHIRE PARTNERS LLC #142
PARCEL . . . : 01-0536-05- -0028- -29-
APPL NUMBER: 07-50018900 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : FOREST OAKS #142-27W LEFT ON NURSERY
LEFT ON LEMEUL BLACK RD LEFT INTO
S/D.JD

SUBDIV: FOREST OAKS PH 3 99LOTS
PHONE : (919) 481-0503
PHONE :

STRUCTURE: 000 000 58X44 3BR W/GARAGE

FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3.00 PROPOSED USE : SFD
SEPTIC - EXISTING? : NEW

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
R127 01	1/02/08 <u>1/2/08</u>	TI <u>AR DT</u>	ONE TRADE ROUGH IN > 2500 VRU #: 001541267

----- COMMENTS AND NOTES -----

ADDRESS : 275 BASKET OAK DR
CONTRACTOR : CAVINESS LAND DEVELOPMENT
OWNER : WOODSHIRE PARTNERS LLC #142
PARCEL : 01-0536-05- -0028- -29-
APPL NUMBER: 07-50018900 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : FOREST OAKS #142-27W LEFT ON NURSERY
LEFT ON LEMEUL BLACK RD LEFT INTO
S/D.JD

SUBDIV: FOREST OAKS PH 3 99LOTS
PHONE : (919) 481-0503
PHONE :

STRUCTURE: 000 000 58X44 3BR W/GARAGE
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
R127 01	1/02/08	DT	ONE TRADE ROUGH IN > 2500 VRU #: 001541267
	1/02/08	AP	Inspection was for plumbing under slab.
B101 01	1/03/08	DT	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001541820
	1/03/08	AP	Monolithic slab inspection
A814 01	1/09/08	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001542575
	1/09/08	AP	✓ 275 BASKET OAK DR
R427 01	1/28/08	JH	FOUR TRADE ROUGH IN >2500 VRU #: 001553278
	1/28/08	DA	1)Fire box needs to be in @ rough in. 2)Nail all 2ply truss per truss drawings. 3)3' head of water on drain lines. 4)Missing nails in roof truss hangers @ each end hanger in master bedroom. 5)Missing uplift clips on 2ply truss in master bedroom on point #1 & #5 and bedroom #3 on point #2 & #4.
R427 02	1/31/08	MR	FOUR TRADE ROUGH IN >2500 VRU #: 001554963
	1/31/08	AP	ins. also
I129 01	2/01/08	MR	R*INSULATION INSPECTION TIME: 17:00 VRU #: 001556513
	2/06/08	AP	
H824 01	2/21/08	JW	✓ ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001567973
	2/21/08	AP	
R431 01	6/24/08	TI	FOUR TRADE FINAL >2500 VRU #: 001630870

AP JD

----- COMMENTS AND NOTES -----

**COUNTY OF HARNETT
DEPARTMENT OF BUILDING INSPECTION
AND PLANNING/DEVELOPMENT
CERTIFICATE OF OCCUPANCY**

This certificate issued pursuant to the requirements of Section 105 of the North Carolina State Building Code and the Harnett County Zoning Ordinance certifies at the time of issuance this structure was in compliance with the various ordinances of the County of Harnett regulating development and building construction or use. For the following:

Use Classification: SFD

PERMIT NUMBERS

Owner: Coviness Land Development

Building Permit No.: _____

911 Address: 275 Basket Oak Dr

Electrical Permit No.: _____

Insulation Permit No.: _____

Plumbing Permit No.: _____

State: _____ Zip Code: _____

Mech. Permit No.: _____

MFG. Home: _____

Date: 6-24-08

James Hall
Building Official

DT 50018700