HTE# 07-5-18954

## Harness County Department of Public Issulth 24441

## **Improvement Permit**

A building permit cannot be issued with only an Improvement Permit PROPERTY LOCATION: SR 1448 AT WENS RD ISSUED TO: STANGE / BUILDONS SUBDIVISION Howards from NEW 🗸 REPAIR EXPANSION Site Improvements required prior to Construction Authorization Issuance: SFID Type of Structure: Proposed Wastewater System Type: 25% NGOVCTON System Projected Daily Flow: 360 May be required based on final location and elevations of facilities Pump Required: ☐Yes ☐ No Type of Water Supply: Community Public Well Distance from well feet Five years Permit valid for: ☐ No expiration The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit. Construction Authorization (Required for Building Permit) The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958. and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout. ISSUED TO: STANCEL BUILDENS PROPERTY LOCATION: SC1448 ATKENS KD SUBDIVISION Howards from LOT # Facility Type: Expansion Basement? Yes Basement Fixtures? 

Yes No Type of Wastewater System\*\* 25% Restauration (Initial) Wastewater Flow: 360 GPD (See note below, if applicable 

) Installation Requirements/Conditions Exact length of each trench  $\frac{2}{120}$ Trench Spacing: 9 Feet on Center Septic Tank Size 1000 gallons Pump Tank Size gallons Trenches shall be installed on contour at a Maximum Trench Depth of: 28-7/8 (Maximum soil cover shall not exceed (Trench bottoms shall be level to +/-1/4" 36" above the trench bottom) in all directions) Pump Requirements: ft. TDH vs. inches below pipe Aggregate Depth: \_\_\_\_\_\_ inches above pipe Conditions: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit. Owner/Legal Representative Signature: \_ This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit. SEE ATTACHED SITE SKETCH Authorized State Agent: Construction Authorization Expiration Date: 2-25-13

HTE# 07-5-18954

Permit # 24441

## Harnett County Department of Public Health Site Sketch

ISSUED TO: STANCE BULIDERS TOX SUBDIVISION Howards Fam LOT # Co

Authorized State Agent June 5 Manham Acres Date: 2-25-08

