

HTE# 075-18959

Harrison County Department of Public Health

24437

Improvement Permit

A building permit cannot be issued with only an Improvement Permit

ISSUED TO: STANLEY BUILDERS INC PROPERTY LOCATION: SR 1448 ATKENS RD
NEW REPAIR EXPANSION SUBDIVISION: Howards Farm LOT # 2
Site Improvements required prior to Construction Authorization Issuance:

Type of Structure: SFD
Proposed Wastewater System Type: 25% REDUCTION
Projected Daily Flow: 360 GPD
Number of bedrooms: 3 Number of Occupants: 6 max
Basement Yes No
Pump Required: Yes No May be required based on final location and elevations of facilities
Type of Water Supply: Community Public Well Distance from well _____ feet Permit valid for: Five years
Permit conditions: _____ No expiration

Authorized State Agent: James E. Marshall Date: 2- - 08 SEE ATTACHED SITE SKETCH
The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.

Construction Authorization

(Required for Building Permit)

The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout.

ISSUED TO: STANLEY BUILDERS INC PROPERTY LOCATION: SR 1448 ATKENS RD
SUBDIVISION: Howards Farm LOT # 2
Facility Type: SFD New Expansion Repair
Basement? Yes No Basement Fixtures? Yes No
Type of Wastewater System** 25% REDUCTION (Initial) Wastewater Flow: 360 GPD
(See note below, if applicable)
25% REDUCTION System (Repair)

Installation Requirements/Conditions

Septic Tank Size 1000 gallons Exact length of each trench 2x 120 feet Trench Spacing: 9 Feet on Center
Pump Tank Size _____ gallons Trenches shall be installed on contour at a Soil Cover: 6 inches
Maximum Trench Depth of: 30-718 inches (Maximum soil cover shall not exceed 36" above the trench bottom)
(Trench bottoms shall be level to +1-1/4" in all directions)
Pump Requirements: _____ ft. TDH vs. _____ GPM Aggregate Depth: 6 inches below pipe
2 inches above pipe
Conditions: _____ 12 inches total

**If applicable: *I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.*

Owner/Legal Representative Signature: _____ Date: _____

This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit.

Authorized State Agent: James E. Marshall Date: 2-25-08 SEE ATTACHED SITE SKETCH
Construction Authorization Expiration Date: 2-25-13

HTE# 07-5-18959

Permit # 24437

Harnett County Department of Public Health Site Sketch

PROPERTY LOCATION: SR 1448 ATKENS RD

ISSUED TO: STANCI Builders Inc SUBDIVISION HONDAS FARM LOT # 2

Authorized State Agent James E. Manhart Date: 2-25-08

