
ADDRESS . . : 295 BASKET OAK DR SUBDIV: FOREST OAKS PH 3 99LOTS
CONTRACTOR : CAVINESS LAND DEVELOPMENT PHONE : (919) 481-0503
OWNER . . . : WOODSHIRE PARTNERS LLC #141 PHONE :
PARCEL . . . : 01-0536-05- -0028- -28-
APPL NUMBER: 07-50019009 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : FOREST OAKS #141-27W LEFT ON NURSERY
LEFT ON LEMEUL BLACK RD LEFT INTO 2ND
S/D ENTRANCE, LOT ON CORNER OF
BLUEVONNET & BASKET OAK, DW OFF
BASKET.JD

STRUCTURE: 000 000 32X52 3BR W/GARAGE
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
P309 01	2/01/08	TI <i>AF-MR</i>	R*PLUMB UNDER SLAB VRU #: 001556570

----- COMMENTS AND NOTES -----

ADDRESS : 295 BASKET OAK DR
CONTRACTOR : CAVINESS LAND DEVELOPMENT
OWNER : WOODSHIRE PARTNERS LLC #141
PARCEL : 01-0536-05- -0028- -28-
APPL NUMBER: 07-50019009 CP NEW RESIDENTIAL (SFD)

SUBDIV: FOREST OAKS PH 3 99LOTS
PHONE : (919) 481-0503
PHONE :

DIRECTIONS : FOREST OAKS #141-27W LEFT ON NURSERY
LEFT ON LEMEUL BLACK RD LEFT INTO 2ND
S/D ENTRANCE, LOT ON CORNER OF
BLUEVONNET & BASKET OAK, DW OFF
BASKET.JD

STRUCTURE: 000 000 32X52 3BR W/GARAGE
FLOOD ZONE . . . : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
P309 01	2/01/08	MR	R*PLUMB UNDER SLAB VRU #: 001556570
	2/01/08	AP	
R125 01	2/06/08	TI	ONE TRADE ROUGH IN VRU #: 001558212
	2/05/08	CA	Need slab inspection, Thanks
B111 01	2/06/08	TI	R*BLDG SLAB INSP TIME: 17:00 VRU #: 001559087
	<u>2/6/08</u>	<u>AR DT</u>	

COMMENTS AND NOTES

ADDRESS : 295 BASKET OAK DR SUBDIV: FOREST OAKS PH 3 99LOTS
CONTRACTOR : CAVINESS LAND DEVELOPMENT PHONE : (919) 481-0503
OWNER : WOODSHIRE PARTNERS LLC #141 PHONE :
PARCEL : 01-0536-05- -0028- -28-
APPL NUMBER: 07-50019009 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : FOREST OAKS #141-27W LEFT ON NURSERY
LEFT ON LEMEUL BLACK RD LEFT INTO 2ND
S/D ENTRANCE, LOT ON CORNER OF
BLUEVONNET & BASKET OAK, DW OFF
BASKET.JD

STRUCTURE: 000 000 32X52 3BR W/GARAGE
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
P309 01	2/01/08	MR	R*PLUMB UNDER SLAB VRU #: 001556570
	2/01/08	AP	
R125 01	2/06/08	TI	ONE TRADE ROUGH IN VRU #: 001558212
	2/05/08	CA	Need slab inspection, Thanks
B111 01	2/06/08	DT	R*BLDG SLAB INSP TIME: 17:00 VRU #: 001559087
	2/06/08	AP	
A814 01	2/13/08	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001559888
	2/14/08	AP	295 BASKET OAK DR
R425 01	2/27/08	TI	FOUR TRADE ROUGH IN VRU #: 001568869

DA-MIR

----- COMMENTS AND NOTES -----

ADDRESS . : 295 BASKET OAK DR SUBDIV: FOREST OAKS PH 3 99LOTS
 CONTRACTOR : CAVINESS LAND DEVELOPMENT PHONE : (919) 481-0503
 OWNER . . : WOODSHIRE PARTNERS LLC #141 PHONE :
 PARCEL . . : 01-0536-05- -0028- -28-
 APPL NUMBER: 07-50019009 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : FOREST OAKS #141-27W LEFT ON NURSERY
 LEFT ON LEMEUL BLACK RD LEFT INTO 2ND
 S/D ENTRANCE, LOT ON CORNER OF
 BLUEVONNET & BASKET OAK, DW OFF
 BASKET.JD

STRUCTURE: 000 000 32X52 3BR W/GARAGE
 FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
P309 01	2/01/08	MR	R*PLUMB UNDER SLAB VRU #: 001556570
	2/01/08	AP	
R125 01	2/06/08	TI	ONE TRADE ROUGH IN VRU #: 001558212
	2/05/08	CA	Need slab inspection, Thanks
B111 01	2/06/08	DT	R*BLDG SLAB INSP TIME: 17:00 VRU #: 001559087
	2/06/08	AP	
A814 01	2/13/08	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001559888
	2/14/08	AP	295 BASKET OAK DR
R425 01	2/27/08	MR	FOUR TRADE ROUGH IN VRU #: 001568869
	2/27/08	DA	baffles vent boot missing
R425 02	3/03/08	TI	FOUR TRADE ROUGH IN VRU #: 001570874

3-3

AP

KS

 COMMENTS AND NOTES

ADDRESS : 295 BASKET OAK DR
CONTRACTOR : CAVINESS LAND DEVELOPMENT
OWNER : WOODSHIRE PARTNERS LLC #141
PARCEL : 01-0536-05- -0028- -28-
APPL NUMBER: 07-50019009 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : FOREST OAKS #141-27W LEFT ON NURSERY
LEFT ON LEMEUL BLACK RD LEFT INTO 2ND
S/D ENTRANCE, LOT ON CORNER OF
BLUEVONNET & BASKET OAK, DW OFF
BASKET.JD

SUBDIV: FOREST OAKS PH 3 99LOTS
PHONE : (919) 481-0503
PHONE :

STRUCTURE: 000 000 32X52 3BR W/GARAGE
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
P309 01	2/01/08 2/01/08	MR AP	R*PLUMB UNDER SLAB VRU #: 001556570
R125 01	2/06/08 2/05/08	TI CA	ONE TRADE ROUGH IN VRU #: 001558212 Need slab inspection, Thanks
B111 01	2/06/08 2/06/08	DT AP	R*BLDG SLAB INSP TIME: 17:00 VRU #: 001559087
A814 01	2/13/08 2/14/08	TI AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001559888 295 BASKET OAK DR
R425 01	2/27/08 2/27/08	MR DA	FOUR TRADE ROUGH IN VRU #: 001568869 baffles vent boot missing
R425 02	3/03/08 3/03/08	KS AP	FOUR TRADE ROUGH IN VRU #: 001570874 1. Attic access to unit shall have a catwalk 24 inches by 30inches. No unprotected romex within 6 feet of the access hole. 2. Waterlines to waterheater in attic are not insulated. 3. Secure insulation in bonus room.
I129 01	3/05/08	TI	R*INSULATION INSPECTION VRU #: 001572140

AP-OR

COMMENTS AND NOTES

ADDRESS : 295 BASKET OAK DR
 CONTRACTOR : CAVINESS LAND DEVELOPMENT
 OWNER : WOODSHIRE PARTNERS LLC #141
 PARCEL : 01-0536-05- -0028- -28-
 APPL NUMBER: 07-50019009 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : FOREST OAKS #141-27W LEFT ON NURSERY
 LEFT ON LEMEUL BLACK RD LEFT INTO 2ND
 S/D ENTRANCE, LOT ON CORNER OF
 BLUEVONNET & BASKET OAK, DW OFF
 BASKET.JD

SUBDIV: FOREST OAKS PH 3 99LOTS
 PHONE : (919) 481-0503
 PHONE :

STRUCTURE: 000 000 32X52 3BR W/GARAGE

FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
P309 01	2/01/08	MR	R*PLUMB UNDER SLAB VRU #: 001556570
	2/01/08	AP	
R125 01	2/06/08	TI	ONE TRADE ROUGH IN VRU #: 001558212
	2/05/08	CA	Need slab inspection, Thanks
B111 01	2/06/08	DT	R*BLDG SLAB INSP TIME: 17:00 VRU #: 001559087
	2/06/08	AP	
A814 01	2/13/08	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001559888
	2/14/08	AP	✓ 295 BASKET OAK DR
R425 01	2/27/08	MR	FOUR TRADE ROUGH IN VRU #: 001568869
	2/27/08	DA	baffles vent boot missing
R425 02	3/03/08	KS	FOUR TRADE ROUGH IN VRU #: 001570874
	3/03/08	AP	1. Attic access to unit shall have a catwalk 24 inches by 30inches. No unprotected romex within 6 feet of the access hole. 2. Waterlines to waterheater in attic are not insulated. 3. Secure insulation in bonus room.
I129 01	3/05/08	MR	R*INSULATION INSPECTION VRU #: 001572140
	3/05/08	AP	
H824 01	5/08/08	JW	✓ ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001607191
	5/08/08	AP	
R429 01	12/05/08	TI	FOUR TRADE FINAL VRU #: 001713854

DP-MR

----- COMMENTS AND NOTES -----

ADDRESS : 295 BASKET OAK DR SUBDIV: FOREST OAKS PH 3 99LOTS
 CONTRACTOR : CAVINESS LAND DEVELOPMENT PHONE : (919) 481-0503
 OWNER : WOODSHIRE PARTNERS LLC #141 PHONE :
 PARCEL : 01-0536-05- -0028- -28-
 APPL NUMBER: 07-50019009 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : FOREST OAKS #141-27W LEFT ON NURSERY
 LEFT ON LEMEUL BLACK RD LEFT INTO 2ND
 S/D ENTRANCE, LOT ON CORNER OF
 BLUEVONNET & BASKET OAK, DW OFF
 BASKET.JD

STRUCTURE: 000 000 32X52 3BR W/GARAGE
 FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
P309 01	2/01/08 2/01/08	MR AP	R*PLUMB UNDER SLAB VRU #: 001556570
R125 01	2/06/08 2/05/08	TI CA	ONE TRADE ROUGH IN VRU #: 001558212 Need slab inspection, Thanks
B111 01	2/06/08 2/06/08	DT AP	R*BLDG SLAB INSP TIME: 17:00 VRU #: 001559087
A814 01	2/13/08 2/14/08	TI AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001559888 ✓ 295 BASKET OAK DR
R425 01	2/27/08 2/27/08	MR DA	FOUR TRADE ROUGH IN VRU #: 001568869 baffles vent boot missing
R425 02	3/03/08 3/03/08	KS AP	FOUR TRADE ROUGH IN VRU #: 001570874 1. Attic access to unit shall have a catwalk 24 inches by 30inches. No unprotected romex within 6 feet of the access hole. 2. Waterlines to waterheater in attic are not insulated. 3. Secure insulation in bonus room.
I129 01	3/05/08 3/05/08	MR AP	R*INSULATION INSPECTION VRU #: 001572140
H824 01	5/08/08 5/08/08	JW AP	✓ ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001607191
R429 01	12/05/08 12/05/08	MR DP	FOUR TRADE FINAL VRU #: 001713854 1. no light or outlet in attic 2. AHU in attic not wired 3. #6 SE cannot be fused higher than 40 amps
R429 02	12/09/08	TI	FOUR TRADE FINAL VRU #: 001714757

AP-MR

COMMENTS AND NOTES

**COUNTY OF HARNETT
DEPARTMENT OF BUILDING INSPECTION
AND PLANNING/DEVELOPMENT
CERTIFICATE OF OCCUPANCY**

This certificate issued pursuant to the requirements of Section 105 of the North Carolina State Building Code and the Harnett County Zoning Ordinance certifies at the time of issuance this structure was in compliance with the various ordinances of the County of Harnett regulating development and building construction or use. For the following:

Use Classification: R-3

Owner: Caumess Land Dev.

911 Address: _____

295 Basket Oak

State: _____ Zip Code: _____

Date: 12-9-8

Mike Reasie

Building Official

PERMIT NUMBERS

Building Permit No.: 07-50019009

Electrical Permit No.: 11

Insulation Permit No.: 11

Plumbing Permit No.: 11

Mech. Permit No.: 11

MFG. Home: _____