

HTE# 08-5-1916SR

Harnett County Department of Public Health 24442

Improvement Permit

A building permit cannot be issued with only an Improvement Permit

ISSUED TO: KEN DAWSON HOMES INC PROPERTY LOCATION: SR 1707 NEIGHBORS RD
 NEW REPAIR EXPANSION SUBDIVISION: BENNETT PLACE LOT # 11
 Type of Structure: SFD Site Improvements required prior to Construction Authorization Issuance:
 Proposed Wastewater System Type: 25% REDUCTION
 Projected Daily Flow: 360 GPD
 Number of bedrooms: 3 Number of Occupants: 6 max
 Basement Yes No
 Pump Required: Yes No May be required based on final location and elevations of facilities
 Type of Water Supply: Community Public Well Distance from well _____ feet
 Permit conditions: _____ Permit valid for: Five years
 No expiration

Authorized State Agent: James E. Manhart Date: 1-28-08 SEE ATTACHED SITE SKETCH
 The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.

Construction Authorization

(Required for Building Permit)

The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout.

ISSUED TO: KEN DAWSON HOMES INC PROPERTY LOCATION: SR 1707
 FACILITY TYPE: SFD New Expansion Repair
 SUBDIVISION: NEIGHBORS RD LOT # 11
 Basement? Yes No Basement Fixtures? Yes No
 Type of Wastewater System** 25% REDUCTION (Initial) Wastewater Flow: 360 GPD
 (See note below, if applicable
25% REDUCTION SYSTEM (Repair)

Installation Requirements/Conditions

Septic Tank Size 1000 gallons
 Pump Tank Size _____ gallons
 Exact length of each trench 4 x 80 feet
 Trenches shall be installed on contour at a
 Maximum Trench Depth of: 28" max inches
 (Trench bottoms shall be level to +/- 1/4" in all directions)
 Pump Requirements: _____ ft. TDH vs. _____ GPM
 Trench Spacing: 9 Feet on Center
 Soil Cover: 6 inches
 (Maximum soil cover shall not exceed 36" above the trench bottom)
 Aggregate Depth: 6 inches below pipe
2 inches above pipe
12 inches total

**If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.

Owner/Legal Representative Signature: _____ Date: _____

This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit.

Authorized State Agent: James E. Manhart Date: 1-28-08 SEE ATTACHED SITE SKETCH
 Construction Authorization Expiration Date: 1-28-13

HTE# 08-5-19165R

Permit # 24442

Harnett County Department of Public Health Site Sketch

ISSUED TO: KENDAWSON/HOMAS, INC PROPERTY LOCATION: 521707 NEIGHBORHOODS RD
SUBDIVISION: BENNETT PLACE LOT # 11

Authorized State Agent: James E. Markan for Date: 1-28-08

