
ADDRESS . . : 306 VALLEY OAK DR SUBDIV: FOREST OAKS PH 3 99LOTS
CONTRACTOR : H & H CONSTRUCTORS INC PHONE : (910) 486-4864
OWNER . . . : WOODSHIRE PARTNERS LLC PHONE :
PARCEL . . . : 01-0536-05- -0028- -39-
APPL NUMBER: 08-50019224 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : HWY 27 W TO NURSERY RD TURN LEFT ON
NURSERY RD LEFT ON LEMUEL BLACK RD LEFT
ON VALLEY OAK INTO FOREST OAKS S/D LOT
152 JB

STRUCTURE: 000 000 46X54 3BDR
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
A814 01	3/18/08	TI	ADDRESS CONFIRMATION VRU #: 001578814
P309 01	3/18/08	TI	R*PLUMB UNDER SLAB VRU #: 001578806

AP-IVR

----- COMMENTS AND NOTES -----

ADDRESS . : 306 VALLEY OAK DR SUBDIV: FOREST OAKS PH 3 99LOTS
CONTRACTOR : H & H CONSTRUCTORS INC PHONE : (910) 486-4864
OWNER . . : WOODSHIRE PARTNERS LLC PHONE :
PARCEL . . : 01-0536-05- -0028- -39-
APPL NUMBER: 08-50019224 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : HWY 27 W TO NURSERY RD TURN LEFT ON
NURSERY RD LEFT ON LEMUEL BLACK RD LEFT
ON VALLEY OAK INTO FOREST OAKS S/D LOT
152 JB

STRUCTURE: 000 000 46X54 3BDR
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
P309 01	3/18/08	MR	R*PLUMB UNDER SLAB VRU #: 001578806
	3/18/08	AP	
A814 01	3/18/08	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001578814
	3/18/08	AP	306 valley oak dr lot 152
B111 01	3/20/08	TI	R*BLDG SLAB INSP VRU #: 001579952

AP-MR

----- COMMENTS AND NOTES -----

ADDRESS . . : 306 VALLEY OAK DR SUBDIV: FOREST OAKS PH 3 99LOTS
CONTRACTOR : H & H CONSTRUCTORS INC PHONE : (910) 486-4864
OWNER . . : WOODSHIRE PARTNERS LLC PHONE :
PARCEL . . : 01-0536-05- -0028- -39-
APPL NUMBER: 08-50019224 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : HWY 27 W TO NURSERY RD TURN LEFT ON
NURSERY RD LEFT ON LEMUEL BLACK RD LEFT
ON VALLEY OAK INTO FOREST OAKS S/D LOT
152 JB

STRUCTURE: 000 000 46X54 3BDR
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
P309 01	3/18/08	MR	R*PLUMB UNDER SLAB VRU #: 001578806
	3/18/08	AP	
A814 01	3/18/08	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001578814
	3/18/08	AP	306 valley oak dr lot 152
B111 01	3/20/08	MR	R*BLDG SLAB INSP VRU #: 001579952
	3/20/08	AP	
R427 01	4/14/08	MR	FOUR TRADE ROUGH IN >2500 VRU #: 001592393
	4/14/08	CA	
R427 02	4/15/08	TI	FOUR TRADE ROUGH IN >2500 VRU #: 001593540

DAT

----- COMMENTS AND NOTES -----

THOMPSON
ENGINEERING, INC

Structural and geotechnical
custom residential design

March 31, 2008

Billy Smith
H & H Homes
2919 Breezewood Avenue
Fayetteville, NC 27303

Dear Mr. Smith,

The "Abbington" plan being constructed in Harnett County, North Carolina was reviewed to address the alternative front entry garage header where the brick veneer terminates at a water table across the gable instead of covering the entire gable as shown on the original plans.

Analysis revealed that a (2) 1 3/4" x 16" LVL header supported by two jacks each end will provide the required support for all applied loads, including up to 2" of brick veneer before it terminates at the water table and being finished with siding on the remainder of the gable. The lintel supporting the brick veneer is to be installed per the brick support notes included on the original plan.

Please call me if you have any questions.

The "Abbington" plan being c
Sincerely, to address the alter
veneer terminates at a water t
I.S. Thompson Engineering, Inc.


Jeffrey B. Whitson
Jeffrey B. Whitson, P.E.
be installed per the brick sup



3/31/08

1033 Wade Avenue, Suite 104
Raleigh, NC 27605

(919) 789-9919 OFFICE
(919) 789-9921 FAX



ADDRESS : 306 VALLEY OAK DR
 CONTRACTOR : H & H CONSTRUCTORS INC
 OWNER : WOODSHIRE PARTNERS LLC
 PARCEL : 01-0536-05- -0028- -39-
 APPL NUMBER: 08-50019224 CP NEW RESIDENTIAL (SFD)

SUBDIV: FOREST OAKS PH 3 99LOTS
 PHONE : (910) 486-4864
 PHONE :

DIRECTIONS : HWY 27 W TO NURSERY RD TURN LEFT ON
 NURSERY RD LEFT ON LEMUEL BLACK RD LEFT
 ON VALLEY OAK INTO FOREST OAKS S/D LOT
 152 JB

STRUCTURE: 000 000 46X54 3BDR
 FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
P309 01	3/18/08	MR	R*PLUMB UNDER SLAB VRU #: 001578806
	3/18/08	AP	
A814 01	3/18/08	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001578814
	3/18/08	AP	306 valley oak dr lot 152
B111 01	3/20/08	MR	R*BLDG SLAB INSP VRU #: 001579952
	3/20/08	AP	
R427 01	4/14/08	MR	FOUR TRADE ROUGH IN >2500 VRU #: 001592393
	4/14/08	CA	
R427 02	4/15/08	JH	FOUR TRADE ROUGH IN >2500 VRU #: 001593540
	4/15/08	DA	1) 3' head of water on drain lines. 2) Nail guards @ top plate in right corner of kitchen nook on back wall. 3) Missing ridge cap over kitchen nook & bonus room. 4) Replace cut stud behind sink in master bathroom.
I129 01	4/22/08	TI	R*INSULATION INSPECTION VRU #: 001596964
		<i>AP-MR</i>	
R427 04	4/22/08	TI	FOUR TRADE ROUGH IN >2500 VRU #: 001596956
		<i>AP-MR</i>	
R427 03	4/22/08	TI	FOUR TRADE ROUGH IN >2500 VRU #: 001596949
	4/21/08	CA	

COMMENTS AND NOTES

ADDRESS : 306 VALLEY OAK DR
CONTRACTOR : H & H CONSTRUCTORS INC
OWNER : WOODSHIRE PARTNERS LLC
PARCEL : 01-0536-05- -0028- -39-
APPL NUMBER: 08-50019224 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : HWY 27 W TO NURSERY RD TURN LEFT ON
NURSERY RD LEFT ON LEMUEL BLACK RD LEFT
ON VALLEY OAK INTO FOREST OAKS S/D LOT
152 JB

SUBDIV: FOREST OAKS PH 3 99LOTS
PHONE : (910) 486-4864
PHONE :

STRUCTURE: 000 000 46X54 3BDR
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
P309 01	3/18/08	MR	R*PLUMB UNDER SLAB VRU #: 001578806
	3/18/08	AP	
A814 01	3/18/08	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001578814
	3/18/08	AP	✓ 306 valley oak dr lot 152
B111 01	3/20/08	MR	R*BLDG SLAB INSP VRU #: 001579952
	3/20/08	AP	
R427 01	4/14/08	MR	FOUR TRADE ROUGH IN >2500 VRU #: 001592393
	4/14/08	CA	
R427 02	4/15/08	JH	FOUR TRADE ROUGH IN >2500 VRU #: 001593540
	4/15/08	DA	1)3' head of water on drain lines. 2)Nail guards @ top plate in right corner of kitchen nook on back wall. 3)Missing ridge cap over kitchen nook & bonus room. 4)Replace cut stud behind sink in master bathroom.
I129 01	4/22/08	MR	R*INSULATION INSPECTION VRU #: 001596964
	4/22/08	AP	
R427 04	4/22/08	MR	FOUR TRADE ROUGH IN >2500 VRU #: 001596956
	4/22/08	AP	
R427 03	4/22/08	TI	FOUR TRADE ROUGH IN >2500 VRU #: 001596949
	4/21/08	CA	
H824 01	5/12/08	JW	✓ ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001608546
	5/12/08	AP	
R431 01	6/05/08	TI	FOUR TRADE FINAL >2500 VRU #: 001620186

DP-MR

COMMENTS AND NOTES

- 1) Hidden splice box by kitchen/nook wall
- 2) Hole in garage wall

Harnett County
102 EAST FRONT ST
P O BOX 65
LILLINGTON NC 27546

DATE: 6/09/08
TIME: 10:52:47

RECEIPT #: 0000008502
CASHIER: JBROCK

APPLICATION NBR: 08-50019224
REFERENCE: REINSPECTION

ITEM DESCRIPTION	PAID
-----	-----
REINSP FEE < 9 VIOLATIONS	50.00
TOTAL AMOUNT PAID:	50.00
PAYMENT TYPE: ESCROW	

ADDRESS : 306 VALLEY OAK DR SUBDIV: FOREST OAKS PH 3 99LOTS
CONTRACTOR : H & H CONSTRUCTORS INC PHONE : (910) 486-4864
OWNER : WOODSHIRE PARTNERS LLC PHONE :
PARCEL : 01-0536-05- -0028- -39-
APPL NUMBER: 08-50019224 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : HWY 27 W TO NURSERY RD TURN LEFT ON
NURSERY RD LEFT ON LEMUEL BLACK RD LEFT
ON VALLEY OAK INTO FOREST OAKS S/D LOT
152 JB

STRUCTURE: 000 000 46X54 3BDR
FLOOD ZONE . . . : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
P309 01	3/18/08	MR	R*PLUMB UNDER SLAB VRU #: 001578806
	3/18/08	AP	
A814 01	3/18/08	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001578814
	3/18/08	AP	✓ 306 valley oak dr lot 152
B111 01	3/20/08	MR	R*BLDG SLAB INSP VRU #: 001579952
	3/20/08	AP	
R427 01	4/14/08	MR	FOUR TRADE ROUGH IN >2500 VRU #: 001592393
	4/14/08	CA	
R427 02	4/15/08	JH	FOUR TRADE ROUGH IN >2500 VRU #: 001593540
	4/15/08	DA	1)3' head of water on drain lines. 2)Nail guards @ top plate in right corner of kitchen nook on back wall. 3)Missing ridge cap over kitchen nook & bonus room. 4)Replace cut stud behind sink in master bathroom.
I129 01	4/22/08	MR	R*INSULATION INSPECTION VRU #: 001596964
	4/22/08	AP	
R427 04	4/22/08	MR	FOUR TRADE ROUGH IN >2500 VRU #: 001596956
	4/22/08	AP	
R427 03	4/22/08	TI	FOUR TRADE ROUGH IN >2500 VRU #: 001596949
	4/21/08	CA	
H824 01	5/12/08	JW	✓ ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001608546
	5/12/08	AP	
R431 01	6/05/08	MR	FOUR TRADE FINAL >2500 VRU #: 001620186
	6/05/08	DP	1. hidden splice box in kitchen wall 2. hole in garaage wall
R431 02	6/10/08	TI	FOUR TRADE FINAL >2500 VRU #: 001622612

AP-MR

----- COMMENTS AND NOTES -----

**COUNTY OF HARNETT
DEPARTMENT OF BUILDING INSPECTION
AND PLANNING/DEVELOPMENT
CERTIFICATE OF OCCUPANCY**

This certificate issued pursuant to the requirements of Section 105 of the North Carolina State Building Code and the Harnett County Zoning Ordinance certifies at the time of issuance this structure was in compliance with the various ordinances of the County of Harnett regulating development and building construction or use. For the following:

Use Classification: R-3 Conditional Use Permit No.: _____
Type of Construction: IV Building Permit No.: 08-50019224
Owner of Building: Wood Shire Partners Electrical Permit No.: _____
Building Address: 306 Valley Oak Insulation Permit No.: _____
Zoning District: _____ Plumbing Permit No.: _____
Zoning Permit No.: _____ Mech. Permit No.: _____
Date: 6-10-8 Envir. C.O. No.: _____
Mike Klam

Building Official

Zoning Official