

**SOIL SITE EVALUATION
 for ON-SITE WASTEWATER SYSTEM**

Owner: 08300 - 19225

Applicant:

Address:

Date Evaluated:

Proposed Facility: SFA

Design Flow (.1949): JLU

Property Size:

Location of Site: 1125

Property Recorded:

- Water Supply: Public Individual Well Spring Other
 Evaluation Method: Auger Boring Pit Cut
 Type of Wastewater: Sewage Industrial Process Mixed

P R O F I L E #	.1940 Landscape Position/ Slope%	Horizon Depth (IN.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1936 Sapra Class	.1944 Root Horiz	
S 3%		0-30	GR SL						.5
		30-38	SH SL						
		0-30	GR SL						.5
		30-38	SH SL						
		0-24	GR SL						.5
		24-38	SH SL						
		0-18	GR SL						.35
		18-28	SH SL						
		28-38	SH SL						
	0-18	GR SL						.35	
	18-28	SH SL							
	28-38	SH SL							

Description	Initial System	Repair System
Available Space (.1945)	/	/
System Type(s)	25'	25'
Site LTAR	.5	.75

Other Factors (.1946): _____
 Site Classification (.1948): P
 Evaluated By: JW
 Others Present: