

**SOIL SITE EVALUATION
 for ON-SITE WASTEWATER SYSTEM**

Owner:
 Address:
 Proposed Facility: *JFP* Design Flow (.1949): *368*
 Location of Site:
 Water Supply: Public Individual Well
 Evaluation Method: Auger Boring Pit
 Type of Wastewater: Sewage Industrial Process

Applicant: *19235*
 Date Evaluated: *2-6-08*
 Property Size:
 Property Recorded:
 Spring Other
 Cut
 Mixed

P R O F I L E #	.1940 Landscape Position/ Slope%	Horizon Depth (IN.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1944 Sapre Class	.1944 Restr Horiz	
1	L 6%	0-12	SL	FR GRN S.P.					.4
		12-48	SL	FR 1 3/4 S.S.S.P.					
2	L 6%	0-16	SL	FR GRN S.P.					.4
		16-48	SCL	FR 1 3/4 S.S.S.P.					
3	L 6%	0-12	SL	FR GRN S.P.					.2
		12-24	SC-CLAY	FR 1 3/4 S.P.					
		24"+	PM			24		PM	
4	L 4%	0-10	SL	FR GRN S.P.					.25
		10-16	SCL	FR 1 3/4 S.S.S.P.					
		16-30	SL CLAY	FR 1 3/4 S.P.					
		30"+	PM						
5	L 4%	0-10	SL	FR GRN S.P.					.25
		10-16	SCL	FR 1 3/4 S.S.S.P.					
		16-30	SL CLAY	FR 1 3/4 S.P.					
		30"+	PM						

Description	Initial System	Repair System
Available Space (.1945)	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
System Type(s)	<i>2 1/2"</i>	<i>retreat JPP</i>
Site LTAR	<i>.4</i>	<i>.2</i>

Other Factors (.1946):
 Site Classification (.1948): *U-375*
 Evaluated By: *[Signature]*
 Others Present:


COMMENTS: _____

<u>LANDSCAPE POSITIONS</u>	<u>GROUP</u>	<u>TEXTURES</u>	<u>.1955 LTAR</u>	<u>CONSISTENCE MOIST</u>	<u>WET</u>
R-RIDGE S-SHOULDER SLOPE L-LINEAR SLOPE FS-FOOT SLOPE N-NOSE SLOPE H-HEAD SLOPE CC-CONCLAVE SLOPE CV-CONVEX SLOPE T-TERRACE FP-FLOOD PLAN	I	S-SAND LS-LOAMY SAND	1.2 - 0.8	VFR-VERY FRIABLE FR-FRIABLE	NS-NON-STICKY SS-SLIGHTLY STICKY
	II	SL-SANDY LOAM L-LOAM	0.8 - 0.6	FI-FIRM VFI-VERY FIRM EFI-EXTREMELY FIRM	S-STICKY VS-VERY STICKY NP-NON-PLASTIC SP-SLIGHTLY STICKY P-PLASTIC VP-VERY PLASTIC
	III	SI-SILT- SIL-SILT LOAM CL-CLAY LOAM SCL-SANDY CLAY LOAM SICL-SILTY CLAY LOAM	0.6 - 0.3		
	IV	SIC-SILTY CLAY C-CLAY SC-SANDY CLAY	0.4 - 0.1		

STRUCTURE
 SG-SINGLE GRAIN
 M-MASSIVE
 CR-CRUMB
 GR-GRANULAR
 SBK-SUBANGULAR BLOCKY
 ABK-ANGULAR BLOCKY
 PL-PLATY
 PR-PRISMATIC

MINERALOGY
 SLIGHTLY EXPANSIVE
 EXPANSIVE

Show profile locations and other site features (dimensions, reference or benchmark, and North).




Jerry Hamilton Bu's
 Johnson Farm's Sub.
 Lot 2 Saddle Lane

* NEED TO MOVE
 Home ~~over~~ even
 with forest
 Home

* PLATE needs
 changing
 to FAN
 RECEPT
 SIDE

28" max

* NEED'S
 50' CLEAR
 OF AREA
 70' OF CLEAR



Saddle Lane

SITE PLAN APPROVAL

DISTRICT RA-30 USE SFD

#BEDROOMS 3

1-22-08 J.C. [Signature]
 Date Zoning Administrator

1" = 40' Scale