
ADDRESS . . : 106 BASKET OAK DR
CONTRACTOR : CAVINESS LAND DEVELOPMENT
OWNER . . . : WOODSHIRE PARTNERS LLC #112
PARCEL . . . : 01-0536-05- -0028- - -
APPL NUMBER: 08-50019286 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : LOT 112 FOREST OAKS SUB DIV
 HWY 27W TO NURSERY RD, NURSERY RD TO
 LEMUEL BLACK RD SUB DIV ON LEFT.
 T/S: 01/28/2008 09:16 AM VBROWN -----

SUBDIV: FOREST OAKS PH 3 99LOTS
PHONE : (919) 481-0503
PHONE :

STRUCTURE: 000 000 26X40 3BR 2.5BATH SLAB
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
P309 01	6/25/08	TI <i>AB JB</i>	R*PLUMB UNDER SLAB VRU #: 001631597

----- COMMENTS AND NOTES -----

PREPARED 6/27/08, 14:44:50
Harnett County

INSPECTION TICKET
INSPECTOR: IVR

PAGE 1
DATE 6/30/08

ADDRESS : 106 BASKET OAK DR SUBDIV: FOREST OAKS PH 3 99LOTS
CONTRACTOR : CAVINESS LAND DEVELOPMENT PHONE : (919) 481-0503
OWNER : WOODSHIRE PARTNERS LLC #112 PHONE :
PARCEL : 01-0536-05- -0028- - -
APPL NUMBER: 08-50019286 CP NEW RESIDENTIAL (SFD)

DIRECTIONS : LOT 112 FOREST OAKS SUB DIV
HWY 27W TO NURSERY RD, NURSERY RD TO
LEMUEL BLACK RD SUB DIV ON LEFT.
T/S: 01/28/2008 09:16 AM VBROWN ----

STRUCTURE: 000 000 26X40 3BR 2.5BATH SLAB
FLOOD ZONE . . . : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
P309 01	6/25/08 6/25/08	JH AP	R*PLUMB UNDER SLAB VRU #: 001631597
B111 01	6/30/08 <u>6/30/08</u>	TI <u>AR</u> <u>DI</u>	R*BLDG SLAB INSP TIME: 17:00 VRU #: 001634260

----- COMMENTS AND NOTES -----

ADDRESS . . : 106 BASKET OAK DR SUBDIV: FOREST OAKS PH 3 99LOTS
CONTRACTOR : CAVINESS LAND DEVELOPMENT PHONE : (919) 481-0503
OWNER . . : WOODSHIRE PARTNERS LLC #112 PHONE :
PARCEL . . : 01-0536-05- -0028- - -
APPL NUMBER: 08-50019286 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : LOT 112 FOREST OAKS SUB DIV
HWY 27W TO NURSERY RD, NURSERY RD TO
LEMUEL BLACK RD SUB DIV ON LEFT.
T/S: 01/28/2008 09:16 AM VBROWN -----

STRUCTURE: 000 000 26X40 3BR 2.5BATH SLAB
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
P309 01	6/25/08 6/25/08	JH AP	R*PLUMB UNDER SLAB VRU #: 001631597
B111 01	6/30/08 6/30/08	DT AP	R*BLDG SLAB INSP TIME: 17:00 VRU #: 001634260
A814 01	7/23/08	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001647114
R427 01	7/24/08 <i>7/24/08</i>	TI <i>DADD</i>	FOUR TRADE ROUGH IN >2500 VRU #: 001647965

----- COMMENTS AND NOTES -----

ADDRESS : 106 BASKET OAK DR
CONTRACTOR : CAVINESS LAND DEVELOPMENT
OWNER : WOODSHIRE PARTNERS LLC #112
PARCEL : 01-0536-05- -0028- - -
APPL NUMBER: 08-50019286 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : LOT 112 FOREST OAKS SUB DIV
HWY 27W TO NURSERY RD, NURSERY RD TO
LEMUEL BLACK RD SUB DIV ON LEFT.
T/S: 01/28/2008 09:16 AM VBROWN ----

SUBDIV: FOREST OAKS PH 3 99LOTS
PHONE : (919) 481-0503
PHONE :

STRUCTURE: 000 000 26X40 3BR 2.5BATH SLAB
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
P309 01	6/25/08	JH	R*PLUMB UNDER SLAB VRU #: 001631597
	6/25/08	AP	
B111 01	6/30/08	DT	R*BLDG SLAB INSP TIME: 17:00 VRU #: 001634260
	6/30/08	AP	
A814 01	7/23/08	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001647114
	7/25/08	AP	106 BASKET OAK DR LOT 112
R427 01	7/24/08	DT	FOUR TRADE ROUGH IN >2500 VRU #: 001647965
	7/24/08	DA	1. Need nail guard in back bedroom for electrical. 2. Need plumbing boots. 3. Need jack studs under girder truss and at rear of garage. 4. No gas pressure. Okay to side and insulat.e
R427 02	7/28/08	TI	FOUR TRADE ROUGH IN >2500 VRU #: 001649425

7/28/08 AP DT

----- COMMENTS AND NOTES -----

ADDRESS : 106 BASKET OAK DR SUBDIV: FOREST OAKS PH 3 99LOTS
CONTRACTOR : CAVINESS LAND DEVELOPMENT PHONE : (919) 481-0503
OWNER : WOODSHIRE PARTNERS LLC #112 PHONE :
PARCEL : 01-0536-05- -0028- - -
APPL NUMBER: 08-50019286 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : LOT 112 FOREST OAKS SUB DIV
HWY 27W TO NURSERY RD, NURSERY RD TO
LEMUEL BLACK RD SUB DIV ON LEFT.
T/S: 01/28/2008 09:16 AM VBROWN -----

STRUCTURE: 000 000 26X40 3BR 2.5BATH SLAB
FLOOD ZONE . . . : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
P309 01	6/25/08	JH	R*PLUMB UNDER SLAB VRU #: 001631597
	6/25/08	AP	
B111 01	6/30/08	DT	R*BLDG SLAB INSP TIME: 17:00 VRU #: 001634260
	6/30/08	AP	
A814 01	7/23/08	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001647114
	7/25/08	AP	106 BASKET OAK DR LOT 112
R427 01	7/24/08	DT	FOUR TRADE ROUGH IN >2500 VRU #: 001647965
	7/24/08	DA	1. Need nail guard in back bedroom for electrical. 2. Need plumbing boots. 3. Need jack studs under girder truss and at rear of garage. 4. No gas pressure. Okay to side and insulat.e
R427 02	7/28/08	DT	FOUR TRADE ROUGH IN >2500 VRU #: 001649425
	7/28/08	AP	
I129 01	7/30/08	TI	R*INSULATION INSPECTION VRU #: 001651884

AP JH

----- COMMENTS AND NOTES -----

ADDRESS : 106 BASKET OAK DR
CONTRACTOR : CAVINESS LAND DEVELOPMENT
OWNER : WOODSHIRE PARTNERS LLC #112
PARCEL : 01-0536-05- -0028- - -
APPL NUMBER: 08-50019286 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : LOT 112 FOREST OAKS SUB DIV
HWY 27W TO NURSERY RD, NURSERY RD TO
LEMUEL BLACK RD SUB DIV ON LEFT.
T/S: 01/28/2008 09:16 AM VBROWN ----

SUBDIV: FOREST OAKS PH 3 99LOTS
PHONE : (919) 481-0503
PHONE :

STRUCTURE: 000 000 26X40 3BR 2.5BATH SLAB

FLOOD ZONE : FLOOD ZONE X

BEDROOMS : 3.00

PROPOSED USE : SFD

SEPTIC - EXISTING? : NEW

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
P309 01	6/25/08	JH	R*PLUMB UNDER SLAB VRU #: 001631597
	6/25/08	AP	
B111 01	6/30/08	DT	R*BLDG SLAB INSP TIME: 17:00 VRU #: 001634260
	6/30/08	AP	
A814 01	7/23/08	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001647114
	7/25/08	AP	106 BASKET OAK DR LOT 112
R427 01	7/24/08	DT	FOUR TRADE ROUGH IN >2500 VRU #: 001647965
	7/24/08	DA	1. Need nail guard in back bedroom for electrical. 2. Need plumbing boots. 3. Need jack studs under girder truss and at rear of garage. 4. No gas pressure.
R427 02	7/28/08	DT	Okay to side and insulat.e
	7/28/08	AP	FOUR TRADE ROUGH IN >2500 VRU #: 001649425
I129 01	7/30/08	JH	R*INSULATION INSPECTION VRU #: 001651884
	7/30/08	AP	
H824 01	8/29/08	JW	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001670546
	8/29/08	AP	
R429 01	10/14/08	TI	FOUR TRADE FINAL VRU #: 001691609

DP-MR

COMMENTS AND NOTES

Grade too high around house

ADDRESS : 106 BASKET OAK DR
 CONTRACTOR : CAVINESS LAND DEVELOPMENT
 OWNER : WOODSHIRE PARTNERS LLC #112
 PARCEL : 01-0536-05- -0028- - -
 APPL NUMBER: 08-50019286 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : LOT 112 FOREST OAKS SUB DIV
 HWY 27W TO NURSERY RD, NURSERY RD TO
 LEMUEL BLACK RD SUB DIV ON LEFT.
 T/S: 01/28/2008 09:16 AM VBROWN ----

SUBDIV: FOREST OAKS PH 3 99LOTS
 PHONE : (919) 481-0503
 PHONE :

STRUCTURE: 000 000 26X40 3BR 2.5BATH SLAB

FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
P309 01	6/25/08	JH	R*PLUMB UNDER SLAB VRU #: 001631597
	6/25/08	AP	
B111 01	6/30/08	DT	R*BLDG SLAB INSP TIME: 17:00 VRU #: 001634260
	6/30/08	AP	
A814 01	7/23/08	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001647114
	7/25/08	AP	✓106 BASKET OAK DR LOT 112
R427 01	7/24/08	DT	FOUR TRADE ROUGH IN >2500 VRU #: 001647965
	7/24/08	DA	1. Need nail guard in back bedroom for electrical. 2. Need plumbing boots. 3. Need jack studs under girder truss and at rear of garage. 4. No gas pressure. Okay to side and insulat.e
R427 02	7/28/08	DT	FOUR TRADE ROUGH IN >2500 VRU #: 001649425
	7/28/08	AP	
I129 01	7/30/08	JH	R*INSULATION INSPECTION VRU #: 001651884
	7/30/08	AP	
H824 01	8/29/08	JW	✓ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001670546
	8/29/08	AP	
R429 01	10/14/08	MR	FOUR TRADE FINAL VRU #: 001691609
	10/14/08	DP	grade too close to sheathing
R429 02	10/15/08	TI	FOUR TRADE FINAL VRU #: 001692151

AP JH

COMMENTS AND NOTES

**COUNTY OF HARNETT
DEPARTMENT OF BUILDING INSPECTION
AND PLANNING/DEVELOPMENT
CERTIFICATE OF OCCUPANCY**

This certificate issued pursuant to the requirements of Section 105 of the North Carolina State Building Code and the Harnett County Zoning Ordinance certifies at the time of issuance this structure was in compliance with the various ordinances of the County of Harnett regulating development and building construction or use. For the following:

Use Classification: SFD

PERMIT NUMBERS

Owner: Caviness Land Development

Building Permit No.: _____

911 Address: 106 Basket oak dr

Electrical Permit No.: _____

Insulation Permit No.: _____

Plumbing Permit No.: _____

State: _____ Zip Code: _____

Mech. Permit No.: _____

MFG. Home: _____

Date: 10-15-08

James T. Hall
Building Official

of 501928