

HTE# 08-500-19290

Harnett County Department of Public Health 24496

Improvement Permit

A building permit cannot be issued with only an Improvement Permit

ISSUED TO CAUNESS Land PROPERTY LOCATION: 1125 SUBDIVISION FOREST OAKS LOT # 114
NEW [X] REPAIR [] EXPANSION []
Type of Structure: SFD-48x48 YBR
Proposed Wastewater System Type: Pump to 25% Red. Sys.
Projected Daily Flow: 480 GPD
Number of bedrooms: 4 Number of Occupants: 8 max
Basement [] Yes [X] No
Pump Required: [X] Yes [] No [] May be required based on final location and elevations of facilities
Type of Water Supply: [] Community [X] Public [] Well Distance from well 50 feet
Permit conditions: Meet on site for final layout keep tank at least 50' from any surface waters

Authorized State Agent: J. W. [Signature] Date: 02-26-08 SEE ATTACHED SITE SKETCH
The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.

Construction Authorization

(Required for Building Permit)

The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout.

ISSUED TO: CAUNESS Land PROPERTY LOCATION: 1125 SUBDIVISION FOREST OAKS LOT # 114
Facility Type: SFD-48x48 YBR [X] New [] Expansion [] Repair
Basement? [] Yes [X] No Basement Fixtures? [] Yes [X] No
Type of Wastewater System** Pump to 25% Red. Sys. (Initial) Wastewater Flow: 480 GPD
(See note below, if applicable [X]) LEP (Repair)

Installation Requirements/Conditions

Septic Tank Size 1000 gallons Exact length of each trench 1824 feet Trench Spacing: 9 Feet on Center
Pump Tank Size 1000 gallons Trenches shall be installed on contour at a Soil Cover: 6 inches
Maximum Trench Depth of: 1824 inches (Maximum soil cover shall not exceed 36" above the trench bottom)
Pump Requirements: _____ ft. TDH vs. _____ GPM _____ inches below pipe
Aggregate Depth: _____ inches above pipe
Conditions: _____ inches total

**If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.
Owner/Legal Representative Signature: _____ Date: _____

This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit.
Authorized State Agent: J. W. [Signature] Date: 02-26-08 SEE ATTACHED SITE SKETCH
Construction Authorization Expiration Date: 02-26-2013

HTE# 08-520-19290

Permit # 24496

Harnett County Department of Public Health Site Sketch

ISSUED TO: Cannon Land

PROPERTY LOCATOR: 1125

SUBDIVISION: FOREST OAKS

LOT # 11C

Authorized State Agent: J. L. [Signature]

Date: 2-26-08

Meet DRPH
 maintain all set DRPHs
 keep tanks 50' from any surface water
 Install 12x4x9 85% reduction system at 18ft. 24" deep.

