

ADDRESS : 147 BASKET OAK DR
CONTRACTOR : CAVINESS LAND DEVELOPMENT
OWNER : WOODSHIRE PARTNERS LLC #147
PARCEL : 01-0536-05- -0028- -34-
APPL NUMBER: 08-50019294 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : FOREST OAKS #147
HWY 27W TO NURSERY RD, LEMUEL RD, SUB
DIV ON LEFT.
T/S: 01/28/2008 09:45 AM VBROWN ----

SUBDIV: FOREST OAKS PH 3 99LOTS
PHONE : (919) 481-0503
PHONE :

STRUCTURE: 000 000 42X38 SFD 3BDR 3BATH WITH GARAGE SLAB

FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3.00
SEPTIC - EXISTING? : NEW
PROPOSED USE : SFD
WATER SUPPLY : UNKNOWN

PERMIT: CPSF 01 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
P309 01	11/04/08 <i>11/4/08</i>	TI <i>AP DI</i>	R*PLUMB UNDER SLAB VRU #: 001700939

COMMENTS AND NOTES

ADDRESS : 147 BASKET OAK DR
CONTRACTOR : CAVINESS LAND DEVELOPMENT
OWNER : WOODSHIRE PARTNERS LLC #147
PARCEL : 01-0536-05- -0028- -34-
APPL NUMBER: 08-50019294 CP NEW RESIDENTIAL (SFD)

SUBDIV: FOREST OAKS PH 3 99LOTS
PHONE : (919) 481-0503
PHONE :

DIRECTIONS : FOREST OAKS #147
HWY 27W TO NURSERY RD, LEMUEL RD, SUB
DIV ON LEFT.
T/S: 01/28/2008 09:45 AM VBROWN ----

STRUCTURE: 000 000 42X38 SFD 3BDR 3BATH WITH GARAGE SLAB

FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3.00 PROPOSED USE : SFD
SEPTIC - EXISTING? : NEW WATER SUPPLY : UNKNOWN

PERMIT: CPSF 01 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
P309 01	11/04/08	DT	R*PLUMB UNDER SLAB VRU #: 001700939
	11/04/08	AP	
B111 01	11/10/08	TI	R*BLDG SLAB INSP VRU #: 001703198
	<i>11/10/08</i>	<i>AS DT</i>	

----- COMMENTS AND NOTES -----

ADDRESS : 147 BASKET OAK DR
CONTRACTOR : CAVINESS LAND DEVELOPMENT
OWNER : WOODSHIRE PARTNERS LLC #147
PARCEL : 01-0536-05- -0028- -34-
APPL NUMBER: 08-50019294 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : FOREST OAKS #147
HWY 27W TO NURSERY RD, LEMUEL RD, SUB
DIV ON LEFT.
T/S: 01/28/2008 09:45 AM VBROWN ----

SUBDIV: FOREST OAKS PH 3 99LOTS
PHONE : (919) 481-0503
PHONE :

STRUCTURE: 000 000 42X38 SFD 3BDR 3BATH WITH GARAGE SLAB

FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3.00 PROPOSED USE : SFD
SEPTIC - EXISTING? : NEW WATER SUPPLY : UNKNOWN

PERMIT: CPSF 01 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
P309 01	11/04/08	DT	R*PLUMB UNDER SLAB VRU #: 001700939
	11/04/08	AP	
B111 01	11/10/08	DT	R*BLDG SLAB INSP VRU #: 001703198
	11/10/08	AP	
A814 01	12/11/08	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001715903
R425 01	12/11/08	TI	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 001715895

DA JH

----- COMMENTS AND NOTES -----

ADDRESS : 147 BASKET OAK DR
 CONTRACTOR : CAVINESS LAND DEVELOPMENT
 OWNER : WOODSHIRE PARTNERS LLC #147
 PARCEL : 01-0536-05- -0028- -34-
 APPL NUMBER: 08-50019294 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : FOREST OAKS #147
 HWY 27W TO NURSERY RD, LEMUEL RD, SUB
 DIV ON LEFT.
 T/S: 01/28/2008 09:45 AM VBROWN ----

SUBDIV: FOREST OAKS PH 3 99LOTS
 PHONE : (919) 481-0503
 PHONE :

STRUCTURE: 000 000 42X38 SFD 3BDR 3BATH WITH GARAGE SLAB

FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW WATER SUPPLY : UNKNOWN

PERMIT: CPSF 01 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
P309 01	11/04/08	DT	R*PLUMB UNDER SLAB VRU #: 001700939
	11/04/08	AP	
B111 01	11/10/08	DT	R*BLDG SLAB INSP VRU #: 001703198
	11/10/08	AP	
A814 01	12/11/08	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001715903
	12/12/08	AP	147 BASKET OAK DR LOT 147
R425 01	12/11/08	JH	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 001715895
	12/11/08	DA	1)Missing house wrap on garge wall. 2)Leak in kitchen under spare bath upstiaars on drain line. 3)Missing receptacle to left of laundry room door & on back of house. 4)Check headroom in stairs it is 6'8" @ roughin without sheetrock & flooring. 5)Smoke detector in hall upstairs needs to be 3' from return. 6)Missing stud to right of spare bath door. 7)Missing nail guards throughout house on wires within 1 1/4" of the edge of top plates.
R425 02	12/15/08	TI	FOUR TRADE ROUGH IN VRU #: 001716860

2/15/08 AP DT

COMMENTS AND NOTES

ADDRESS : 147 BASKET OAK DR SUBDIV: FOREST OAKS PH 3 99LOTS
 CONTRACTOR: CAVINESS LAND DEVELOPMENT PHONE : (919) 481-0503
 OWNER : WOODSHIRE PARTNERS LLC #147 PHONE :
 PARCEL : 01-0536-05- -0028- -34-
 APPL NUMBER: 08-50019294 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : FOREST OAKS #147
 HWY 27W TO NURSERY RD, LEMUEL RD, SUB
 DIV ON LEFT.
 T/S: 01/28/2008 09:45 AM VBROWN ----

STRUCTURE: 000 000 42X38 SFD 3BDR 3BATH WITH GARAGE SLAB
 FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW WATER SUPPLY : UNKNOWN

PERMIT: CPSF 01 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
P309 01	11/04/08	DT	R*PLUMB UNDER SLAB VRU #: 001700939
	11/04/08	AP	
B111 01	11/10/08	DT	R*BLDG SLAB INSP VRU #: 001703198
	11/10/08	AP	
A814 01	12/11/08	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001715903
	12/12/08	AP	147 BASKET OAK DR LOT 147
R425 01	12/11/08	JH	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 001715895
	12/11/08	DA	1)Missing house wrap on garge wall. 2)Leak in kitchen under spare bath upstiaars on drain line. 3)Missing receptacle to left of laundry room door & on back of house. 4)Check headroom in stairs it is 6'8" @ roughin without sheetrock & flooring. 5)Smoke detector in hall upstairs needs to be 3' from return. 6)Missing stud to right of spare bath door. 7)Missing nail guards throughout house on wires within 1 1/4" of the edge of top plates.
R425 02	12/15/08	DT	FOUR TRADE ROUGH IN VRU #: 001716860
	12/15/08	AP	
I129 01	12/17/08	TI	R*INSULATION INSPECTION VRU #: 001717832

DA-MR

COMMENTS AND NOTES

HARNETT COUNTY

Building Inspections Dept.

108 E. Front St.

Lillington, NC 27546

910-893-7525

DO NOT REMOVE

DATE:12/17/08

PERMIT# 08-50019294

ADDRESS: 147 basket oak

VIOLATIONS:

1. Water pipes must be insulated or within the insulation envelope

Harnett County Building Department

Mike Rearic cell# (910) 984- 4772

ADDRESS : 147 BASKET OAK DR
CONTRACTOR : CAVINESS LAND DEVELOPMENT
OWNER : WOODSHIRE PARTNERS LLC #147
PARCEL : 01-0536-05- -0028- -34-
APPL NUMBER: 08-50019294 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : FOREST OAKS #147
HWY 27W TO NURSERY RD, LEMUEL RD, SUB
DIV ON LEFT.
T/S: 01/28/2008 09:45 AM VBROWN ----

SUBDIV: FOREST OAKS PH 3 99LOTS
PHONE : (919) 481-0503
PHONE :

STRUCTURE: 000 000 42X38 SFD 3BDR 3BATH WITH GARAGE SLAB

FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3.00 PROPOSED USE : SFD
SEPTIC - EXISTING? : NEW WATER SUPPLY : UNKNOWN

PERMIT: CPSF 01 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
P309 01	11/04/08	DT	R*PLUMB UNDER SLAB VRU #: 001700939
	11/04/08	AP	
B111 01	11/10/08	DT	R*BLDG SLAB INSP VRU #: 001703198
	11/10/08	AP	
A814 01	12/11/08	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001715903
	12/12/08	AP	147 BASKET OAK DR LOT 147
R425 01	12/11/08	JH	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 001715895
	12/11/08	DA	1)Missing house wrap on garge wall. 2)Leak in kitchen under spare bath upstiars on drain line. 3)Missing receptacle to left of laundry room door & on back of house. 4)Check headroom in stairs it is 6'8" @ roughin without sheetrock & flooring. 5)Smoke detector in hall upstairs needs to be 3' from return. 6)Missing stud to right of spare bath door. 7)Missing nail guards throughout house on wires within 1 1/4" of the edge of top plates.
R425 02	12/15/08	DT	FOUR TRADE ROUGH IN VRU #: 001716860
	12/15/08	AP	
I129 01	12/17/08	MR	R*INSULATION INSPECTION VRU #: 001717832
	12/17/08	DA	1. pipes not insulated
I129 02	12/18/08	TI	R*INSULATION INSPECTION VRU #: 001718788

AP-VR

COMMENTS AND NOTES

ADDRESS : 147 BASKET OAK DR SUBDIV: FOREST OAKS PH 3 99LOTS
CONTRACTOR : CAVINESS LAND DEVELOPMENT PHONE : (919) 481-0503
OWNER : WOODSHIRE PARTNERS LLC #147 PHONE :
PARCEL : 01-0536-05- -0028- -34-
APPL NUMBER: 08-50019294 CP NEW RESIDENTIAL (SFD)

DIRECTIONS : FOREST OAKS #147
HWY 27W TO NURSERY RD, LEMUEL RD, SUB
DIV ON LEFT.
T/S: 01/28/2008 09:45 AM VBROWN ----

STRUCTURE: 000 000 42X38 SFD 3BDR 3BATH WITH GARAGE SLAB
FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3.00 PROPOSED USE : SFD
SEPTIC - EXISTING? : NEW WATER SUPPLY : UNKNOWN

PERMIT: CPSF 01 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
P309 01	11/04/08	DT	R*PLUMB UNDER SLAB VRU #: 001700939
	11/04/08	AP	
B111 01	11/10/08	DT	R*BLDG SLAB INSP VRU #: 001703198
	11/10/08	AP	
A814 01	12/11/08	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001715903
	12/12/08	AP	✓ 147 BASKET OAK DR LOT 147
R425 01	12/11/08	JH	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 001715895
	12/11/08	DA	1)Missing house wrap on garge wall. 2)Leak in kitchen under spare bath upstiaars on drain line. 3)Missing receptacle to left of laundry room door & on back of house. 4)Check headroom in stairs it is 6'8" @ roughin without sheetrock & flooring. 5)Smoke detector in hall upstairs needs to be 3' from return. 6)Missing stud to right of spare bath door. 7)Missing nail guards throughout house on wires within 1 1/4" of the edge of top plates.
R425 02	12/15/08	DT	FOUR TRADE ROUGH IN VRU #: 001716860
	12/15/08	AP	
I129 01	12/17/08	MR	R*INSULATION INSPECTION VRU #: 001717832
	12/17/08	DA	1. pipes not insulated
I129 02	12/18/08	MR	R*INSULATION INSPECTION VRU #: 001718788
	12/18/08	AP	
H824 01	2/24/09	JW	✓ ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001738376
	2/24/09	AP	
R429 01	3/13/09	TI	FOUR TRADE FINAL VRU #: 001743331

3-13-9 AP-MR

COMMENTS AND NOTES

NO Dishwasher

**COUNTY OF HARNETT
DEPARTMENT OF BUILDING INSPECTION
AND PLANNING/DEVELOPMENT
CERTIFICATE OF OCCUPANCY**

This certificate issued pursuant to the requirements of Section 105 of the North Carolina State Building Code and the Harnett County Zoning Ordinance certifies at the time of issuance this structure was in compliance with the various ordinances of the County of Harnett regulating development and building construction or use. For the following:

Use Classification: R-3

Conditional Use Permit No.: _____

Type of Construction: I

Building Permit No.: 08-50019294

Owner of Building: Woodshire Partners

Electrical Permit No.: 11

Building Address: 147 Basket Oak

Insulation Permit No.: 11

Zoning District: _____

Plumbing Permit No.: 11

Zoning Permit No.: _____

Mech. Permit No.: 11

Date: 3-13-9

Envir. C.O. No.: _____

T. Michael Reavis

Building Official

Zoning Official