

Improvement Permit

A building permit cannot be issued with only an Improvement Permit

ISSUED TO: CAVINNESS Land Dev. PROPERTY LOCATION: 1125 SUBDIVISION: FOREST OAKS LOT # 147
NEW [X] REPAIR [ ] EXPANSION [ ]
Type of Structure: SFD - 42x38 - 3BR max
Proposed Wastewater System Type: Pump to 2' wide chamber
Projected Daily Flow: 360 max GPD
Number of bedrooms: 3 max Number of Occupants: 6 max
Basement [ ] Yes [X] No
Pump Required: [X] Yes [ ] No [ ] May be required based on final location and elevations of facilities
Type of Water Supply: [ ] Community [X] Public [ ] Well Distance from well 100 feet Permit valid for: [X] Five years [ ] No expiration
Permit conditions: Meet on site for Final Layout maintain All set Backs
MUI? Being in 8 to 12" of Approved Cover

Authorized State Agent: [Signature] Date: 10-17-08 SEE ATTACHED SITE SKETCH
The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.

Construction Authorization

(Required for Building Permit)

The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout.

ISSUED TO: CAVINNESS Land Dev. PROPERTY LOCATION: 1125 SUBDIVISION: FOREST OAKS LOT # 147
Facility Type: SFD - 42x38 - 3BR max [X] New [ ] Expansion [ ] Repair
Basement? [ ] Yes [X] No Basement Fixtures? [ ] Yes [X] No
Type of Wastewater System\*\* Pump to 2' wide chamber (Initial) Wastewater Flow: 360 max GPD
(See note below, if applicable [X]) Panel Blocks (Repair)

Installation Requirements/Conditions
Septic Tank Size 1000 gallons Number of trenches 1
Pump Tank Size 1000 gallons Exact length of each trench 300 feet Trench Spacing: 7' Feet on Center
Trenches shall be installed on contour at a Soil Cover: 6 inches
Maximum Trench Depth of: 12 inches (Maximum soil cover shall not exceed 36" above the trench bottom)
in all directions
Pump Requirements: \_\_\_\_\_ ft. TDH vs. \_\_\_\_\_ GPM \_\_\_\_\_ inches below pipe
Aggregate Depth: \_\_\_\_\_ inches above pipe
Conditions: \_\_\_\_\_ inches total

\*\*If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.
Owner/Legal Representative Signature: \_\_\_\_\_ Date: \_\_\_\_\_

This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit. SEE ATTACHED SITE SKETCH
Authorized State Agent: [Signature] Date: 10-17-08
Construction Authorization Expiration Date: 10-17-2013

HTE# 08-530-19294RRR


Permit # 25084

# Harnett County Department of Public Health Site Sketch

ISSUED TO: Cauhess Land Dev. PROPERTY LOCATOR: 1125  
SUBDIVISION: FOREST OAKS LOT # LY7

Authorized State Agent: Ju Waters Date: 10-17-08

101



Meet onsite for Final layout  
 maintain All set Backs,  
 Install 300' x 2' wide  
 chambers at 12" Deep  
 Must Bring in 8 to 12"  
 of Approved cover soil

Road 101