

ADDRESS : 125 BASKET OAK DR
CONTRACTOR : CAVINESS LAND DEVELOPMENT
OWNER : WOODSHIRE PARTNERS LLC #148
PARCEL : 01-0536-05- -0028- -35-
APPL NUMBER: 08-50019295 CP NEW RESIDENTIAL (SFD)

SUBDIV: FOREST OAKS PH 3 99LOTS
PHONE : (919) 481-0503
PHONE :

DIRECTIONS : FOREST OAKS #148
HWY 27W TO NURSERY RD, LEMUEL BLACK RD,
SUB DIV ON LEFT.
T/S: 01/28/2008 09:49 AM VBROWN ----

STRUCTURE: 000 000 39.92X22 3BDR 2BATH / GARAGE NODECK SLAB

FLOOD ZONE : FLOOD ZONE X

BEDROOMS : 3.00

PROPOSED USE : SFD

SEPTIC - EXISTING? : NEW

WATER SUPPLY : UNKNOWN

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED	INSP	DESCRIPTION
	COMPLETED	RESULT	RESULTS/COMMENTS
P309 01	11/03/08	TI	R*PLUMB UNDER SLAB VRU #: 001700517

AP-MR

COMMENTS AND NOTES

ADDRESS . . : 125 BASKET OAK DR SUBDIV: FOREST OAKS PH 3 99LOTS
CONTRACTOR : CAVINESS LAND DEVELOPMENT PHONE : (919) 481-0503
OWNER . . . : WOODSHIRE PARTNERS LLC #148 PHONE :
PARCEL . . . : 01-0536-05- -0028- -35-
APPL NUMBER: 08-50019295 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : FOREST OAKS #148
HWY 27W TO NURSERY RD, LEMUEL BLACK RD,
SUB DIV ON LEFT.
T/S: 01/28/2008 09:49 AM VBROWN -----

STRUCTURE: 000 000 39.92X22 3BDR 2BATH / GARAGE NODECK SLAB
FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3.00 PROPOSED USE : SFD
SEPTIC - EXISTING? : NEW WATER SUPPLY : UNKNOWN

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
P309 01	11/03/08	MR	R*PLUMB UNDER SLAB VRU #: 001700517
	11/03/08	AP	
B101 01	11/07/08 <i>11/7/08</i>	TI <i>AP DT</i>	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001702836 monolithic slab

----- COMMENTS AND NOTES -----

ADDRESS . . : 125 BASKET OAK DR SUBDIV: FOREST OAKS PH 3 99LOTS
 CONTRACTOR : CAVINESS LAND DEVELOPMENT PHONE : (919) 481-0503
 OWNER . . . : WOODSHIRE PARTNERS LLC #148 PHONE :
 PARCEL . . . : 01-0536-05- -0028- -35-
 APPL NUMBER: 08-50019295 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : FOREST OAKS #148
 HWY 27W TO NURSERY RD, LEMUEL BLACK RD,
 SUB DIV ON LEFT.
 T/S: 01/28/2008 09:49 AM VBROWN -----

STRUCTURE: 000 000 39.92X22 3BDR 2BATH / GARAGE NODECK SLAB
 FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW WATER SUPPLY : UNKNOWN

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
P309 01	11/03/08 11/03/08	MR AP	R*PLUMB UNDER SLAB VRU #: 001700517
B101 01	11/07/08 11/07/08	DT AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001702836 monolithic slab
A814 01	11/20/08 11/17/08	TI AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001705818 125 basket oak dr lot 148
R427 01	12/15/08	TI	FOUR TRADE ROUGH IN >2500 VRU #: 001716901

12/15/08 DA DT

----- COMMENTS AND NOTES -----

ADDRESS : 125 BASKET OAK DR SUBDIV: FOREST OAKS PH 3 99LOTS
 CONTRACTOR : CAVINESS LAND DEVELOPMENT PHONE : (919) 481-0503
 OWNER : WOODSHIRE PARTNERS LLC #148 PHONE :
 PARCEL : 01-0536-05- -0028- -35-
 APPL NUMBER: 08-50019295 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : FOREST OAKS #148
 HWY 27W TO NURSERY RD, LEMUEL BLACK RD,
 SUB DIV ON LEFT.
 T/S: 01/28/2008 09:49 AM VBROWN -----

STRUCTURE: 000 000 39.92X22 3BDR 2BATH / GARAGE NODECK SLAB
 FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW WATER SUPPLY : UNKNOWN

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
P309 01	11/03/08 11/03/08	MR AP	R*PLUMB UNDER SLAB VRU #: 001700517
B101 01	11/07/08 11/07/08	DT AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001702836 monolithic slab
A814 01	11/20/08 11/17/08	TI AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001705818 125 basket oak dr lot 148
R427 01	12/15/08 12/15/08	DT DA	FOUR TRADE ROUGH IN >2500 VRU #: 001716901 1. Jack studs missing in garage and at rear of first story. 2. Fire caulk missing or insufficient for plumbing on first floor. 3. Need plumbing boots. 4. Wall cavity by spare tub/shower for plumbing vent must be fire blocked at top. 5. Watch headroom for stairs at final. Okay to side and insulate.
R425 01	12/17/08	TI	FOUR TRADE ROUGH IN VRU #: 001717883

DP-MR

----- COMMENTS AND NOTES -----

ADDRESS : 125 BASKET OAK DR SUBDIV: FOREST OAKS PH 3 99LOTS
 CONTRACTOR : CAVINESS LAND DEVELOPMENT PHONE : (919) 481-0503
 OWNER : WOODSHIRE PARTNERS LLC #148 PHONE :
 PARCEL : 01-0536-05- -0028- -35-
 APPL NUMBER: 08-50019295 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : FOREST OAKS #148
 HWY 27W TO NURSERY RD, LEMUEL BLACK RD,
 SUB DIV ON LEFT.
 T/S: 01/28/2008 09:49 AM VBROWN ----

STRUCTURE: 000 000 39.92X22 3BDR 2BATH / GARAGE NODECK SLAB
 FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW WATER SUPPLY : UNKNOWN

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
P309 01	11/03/08 11/03/08	MR AP	R*PLUMB UNDER SLAB VRU #: 001700517
B101 01	11/07/08 11/07/08	DT AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001702836 monolithic slab
A814 01	11/20/08 11/17/08	TI AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001705818 125 basket oak dr lot 148
R427 01	12/15/08 12/15/08	DT DA	FOUR TRADE ROUGH IN >2500 VRU #: 001716901 1. Jack studs missing in garage and at rear of first story. 2. Fire caulk missing or insufficient for plumbing on first floor. 3. Need plumbing boots. 4. Wall cavity by spare tub/shower for plumbing vent must befire blocked at top. 5. Watch headroom for stairs at final. Okay to side and insulate.
R425 01	12/17/08 12/17/08	MR DP	FOUR TRADE ROUGH IN VRU #: 001717883 1. previous items not repaired. pipes not insulated
I129 01	12/18/08	TI	R*INSULATION INSPECTION VRU #: 001718816
R425 02	12/18/08	TI	FOUR TRADE ROUGH IN VRU #: 001718808

COMMENTS AND NOTES

ADDRESS : 125 BASKET OAK DR SUBDIV: FOREST OAKS PH 3 99LOTS
 CONTRACTOR : CAVINESS LAND DEVELOPMENT PHONE : (919) 481-0503
 OWNER : WOODSHIRE PARTNERS LLC #148 PHONE :
 PARCEL : 01-0536-05- -0028- -35-
 APPL NUMBER: 08-50019295 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : FOREST OAKS #148
 HWY 27W TO NURSERY RD, LEMUEL BLACK RD,
 SUB DIV ON LEFT.
 T/S: 01/28/2008 09:49 AM VBROWN ----

STRUCTURE: 000 000 39.92X22 3BDR 2BATH / GARAGE NODECK SLAB

FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW WATER SUPPLY : UNKNOWN

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
P309 01	11/03/08	MR	R*PLUMB UNDER SLAB VRU #: 001700517
	11/03/08	AP	
B101 01	11/07/08	DT	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001702836
	11/07/08	AP	monolithic slab
A814 01	11/20/08	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001705818
	11/17/08	AP	125 basket oak dr lot 148
R427 01	12/15/08	DT	FOUR TRADE ROUGH IN >2500 VRU #: 001716901
	12/15/08	DA	1. Jack studs missing in garage and at rear of first story. 2. Fire caulk missing or insufficient for plumbing on first floor. 3. Need plumbing boots. 4. Wall cavity by spare tub/shower for plumbing vent must be before blocked at top. 5. Watch headroom for stairs at final. Okay to side and insulate.
R425 01	12/17/08	MR	FOUR TRADE ROUGH IN VRU #: 001717883
	12/17/08	DP	1. previous items not repaired. pipes not insulated
I129 01	12/18/08	MR	R*INSULATION INSPECTION VRU #: 001718816
	12/18/08	AP	
R425 02	12/18/08	MR	FOUR TRADE ROUGH IN VRU #: 001718808
	12/18/08	AP	
R429 01	2/24/09	TI	FOUR TRADE FINAL VRU #: 001737482
	2/23/09	CA	CANCELLED FINAL INSPECTION. (02/23/09) NO OPERATIONS PERMIT*****
H824 01	2/25/09	JW	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001738863
	2/25/09	AP	
R429 02	2/26/09	TI	FOUR TRADE FINAL VRU #: 001738267
	2/25/09	CA	CANCELLED FINAL INSPECTION. 02/25/09 NO OPERATIONS PERMIT.
R429 03	3/02/09	TI	FOUR TRADE FINAL VRU #: 001739218
	<u>3/2/09</u>	<u>DA DT</u>	

COMMENTS AND NOTES

ADDRESS : 125 BASKET OAK DR
 CONTRACTOR : CAVINESS LAND DEVELOPMENT
 OWNER : WOODSHIRE PARTNERS LLC #148
 PARCEL : 01-0536-05- -0028- -35-
 APPL NUMBER: 08-50019295 CP NEW RESIDENTIAL (SFD)

SUBDIV: FOREST OAKS PH 3 99LOTS
 PHONE : (919) 481-0503
 PHONE :

DIRECTIONS : FOREST OAKS #148
 HWY 27W TO NURSERY RD, LEMUEL BLACK RD,
 SUB DIV ON LEFT.
 T/S: 01/28/2008 09:49 AM VBROWN ----

STRUCTURE: 000 000 39.92X22 3BDR 2BATH / GARAGE NODECK SLAB
 FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW WATER SUPPLY : UNKNOWN

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
P309 01	11/03/08	MR	R*PLUMB UNDER SLAB VRU #: 001700517
	11/03/08	AP	
B101 01	11/07/08	DT	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001702836
	11/07/08	AP	monolithic slab
A814 01	11/20/08	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001705818
	11/17/08	AP	✓ 125 basket oak dr lot 148
R427 01	12/15/08	DT	FOUR TRADE ROUGH IN >2500 VRU #: 001716901
	12/15/08	DA	1. Jack studs missing in garage and at rear of first story. 2. Fire caulk missing or insufficient for plumbing on first floor. 3. Need plumbing boots. 4. Wall cavity by spare tub/shower for plumbing vent must befire blocked at top. 5. Watch headroom for stairs at final. Okay to side and insulate.
R425 01	12/17/08	MR	FOUR TRADE ROUGH IN VRU #: 001717883
	12/17/08	DP	1. previous items not repaired. pipes not insulated
I129 01	12/18/08	MR	R*INSULATION INSPECTION VRU #: 001718816
	12/18/08	AP	
R425 02	12/18/08	MR	FOUR TRADE ROUGH IN VRU #: 001718808
	12/18/08	AP	
R429 01	2/24/09	TI	FOUR TRADE FINAL VRU #: 001737482
	2/23/09	CA	CANCELLED FINAL INSPECTION. (02/23/09) NO OPERATIONS PERMIT*****
H824 01	2/25/09	JW	✓ ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001738863
	2/25/09	AP	
R429 02	2/26/09	TI	FOUR TRADE FINAL VRU #: 001738267
	2/25/09	CA	CANCELLED FINAL INSPECTION. 02/25/09 NO OPERATIONS PERMIT.
R429 03	3/02/09	DT	FOUR TRADE FINAL VRU #: 001739218
	3/02/09	DA	1. Need paperwork for air handler breakers. 2. Do not have 80 inched head clearance in stairway.
R429 04	3/30/09	TI	FOUR TRADE FINAL VRU #: 001748826

3-30-9 AP-MR

COUNTY OF HARNETT
DEPARTMENT OF BUILDING INSPECTION
AND PLANNING/DEVELOPMENT
CERTIFICATE OF OCCUPANCY

This certificate issued pursuant to the requirements of Section 105 of the North Carolina State Building Code and the Harnett County Zoning Ordinance certifies at the time of issuance this structure was in compliance with the various ordinances of the County of Harnett regulating development and building construction or use. For the following:

Use Classification: R-3

Owner: Woodshire Partners

911 Address: _____

125 Basket Oak

State: NC Zip Code: _____

Date: _____

T. Michael Reamie

Building Official

PERMIT NUMBERS

Building Permit No.: 08-50019295

Electrical Permit No.: ''

Insulation Permit No.: ''

Plumbing Permit No.: ''

Mech. Permit No.: ''

MFG. Home: _____