

PREPARED 9/15/08, 14:02:54
Harnett County

INSPECTION TICKET
INSPECTOR: IVR

PAGE 7
DATE 9/16/08

ADDRESS : 44 ORANGEWOOD CT SUBDIV: WOODSHIRE PH 5
CONTRACTOR : DUSTIN BLACKWELL, INC PHONE : (919) 606-4696
OWNER : BLACKWELL HOMES #208 PHONE : (919) 606-4596
PARCEL : 01-0536-06- -0028- -48-
APPL NUMBER: 08-50019305 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : WOODSHIRE #208
HWY 27W TO NURSERY RD, LEMUEL BLACK RD,
SUB DIV ON LEFT.
T/S: 01/28/2008 11:42 AM VBROWN ----

STRUCTURE: 000 000 67X49 CRAWL 4BDR 3BATH W/GAR & 10X16DECK
FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 4.00 PROPOSED USE : SFD
SEPTIC - EXISTING? : NEW WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED	INSP	DESCRIPTION
	COMPLETED	RESULT	RESULTS/COMMENTS
B101 01	9/16/08	TI	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001677244
	<u>9/16/08</u>	<u>DAP DT</u>	

----- COMMENTS AND NOTES -----

ADDRESS . . : 44 ORANGEWOOD CT SUBDIV: WOODSHIRE PH 5
CONTRACTOR : DUSTIN BLACKWELL, INC PHONE : (919) 606-4696
OWNER . . . : BLACKWELL HOMES #208 PHONE : (919) 606-4596
PARCEL . . . : 01-0536-06- -0028- -48-
APPL NUMBER: 08-50019305 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : WOODSHIRE #208
HWY 27W TO NURSERY RD, LEMUEL BLACK RD,
SUB DIV ON LEFT.
T/S: 01/28/2008 11:42 AM VBROWN ----

STRUCTURE: 000 000 67X49 CRAWL 4BDR 3BATH W/GAR & 10X16DECK
FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 4.00 PROPOSED USE : SFD
SEPTIC - EXISTING? : NEW WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	9/16/08 9/16/08	DT AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001677244
A814 01	9/18/08	TI	ADDRESS CONFIRMATION VRU #: 001678234
B103 01	9/18/08 <u>9/18/08</u>	TI <u>AP DT</u>	R*BLDG FOUND & TEMP SVC POLE VRU #: 001678242

----- COMMENTS AND NOTES -----

Brent
(919) 868 5821
7763

Chink-oak
(919) 795 1049

ADDRESS : 44 ORANGEWOOD CT SUBDIV: WOODSHIRE PH 5
 CONTRACTOR : DUSTIN BLACKWELL, INC PHONE : (919) 606-4696
 OWNER : BLACKWELL HOMES #208 PHONE : (919) 606-4596
 PARCEL : 01-0536-06- -0028- -48-
 APPL NUMBER: 08-50019305 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : WOODSHIRE #208
 HWY 27W TO NURSERY RD, LEMUEL BLACK RD,
 SUB DIV ON LEFT.
 T/S: 01/28/2008 11:42 AM VBROWN -----

STRUCTURE: 000 000 67X49 CRAWL 4BDR 3BATH W/GAR & 10X16DECK
 FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 4.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	9/16/08	DT	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001677244
	9/16/08	AP	
A814 01	9/18/08	TI	ADDRESS CONFIRMATION VRU #: 001678234
B103 01	9/18/08	DT	R*BLDG FOUND & TEMP SVC POLE VRU #: 001678242
	9/18/08	AP	
B105 01	9/19/08	TI	R*OPEN FLOOR VRU #: 001679521

AP JH

----- COMMENTS AND NOTES -----

ADDRESS : 44 ORANGEWOOD CT SUBDIV: WOODSHIRE PH 5
CONTRACTOR : DUSTIN BLACKWELL, INC PHONE : (919) 606-4696
OWNER : BLACKWELL HOMES #208 PHONE : (919) 606-4596
PARCEL : 01-0536-06- -0028- -48-
APPL NUMBER: 08-50019305 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : WOODSHIRE #208
HWY 27W TO NURSERY RD, LEMUEL BLACK RD,
SUB DIV ON LEFT.
T/S: 01/28/2008 11:42 AM VBROWN ----

STRUCTURE: 000 000 67X49 CRAWL 4BDR 3BATH W/GAR & 10X16DECK
FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 4.00 PROPOSED USE : SFD
SEPTIC - EXISTING? : NEW WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	9/16/08	DT	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001677244
	9/16/08	AP	
B103 01	9/18/08	DT	R*BLDG FOUND & TEMP SVC POLE VRU #: 001678242
	9/18/08	AP	
A814 01	9/18/08	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001678234
	9/19/08	AP	44 ORANGEWOOD CT LOT 208
B105 01	9/19/08	JH	R*OPEN FLOOR VRU #: 001679521
	9/19/08	AP	
R427 01	10/06/08	TI	FOUR TRADE ROUGH IN >2500 VRU #: 001686679

DA Jlt

----- COMMENTS AND NOTES -----

ADDRESS : 44 ORANGEWOOD CT SUBDIV: WOODSHIRE PH 5
 CONTRACTOR : DUSTIN BLACKWELL, INC PHONE : (919) 606-4696
 OWNER : BLACKWELL HOMES #208 PHONE : (919) 606-4596
 PARCEL : 01-0536-06- -0028- -48-
 APPL NUMBER: 08-50019305 CP NEW RESIDENTIAL (SFD)

DIRECTIONS : WOODSHIRE #208
 HWY 27W TO NURSERY RD, LEMUEL BLACK RD,
 SUB DIV ON LEFT.
 T/S: 01/28/2008 11:42 AM VBROWN ----

STRUCTURE: 000 000 67X49 CRAWL 4BDR 3BATH W/GAR & 10X16DECK
 FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 4.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	9/16/08	DT	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001677244
	9/16/08	AP	
B103 01	9/18/08	DT	R*BLDG FOUND & TEMP SVC POLE VRU #: 001678242
	9/18/08	AP	
A814 01	9/18/08	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001678234
	9/19/08	AP	44 ORANGEWOOD CT LOT 208
B105 01	9/19/08	JH	R*OPEN FLOOR VRU #: 001679521
	9/19/08	AP	
R427 01	10/06/08	JH	FOUR TRADE ROUGH IN >2500 VRU #: 001686679
	10/06/08	DA	<ol style="list-style-type: none"> 1) Nail guard @ drain line for washer. 2) Nail guard & fire caulk behind refrigerator. 3) Need more strapping on drain lines over kitchen & under house every 4'. 4) Window to right of back door needs to be tempered. 5) Nail guard behind toilet & @ water heater in master bathroom. 6) Need 10D common nails in 45 degree holes in hangers in sitting room. 7) Fire caulk wire @ top plate on right wall in play room. 8) Fire caulk 2" vent pipes upstairs @ floor level.
R427 03	10/07/08	TI	FOUR TRADE ROUGH IN >2500 TIME: 17:00 VRU #: 001688407
		AE-MR	

COMMENTS AND NOTES

ADDRESS : 44 ORANGEWOOD CT SUBDIV: WOODSHIRE PH 5
 CONTRACTOR : DUSTIN BLACKWELL, INC PHONE : (919) 606-4696
 OWNER : BLACKWELL HOMES #208 PHONE : (919) 606-4596
 PARCEL : 01-0536-06- -0028- -48-
 APPL NUMBER: 08-50019305 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : WOODSHIRE #208
 HWY 27W TO NURSERY RD, LEMUEL BLACK RD,
 SUB DIV ON LEFT.
 T/S: 01/28/2008 11:42 AM VBROWN ----

STRUCTURE: 000 000 67X49 CRAWL 4BDR 3BATH W/GAR & 10X16DECK
 FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 4.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	9/16/08	DT	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001677244
	9/16/08	AP	
B103 01	9/18/08	DT	R*BLDG FOUND & TEMP SVC POLE VRU #: 001678242
	9/18/08	AP	
A814 01	9/18/08	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001678234
	9/19/08	AP	44 ORANGEWOOD CT LOT 208
B105 01	9/19/08	JH	R*OPEN FLOOR VRU #: 001679521
	9/19/08	AP	
R427 01	10/06/08	JH	FOUR TRADE ROUGH IN >2500 VRU #: 001686679
	10/06/08	DA	1)Nail guard @ drain line for washer. 2)Nail guard & fire caulk behind refigerater. 3)Need more strapping on drain lines over kitchen & under house every 4'. 4)Window to right of back door needs to be tempered. 5)Nail guard behind toilet & @ water heater in master bathroom. 6)Need 10D coomon nails in 45 degree holes in hangers in sitting room. 7)Fire caulk wire @ top plate on right wall in play room. 8) Fire caulk 2" vent pipes upstairs @ floor level.
R427 03	10/07/08	MR	FOUR TRADE ROUGH IN >2500 TIME: 17:00 VRU #: 001688407
	10/07/08	AE	still need tempered window at back door by final
I129 01	10/08/08	TI	R*INSULATION INSPECTION VRU #: 001688951
	<u>10/8/08</u>	<u>AP DT</u>	
R427 02	10/08/08	TI	FOUR TRADE ROUGH IN >2500 VRU #: 001688282
	10/07/08	CA	

COMMENTS AND NOTES

ADDRESS : 44 ORANGEWOOD CT SUBDIV: WOODSHIRE PH 5
 CONTRACTOR : DUSTIN BLACKWELL, INC PHONE : (919) 606-4696
 OWNER : BLACKWELL HOMES #208 PHONE : (919) 606-4596
 PARCEL : 01-0536-06- -0028- -48-
 APPL NUMBER: 08-50019305 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : WOODSHIRE #208
 HWY 27W TO NURSERY RD, LEMUEL BLACK RD,
 SUB DIV ON LEFT.
 T/S: 01/28/2008 11:42 AM VBROWN ----

STRUCTURE: 000 000 67X49 CRAWL 4BDR 3BATH W/GAR & 10X16DECK
 FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 4.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	9/16/08	DT	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001677244
	9/16/08	AP	
B103 01	9/18/08	DT	R*BLDG FOUND & TEMP SVC POLE VRU #: 001678242
	9/18/08	AP	
A814 01	9/18/08	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001678234
	9/19/08	AP	✓ 44 ORANGEWOOD CT LOT 208
B105 01	9/19/08	JH	R*OPEN FLOOR VRU #: 001679521
	9/19/08	AP	
R427 01	10/06/08	JH	FOUR TRADE ROUGH IN >2500 VRU #: 001686679
	10/06/08	DA	1)Nail guard @ drain line for washer. 2)Nail guard & fire caulk behind refigerater. 3)Need more strapping on drain lines over kitchen & under house every 4'. 4)Window to right of back door needs to be tempered. 5)Nail guard behind toilet & @ water heater in master bathroom. 6)Need 10D coomon nails in 45 degree holes in hangers in sitting room. 7)Fire caulk wire @ top plate on right wall in play room. 8) Fire caulk 2" vent pipes upstairs @ floor level.
R427 03	10/07/08	MR	FOUR TRADE ROUGH IN >2500 TIME: 17:00 VRU #: 001688407
	10/07/08	AE	still need tempered window at back door by final
I129 01	10/08/08	DT	R*INSULATION INSPECTION VRU #: 001688951
	10/08/08	AP	
R427 02	10/08/08	TI	FOUR TRADE ROUGH IN >2500 VRU #: 001688282
	10/07/08	CA	
H824 01	10/21/08	JW	✓ ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001696087
	10/21/08	AP	
R431 01	11/13/08	DT	FOUR TRADE FINAL >2500 VRU #: 001704295
	11/13/08	CA	Per Dustin
R431 02	11/17/08	JH	FOUR TRADE FINAL >2500 VRU #: 001705961
	11/17/08	CA	per Dustin
R431 03	11/21/08	TI	FOUR TRADE FINAL >2500 VRU #: 001707066

11.21.08 *AP*

COMMENTS AND NOTES

FS

Lot 208

**COUNTY OF HARNETT
DEPARTMENT OF BUILDING INSPECTION
AND PLANNING/DEVELOPMENT
CERTIFICATE OF OCCUPANCY**

This certificate issued pursuant to the requirements of Section 105 of the North Carolina State Building Code and the Harnett County Zoning Ordinance certifies at the time of issuance this structure was in compliance with the various ordinances of the County of Harnett regulating development and building construction or use. For the following:

Use Classification: D

PERMIT NUMBERS

Owner: Blackwell Homes

Building Permit No.: 8-5-19305

911 Address: 44 Orange Woods Ct

Electrical Permit No.: 8-5-19305

Insulation Permit No.: 8-5-19305

Plumbing Permit No.: 8-5-19305

State: _____ Zip Code: _____

Mech. Permit No.: 8-5-19305

MFG. Home: _____

Date: 11-21-8
Fred Sperry
Building Official