
ADDRESS . . : 288 SONORA DR SUBDIV: WOODSHIRE PH 5
CONTRACTOR : DBI-DUSTIN BLACKWELL INC PHONE : (919) 606-4696
OWNER . . . : WOODSHIRE PARTNERS LLC #224 PHONE :
PARCEL . . . : 01-0536-06- -0028- -64-
APPL NUMBER: 08-50019310 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : WOODSHIRE #224
HWY 27W TO NURSERY RD, LEMUEL BLACK RD,
SUB DIV ON LEFT.
T/S: 01/28/2008 11:52 AM VBROWN ----

STRUCTURE: 000 000 50X67 3BDR 3BATH SFD
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	6/26/08 <i>6-26-08</i>	TI <i>AP</i>	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001632470

----- COMMENTS AND NOTES -----

F

ADDRESS . . : 288 SONORA DR SUBDIV: WOODSHIRE PH 5
CONTRACTOR : DBI-DUSTIN BLACKWELL INC PHONE : (919) 606-4696
OWNER . . : WOODSHIRE PARTNERS LLC #224 PHONE :
PARCEL . . : 01-0536-06- -0028- -64-
APPL NUMBER: 08-50019310 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : WOODSHIRE #224
HWY 27W TO NURSERY RD, LEMUEL BLACK RD,
SUB DIV ON LEFT.
T/S: 01/28/2008 11:52 AM VBROWN -----

STRUCTURE: 000 000 50X67 3BDR 3BATH SFD
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	6/26/08	FS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001632470
	6/26/08	AP	
A814 01	6/30/08	TI	ADDRESS CONFIRMATION VRU #: 001634039
B103 01	6/30/08	TI <i>AP JH</i>	R*BLDG FOUND & TEMP SVC POLE VRU #: 001634013

----- COMMENTS AND NOTES -----

ADDRESS . : 288 SONORA DR SUBDIV: WOODSHIRE PH 5
CONTRACTOR : DBI-DUSTIN BLACKWELL INC PHONE : (919) 606-4696
OWNER . . : WOODSHIRE PARTNERS LLC #224 PHONE :
PARCEL . . : 01-0536-06- -0028- -64-
APPL NUMBER: 08-50019310 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : WOODSHIRE #224
HWY 27W TO NURSERY RD, LEMUEL BLACK RD,
SUB DIV ON LEFT.
T/S: 01/28/2008 11:52 AM VBROWN ----

STRUCTURE: 000 000 50X67 3BDR 3BATH SFD
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	6/26/08	FS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001632470
	6/26/08	AP	
A814 01	6/30/08	TI	ADDRESS CONFIRMATION VRU #: 001634039
B103 01	6/30/08	JH	R*BLDG FOUND & TEMP SVC POLE VRU #: 001634013
	6/30/08	AP	
B105 01	7/02/08	TI	R*OPEN FLOOR VRU #: 001635572
	<u>7/2/08</u>	<u>AR DT</u>	

COMMENTS AND NOTES

ADDRESS : 288 SONORA DR
CONTRACTOR : DBI-DUSTIN BLACKWELL INC
OWNER : WOODSHIRE PARTNERS LLC #224
PARCEL : 01-0536-06- -0028- -64-
APPL NUMBER: 08-50019310 CP NEW RESIDENTIAL (SFD)

SUBDIV: WOODSHIRE PH 5
PHONE : (919) 606-4696
PHONE :

DIRECTIONS : WOODSHIRE #224
HWY 27W TO NURSERY RD, LEMUEL BLACK RD,
SUB DIV ON LEFT.
T/S: 01/28/2008 11:52 AM VBROWN ----

STRUCTURE: 000 000 50X67 3BDR 3BATH SFD
FLOOD ZONE . . . : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	6/26/08 6/26/08	FS AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001632470
B103 01	6/30/08 6/30/08	JH AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001634013
A814 01	6/30/08 7/03/08	TI AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001634039 288 SONORA DR LOT 224
B105 01	7/02/08 7/02/08	DT AP	R*OPEN FLOOR VRU #: 001635572
R427 01	7/14/08 <u>7/14/08</u>	TI <u>DAVI</u>	FOUR TRADE ROUGH IN >2500 TIME: 17:00 VRU #: 001641216

----- COMMENTS AND NOTES -----

ADDRESS : 288 SONORA DR SUBDIV: WOODSHIRE PH 5
CONTRACTOR : DBI-DUSTIN BLACKWELL INC PHONE : (919) 606-4696
OWNER : WOODSHIRE PARTNERS LLC #224 PHONE :
PARCEL : 01-0536-06- -0028- -64-
APPL NUMBER: 08-50019310 CP NEW RESIDENTIAL (SFD)

DIRECTIONS : WOODSHIRE #224
HWY 27W TO NURSERY RD, LEMUEL BLACK RD,
SUB DIV ON LEFT.
T/S: 01/28/2008 11:52 AM VBROWN ----

STRUCTURE: 000 000 50X67 3BDR 3BATH SFD
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	6/26/08	FS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001632470
	6/26/08	AP	
B103 01	6/30/08	JH	R*BLDG FOUND & TEMP SVC POLE VRU #: 001634013
	6/30/08	AP	
A814 01	6/30/08	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001634039
	7/03/08	AP	288 SONORA DR LOT 224
B105 01	7/02/08	DT	R*OPEN FLOOR VRU #: 001635572
	7/02/08	AP	
R427 01	7/14/08	DT	FOUR TRADE ROUGH IN >2500 TIME: 17:00 VRU #: 001641216
	7/14/08	DA	1. Rodent proof master tub and shower. 2. Re-caulk electrical above panel box and vent for washing machine. 3. A6 truss not connected to brace. 4. C2 girder truss not nailed correctly. 5. B4 truss not strapped for uplift. 6. E trusses not strapped correctly. 7. Window within 24 inches of rear door must be tempered. Okay to insulate, do not side.
I129 01	7/16/08	TI	R*INSULATION INSPECTION VRU #: 001642057
	<u>7/16/08</u>	<u>AP DT</u>	
R427 02	7/16/08	TI	FOUR TRADE ROUGH IN >2500 TIME: 17:00 VRU #: 001643311
	<u>7/16/08</u>	<u>AP DT</u>	

----- COMMENTS AND NOTES -----

ADDRESS : 288 SONORA DR SUBDIV: WOODSHIRE PH 5
 CONTRACTOR : DBI-DUSTIN BLACKWELL INC PHONE : (919) 606-4696
 OWNER . . : WOODSHIRE PARTNERS LLC #224 PHONE :
 PARCEL . . : 01-0536-06- -0028- -64-
 APPL NUMBER: 08-50019310 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : WOODSHIRE #224
 HWY 27W TO NURSERY RD, LEMUEL BLACK RD,
 SUB DIV ON LEFT.
 T/S: 01/28/2008 11:52 AM VBROWN ----

STRUCTURE: 000 000 50X67 3BDR 3BATH SFD
 FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	6/26/08 6/26/08	FS AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001632470
B103 01	6/30/08 6/30/08	JH AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001634013
A814 01	6/30/08 7/03/08	TI AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001634039 ✓ 288 SONORA DR LOT 224
B105 01	7/02/08 7/02/08	DT AP	R*OPEN FLOOR VRU #: 001635572
R427 01	7/14/08 7/14/08	DT DA	FOUR TRADE ROUGH IN >2500 TIME: 17:00 VRU #: 001641216 1. Rodent proof master tub and shower. 2. Re-caulk electrical above panel box and vent for washing machine. 3. A6 truss not connected to brace. 4. C2 girder truss not nailed correctly. 5. B4 truss not strapped for uplift. 6. E trusses not strapped correctly. 7. Window within 24 inches of rear door must be tempered. Okay to insulate, do not side.
I129 01	7/16/08 7/16/08	DT AP	R*INSULATION INSPECTION VRU #: 001642057
R427 02	7/16/08 7/16/08	DT AP	FOUR TRADE ROUGH IN >2500 TIME: 17:00 VRU #: 001643311 1. Window near rear door must be tempered by final
H824 01	7/31/08 7/31/08	JW AP	✓ ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001653666
R431 01	9/05/08	TI	FOUR TRADE FINAL >2500 VRU #: 001672054

DP-MR

COMMENTS AND NOTES

ADDRESS : 288 SONORA DR SUBDIV: WOODSHIRE PH 5
 CONTRACTOR : DBI-DUSTIN BLACKWELL INC PHONE : (919) 606-4696
 OWNER : WOODSHIRE PARTNERS LLC #224 PHONE :
 PARCEL : 01-0536-06- -0028- -64-
 APPL NUMBER: 08-50019310 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : WOODSHIRE #224
 HWY 27W TO NURSERY RD, LEMUEL BLACK RD,
 SUB DIV ON LEFT.
 T/S: 01/28/2008 11:52 AM VBROWN ----

STRUCTURE: 000 000 50X67 3BDR 3BATH SFD
 FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	6/26/08	FS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001632470
	6/26/08	AP	
B103 01	6/30/08	JH	R*BLDG FOUND & TEMP SVC POLE VRU #: 001634013
	6/30/08	AP	
A814 01	6/30/08	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001634039
	7/03/08	AP	288 SONORA DR LOT 224
B105 01	7/02/08	DT	R*OPEN FLOOR VRU #: 001635572
	7/02/08	AP	
R427 01	7/14/08	DT	FOUR TRADE ROUGH IN >2500 TIME: 17:00 VRU #: 001641216
	7/14/08	DA	1. Rodent proof master tub and shower. 2. Re-caulk electrical above panel box and vent for washing machine. 3. A6 truss not connected to brace. 4. C2 girder truss not nailed correctly. 5. B4 truss not strapped for uplift. 6. E trusses not strapped correctly. 7. Window within 24 inches of rear door must be tempered. Okay to insulate, do not side.
I129 01	7/16/08	DT	R*INSULATION INSPECTION VRU #: 001642057
	7/16/08	AP	
R427 02	7/16/08	DT	FOUR TRADE ROUGH IN >2500 TIME: 17:00 VRU #: 001643311
	7/16/08	AP	1. Window near rear door must be tempered by final
H824 01	7/31/08	JW	✓ ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001653666
	7/31/08	AP	
R431 01	9/05/08	MP	FOUR TRADE FINAL >2500 VRU #: 001672054
	9/05/08	DP	handrail need on stairs in garage
R431 02	9/09/08	TI	FOUR TRADE FINAL >2500 VRU #: 001673920

AP-MP

COMMENTS AND NOTES

**COUNTY OF HARNETT
DEPARTMENT OF BUILDING INSPECTION
AND PLANNING/DEVELOPMENT
CERTIFICATE OF OCCUPANCY**

This certificate issued pursuant to the requirements of Section 105 of the North Carolina State Building Code and the Harnett County Zoning Ordinance certifies at the time of issuance this structure was in compliance with the various ordinances of the County of Harnett regulating development and building construction or use. For the following:

Use Classification: R-3

Owner: Woodshire partners

911 Address: 288 Souara

State: _____ Zip Code: _____

Date: 9-9-8

Mike Reavis

Building Official

PERMIT NUMBERS

Building Permit No.: 08-50019310

Electrical Permit No.: "

Insulation Permit No.: "

Plumbing Permit No.: "

Mech. Permit No.: "

MFG. Home: _____