
ADDRESS . : 82 KIMBROUGH DR SUBDIV: WOODSHIRE PH 5
CONTRACTOR : CUMBERLAND HOMES INC PHONE : (910) 892-4345
OWNER . . : NEW CENTURY HOMES LLC #213 PHONE :
PARCEL . . : 01-0536-06- -0028- -53-
APPL NUMBER: 08-50019379 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : 27 W TURN LEFT ON NURSERY RD TURN LEFT
ON LAMUEL BLACK RD TURN LEFT ON
WOODSHIRE DR TURN RIGHT ON SONORA DR
TURN LEFT ON KIMBROUGH LOT WILL BE ON
RIGHT LOT 213 JB

STRUCTURE: 000 000 54X45 3BDR
FLOOD ZONE . . . : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	<u>3/04/08</u> <u>3.4.8</u>	TI <u>AP</u>	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001571702

----- COMMENTS AND NOTES -----
F

ADDRESS . : 82 KIMBROUGH DR SUBDIV: WOODSHIRE PH 5
CONTRACTOR : CUMBERLAND HOMES INC PHONE : (910) 892-4345
OWNER . . : NEW CENTURY HOMES LLC #213 PHONE :
PARCEL . . : 01-0536-06- -0028- -53-
APPL NUMBER: 08-50019379 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : 27 W TURN LEFT ON NURSERY RD TURN LEFT
ON LAMUEL BLACK RD TURN LEFT ON
WOODSHIRE DR TURN RIGHT ON SONORA DR
TURN LEFT ON KIMBROUGH LOT WILL BE ON
RIGHT LOT 213 JB

STRUCTURE: 000 000 54X45 3BDR
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	3/04/08 3/04/08	FS AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001571702
B103 01	3/13/08 <u>3/13/08</u>	TI <u>AP DT</u>	R*BLDG FOUND & TEMP SVC POLE VRU #: 001576155

----- COMMENTS AND NOTES -----

ADDRESS . : 82 KIMBROUGH DR SUBDIV: WOODSHIRE PH 5
CONTRACTOR : CUMBERLAND HOMES INC PHONE : (910) 892-4345
OWNER . . : NEW CENTURY HOMES LLC #213 PHONE :
PARCEL . . : 01-0536-06- -0028- -53-
APPL NUMBER: 08-50019379 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : 27 W TURN LEFT ON NURSERY RD TURN LEFT
ON LAMUEL BLACK RD TURN LEFT ON
WOODSHIRE DR TURN RIGHT ON SONORA DR
TURN LEFT ON KIMBROUGH LOT WILL BE ON
RIGHT LOT 213 JB

STRUCTURE: 000 000 54X45 3BDR
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	3/04/08 3/04/08	FS AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001571702
B103 01	3/13/08 3/13/08	DT AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001576155
A814 01	3/19/08	TI	ADDRESS CONFIRMATION VRU #: 001579523
P309 01	3/19/08 <u>3/19/08</u>	TI <u>AS DT</u>	R*PLUMB UNDER SLAB VRU #: 001579515

----- COMMENTS AND NOTES -----

ADDRESS . : 82 KIMBROUGH DR SUBDIV: WOODSHIRE PH 5
CONTRACTOR : CUMBERLAND HOMES INC PHONE : (910) 892-4345
OWNER . . : NEW CENTURY HOMES LLC #213 PHONE :
PARCEL . . : 01-0536-06- -0028- -53-
APPL NUMBER: 08-50019379 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : 27 W TURN LEFT ON NURSERY RD TURN LEFT
ON LAMUEL BLACK RD TURN LEFT ON
WOODSHIRE DR TURN RIGHT ON SONORA DR
TURN LEFT ON KIMBROUGH LOT WILL BE ON
RIGHT LOT 213 JB

STRUCTURE: 000 000 54X45 3BDR
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	3/04/08 3/04/08	FS AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001571702
B103 01	3/13/08 3/13/08	DT AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001576155
A814 01	3/19/08	TI	ADDRESS CONFIRMATION VRU #: 001579523
P309 01	3/19/08	TI	R*PLUMB UNDER SLAB VRU #: 001579515
B111 01	3/20/08	TI	R*BLDG SLAB INSP VRU #: 001580328

AP- Dean signed off in field
AP-MR

----- COMMENTS AND NOTES -----

ADDRESS : 82 KIMBROUGH DR
CONTRACTOR : CUMBERLAND HOMES INC
OWNER : NEW CENTURY HOMES LLC #213
PARCEL : 01-0536-06- -0028- -53-
APPL NUMBER: 08-50019379 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : 27 W TURN LEFT ON NURSERY RD TURN LEFT
ON LAMUEL BLACK RD TURN LEFT ON
WOODSHIRE DR TURN RIGHT ON SONORA DR
TURN LEFT ON KIMBROUGH LOT WILL BE ON
RIGHT LOT 213 JB

SUBDIV: WOODSHIRE PH 5
PHONE : (910) 892-4345
PHONE :

STRUCTURE: 000 000 54X45 3BDR
FLOOD ZONE . . . : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	3/04/08	FS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001571702
	3/04/08	AP	
B103 01	3/13/08	DT	R*BLDG FOUND & TEMP SVC POLE VRU #: 001576155
	3/13/08	AP	
P309 01	3/19/08	DT	R*PLUMB UNDER SLAB VRU #: 001579515
	3/19/08	AP	
A814 01	3/19/08	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001579523
	3/19/08	AP	82 KIMBROUGH DR LOT 213
B111 01	3/20/08	MR	R*BLDG SLAB INSP VRU #: 001580328
	3/20/08	AP	
R425 01	4/30/08	TI	FOUR TRADE ROUGH IN VRU #: 001601202

4/30/08 DADT

----- COMMENTS AND NOTES -----

ADDRESS : 82 KIMBROUGH DR
CONTRACTOR : CUMBERLAND HOMES INC
OWNER : NEW CENTURY HOMES LLC #213
PARCEL : 01-0536-06- -0028- -53-
APPL NUMBER: 08-50019379 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : 27 W TURN LEFT ON NURSERY RD TURN LEFT
ON LAMUEL BLACK RD TURN LEFT ON
WOODSHIRE DR TURN RIGHT ON SONORA DR
TURN LEFT ON KIMBROUGH LOT WILL BE ON
RIGHT LOT 213 JB

SUBDIV: WOODSHIRE PH 5
PHONE : (910) 892-4345
PHONE :

STRUCTURE: 000 000 54X45 3BDR
FLOOD ZONE . . . : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	3/04/08	FS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001571702
	3/04/08	AP	
B103 01	3/13/08	DT	R*BLDG FOUND & TEMP SVC POLE VRU #: 001576155
	3/13/08	AP	
P309 01	3/19/08	DT	R*PLUMB UNDER SLAB VRU #: 001579515
	3/19/08	AP	
A814 01	3/19/08	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001579523
	3/19/08	AP	82 KIMBROUGH DR LOT 213
B111 01	3/20/08	MR	R*BLDG SLAB INSP VRU #: 001580328
	3/20/08	AP	
R425 01	4/30/08	BT	FOUR TRADE ROUGH IN VRU #: 001601202
	4/30/08	DA	Roofing incomplete. Need fire caulk for phone wire in great room. Need 10 psi on gas line. Okay to side and insulate
R425 02	5/01/08	TI	FOUR TRADE ROUGH IN VRU #: 001601895

AP JB

----- COMMENTS AND NOTES -----

ADDRESS . . : 82 KIMBROUGH DR SUBDIV: WOODSHIRE PH 5
CONTRACTOR : CUMBERLAND HOMES INC PHONE : (910) 892-4345
OWNER . . . : NEW CENTURY HOMES LLC #213 PHONE :
PARCEL . . . : 01-0536-06- -0028- -53-
APPL NUMBER: 08-50019379 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : 27 W TURN LEFT ON NURSERY RD TURN LEFT
ON LAMUEL BLACK RD TURN LEFT ON
WOODSHIRE DR TURN RIGHT ON SONORA DR
TURN LEFT ON KIMBROUGH LOT WILL BE ON
RIGHT LOT 213 JB

STRUCTURE: 000 000 54X45 3BDR
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	3/04/08	FS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001571702
	3/04/08	AP	
B103 01	3/13/08	DT	R*BLDG FOUND & TEMP SVC POLE VRU #: 001576155
	3/13/08	AP	
P309 01	3/19/08	DT	R*PLUMB UNDER SLAB VRU #: 001579515
	3/19/08	AP	
A814 01	3/19/08	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001579523
	3/19/08	AP	82 KIMBROUGH DR LOT 213
B111 01	3/20/08	MR	R*BLDG SLAB INSP VRU #: 001580328
	3/20/08	AP	
R425 01	4/30/08	DT	FOUR TRADE ROUGH IN VRU #: 001601202
	4/30/08	DA	1. Roofing incomplete. 2. Need fire caulk for phone wire in great room. 3. Need 10 psi on gas line. Okay to side and insulate
R425 02	5/01/08	JH	FOUR TRADE ROUGH IN VRU #: 001601895
	5/01/08	AP	
I129 01	5/02/08	TI	R*INSULATION INSPECTION VRU #: 001602661

5/2/08 DA DT

----- COMMENTS AND NOTES -----

ADDRESS : 82 KIMBROUGH DR SUBDIV: WOODSHIRE PH 5
 CONTRACTOR : CUMBERLAND HOMES INC PHONE : (910) 892-4345
 OWNER : NEW CENTURY HOMES LLC #213 PHONE :
 PARCEL : 01-0536-06- -0028- -53-
 APPL NUMBER: 08-50019379 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : 27 W TURN LEFT ON NURSERY RD TURN LEFT
 ON LAMUEL BLACK RD TURN LEFT ON
 WOODSHIRE DR TURN RIGHT ON SONORA DR
 TURN LEFT ON KIMBROUGH LOT WILL BE ON
 RIGHT LOT 213 JB

STRUCTURE: 000 000 54X45 3BDR
 FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	3/04/08	FS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001571702
	3/04/08	AP	
B103 01	3/13/08	DT	R*BLDG FOUND & TEMP SVC POLE VRU #: 001576155
	3/13/08	AP	
P309 01	3/19/08	DT	R*PLUMB UNDER SLAB VRU #: 001579515
	3/19/08	AP	
A814 01	3/19/08	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001579523
	3/19/08	AP	82 KIMBROUGH DR LOT 213
B111 01	3/20/08	MR	R*BLDG SLAB INSP VRU #: 001580328
	3/20/08	AP	
R425 01	4/30/08	DT	FOUR TRADE ROUGH IN VRU #: 001601202
	4/30/08	DA	1. Roofing incomplete. 2. Need fire caulk for phone wire in great room. 3. Need 10 psi on gas line. Okay to side and insulate
R425 02	5/01/08	JH	FOUR TRADE ROUGH IN VRU #: 001601895
	5/01/08	AP	
I129 01	5/02/08	DT	R*INSULATION INSPECTION VRU #: 001602661
	5/02/08	DA	Job not complete
I129 02	5/05/08	TI	R*INSULATION INSPECTION VRU #: 001603232
	5/5/08	AP	

COMMENTS AND NOTES

ADDRESS : 82 KIMBROUGH DR SUBDIV: WOODSHIRE PH 5
 CONTRACTOR : CUMBERLAND HOMES INC PHONE : (910) 892-4345
 OWNER : NEW CENTURY HOMES LLC #213 PHONE :
 PARCEL : 01-0536-06- -0028- -53-
 APPL NUMBER: 08-50019379 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : 27 W TURN LEFT ON NURSERY RD TURN LEFT
 ON LAMUEL BLACK RD TURN LEFT ON
 WOODSHIRE DR TURN RIGHT ON SONORA DR
 TURN LEFT ON KIMBROUGH LOT WILL BE ON
 RIGHT LOT 213 JB

STRUCTURE: 000 000 54X45 3BDR
 FLOOD ZONE . . . : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	3/04/08	FS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001571702
	3/04/08	AP	
B103 01	3/13/08	DT	R*BLDG FOUND & TEMP SVC POLE VRU #: 001576155
	3/13/08	AP	
P309 01	3/19/08	DT	R*PLUMB UNDER SLAB VRU #: 001579515
	3/19/08	AP	
A814 01	3/19/08	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001579523
	3/19/08	AP	82 KIMBROUGH DR LOT 213
B111 01	3/20/08	MR	R*BLDG SLAB INSP VRU #: 001580328
	3/20/08	AP	
R425 01	4/30/08	DT	FOUR TRADE ROUGH IN VRU #: 001601202
	4/30/08	DA	1. Roofing incomplete. 2. Need fire caulk for phone wire in great room. 3. Need 10 psi on gas line. Okay to side and insulate
R425 02	5/01/08	JH	FOUR TRADE ROUGH IN VRU #: 001601895
	5/01/08	AP	
I129 01	5/02/08	DT	R*INSULATION INSPECTION VRU #: 001602661
	5/02/08	DA	Job not complete
I129 02	5/05/08	DT	R*INSULATION INSPECTION VRU #: 001603232
	5/05/08	AP	
H824 01	5/13/08	JW	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001609155
	5/13/08	AP	
R429 01	6/24/08	TI	FOUR TRADE FINAL VRU #: 001630813
	6/24/08	AP DT	

COMMENTS AND NOTES

**COUNTY OF HARNETT
DEPARTMENT OF BUILDING INSPECTION
AND PLANNING/DEVELOPMENT
CERTIFICATE OF OCCUPANCY**

This certificate issued pursuant to the requirements of Section 105 of the North Carolina State Building Code and the Harnett County Zoning Ordinance certifies at the time of issuance this structure was in compliance with the various ordinances of the County of Harnett regulating development and building construction or use. For the following:

Use Classification: Residential

Owner: New Century Homes

911 Address: 82 Kimbrough Dr

State: NC Zip Code: _____

Date: 6/24/08

D. E. T. S. L.

Building Official

PERMIT NUMBERS

Building Permit No.: _____

Electrical Permit No.: _____

Insulation Permit No.: _____

Plumbing Permit No.: _____

Mech. Permit No.: 08-50019379

MFG. Home: _____