

Owner:

Applicant:

Address:

Date Evaluated: 2/19/08

Proposed Facility: 3 Bedroom Home Design Flow (.1949): 360 gpd

Property Size:

Location of Site:

Property Recorded:

Water Supply: ☐ Public ☐ Individual ☒ Well ☐ Spring ☐ Other

Evaluation Method: ☒ Auger Boring

[] Pit

☐ Cut

Type of Wastewater: ☒ Sewage

☐ Industrial Process

☐ Mixed

[illegible]

Description	Initial System	Repair System
Available Space (.1945)	✓	✓
System Type(s)	CO-2	CO-2
Site LTAR	.8	.8

Other Factors (.1946): _____

Site Classification (.1948):

Evaluated By: 

Others Present:


COMMENTS: _____

<u>LANDSCAPE POSITIONS</u>	<u>GROUP</u>	<u>TEXTURES</u>	<u>.1955 LTAR</u>	<u>CONSISTENCE MOIST</u>	<u>WET</u>
R-RIDGE	I	S-SAND	1.2 - 0.8	VFR-VERY FRIABLE FR-FRIABLE FI-FIRM VFI-VERY FIRM EFI-EXTREMELY FIRM	NS-NON-STICKY SS-SLIGHTLY STICKY S-STICKY VS-VERY STICKY NP-NON-PLASTIC SP-SLIGHTLY STICKY P-PLASTIC VP-VERY PLASTIC
S-SHOULDER SLOPE		LS-LOAMY SAND			
L-LINEAR SLOPE	II	SL-SANDY LOAM	0.8 – 0.6		
FS-FOOT SLOPE		L-LOAM			
N-NOSE SLOPE	III	SI-SILT-	0.6 – 0.3		
H-HEAD SLOPE		SIL-SILT LOAM			
CC-CONCLAVE SLOPE	IV	CL-CLAY LOAM	0.4 – 0.1		
CV-CONVEX SLOPE		SCL-SANDY CLAY LOAM			
T-TERRACE		SICL-SILTY CLAY LOAM			
FP-FLOOD PLAN		SIC-SILTY CLAY			
		C-CLAY			
		SC-SANDY CLAY			

STRUCTURE
 SG-SINGLE GRAIN
 M-MASSIVE
 CR-CRUMB
 GR-GRANULAR
 SBK-SUBANGULAR BLOCKY
 ABK-ANGULAR BLOCKY
 PL-PLATY
 PR-PRISMATIC

MINERALOGY
 SLIGHTLY EXPANSIVE
 EXPANSIVE


Show profile locations and other site features (dimensions, reference or benchmark, and North).



SITE PLAN APPROVAL ^{70x70}
 DISTRICT _____ USE SFD / Future 24x40 Detached Garage
 #BEDROOMS _____
2-12-08 V.C. Brown
 Date Zoning Administrator

NOTE:
 THIS SURVEY CREATI
 WITHIN THE AREA OF
 THAT HAS AN ORDINA
 OF LAND.

JACK P. TAYLOR
 D.B. 820, PG. 362



MARION TAYLOR
 D.B. 865, PG. 225