

Improvement Permit

A building permit cannot be issued with only an Improvement Permit

ISSUED TO: Kent Pierce PROPERTY LOCATION: 1210
 SUBDIVISION: Persimmon Hill LOT # 24

NEW REPAIR EXPANSION Site Improvements required prior to Construction Authorization Issuance:

Type of Structure: SFO - 28 x 59 3BR

Proposed Wastewater System Type: Pump + 25% Red. system

Projected Daily Flow: 360 GPD

Number of bedrooms: 3 Number of Occupants: 6 max

Basement Yes No

Pump Required: Yes No May be required based on final location and elevations of facilities

Type of Water Supply: Community Public Well Distance from well 50 feet Permit valid for: Five years

Permit conditions: Meet onsite for final layout maintain all set back No expiration

Please note that supply easement is on lot 24, 25 & 26 - suggest that all 3 supply lines be placed at one time each clearly marked & labeled

Authorized State Agent: J. W. [Signature] Date: 3-27-08 SEE ATTACHED SITE SKETCH

The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.

Construction Authorization

(Required for Building Permit)

The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout.

ISSUED TO: Kent Pierce PROPERTY LOCATION: 1210
 SUBDIVISION: Persimmon Hill LOT # 24

Facility Type: SFO - 28 x 59 - 3BR New Expansion Repair

Basement? Yes No Basement Fixtures? Yes No

Type of Wastewater System** Pump + 25% Red. sys (Initial) Wastewater Flow: 360 GPD

(See note below, if applicable
25% Reduction system (Repair)

Installation Requirements/Conditions

Septic Tank Size 1000 gallons Exact length of each trench 3 x 100 feet Trench Spacing: 9 Feet on Center
 Pump Tank Size 1000 gallons Trenches shall be installed on contour at a Soil Cover: 6 inches

Maximum Trench Depth of: 18 inches (Maximum soil cover shall not exceed 36" above the trench bottom)
 (Trench bottoms shall be level to +/- 1/4" in all directions)

Pump Requirements: _____ ft. TDH vs. _____ GPM _____ inches below pipe

Aggregate Depth: _____ inches above pipe

Conditions: _____ inches total

**If applicable: *I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.*

Owner/Legal Representative Signature: _____ Date: _____

This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit.

Authorized State Agent: J. W. [Signature] Date: 03-27-08 SEE ATTACHED SITE SKETCH

Construction Authorization Expiration Date: 03-27-2013

HTE# 08-500-19457R

Permit # 24672

Harnett County Department of Public Health Site Sketch

ISSUED TO: Kent Pizace

PROPERTY LOCATOR: 1210

SUBDIVISION Persimmon Hill

LOT # 24

Authorized State Agent: [Signature]

Date: 03-23-08

Meet onsite for Final Layout
 Maintain All Setbacks
 Install 3x100 + 25% Reduction system
 At 18" max.
 Supply Easement is shared with
 Lots 26 & 25. I suggest that all
 3 supply lines be installed at one
 time. All supply lines are to be
 marked so that they are to
 be identified later.

