



Harnett County
420 McKinney Pkwy
LILLINGTON, NC 27546
Phone:
Fax:

2/14/2022

SUBJECT: CPSF08-50019474
BUILDING RESIDENTIAL

To: HAL OWEN & ASSOCIATES #421

Here are the results of all Inspections located at **125 DUCK LN:**

Inspection Type: ENVIR. HLTH. CONFIRMATION
Scheduled Date/Time: 3/6/2008
Completed Date/Time: 6/18/2008
Inspector: Unassigned
Result: APPROVED
Remarks:
Notes:

Inspection Type: ENVIR. HLTH. CONFIRMATION
Scheduled Date/Time: 12/11/2008
Completed Date/Time: 12/5/2008
Inspector: Unassigned
Result: APPROVED
Remarks:
Notes:

Inspection Type: BLDG PLAN REVIEW
Scheduled Date/Time: 1/21/2009
Completed Date/Time: 1/21/2009
Inspector: Unassigned
Result: DISAPPROVED
Remarks:
Notes:

Inspection Type: BLDG PLAN REVIEW
Scheduled Date/Time: 2/3/2009
Completed Date/Time: 2/3/2009
Inspector: Unassigned
Result: APPROVED
Remarks:
Notes:



Harnett County
420 McKinney Pkwy

LILLINGTON, NC 27546
Phone:
Fax:

Inspection Type: BLDG PLAN REVIEW
Scheduled Date/Time: 2/3/2009
Completed Date/Time: 2/3/2009
Inspector: Unassigned
Result: APPROVED
Remarks:
Notes:

Inspection Type: R BLDG FOOTING / TEMP SVC POLE
Scheduled Date/Time: 3/19/2009
Completed Date/Time: 3/19/2009
Inspector: Unassigned
Result: CANCELLED
Remarks:
Notes:

Inspection Type: R BLDG FOOTING / TEMP SVC POLE
Scheduled Date/Time: 3/20/2009
Completed Date/Time: 3/20/2009
Inspector: Unassigned
Result: APPROVED
Remarks:
Notes: observed eng. letters on pilings and stone fill

Inspection Type: ADDRESS CONFIRMATION
Scheduled Date/Time: 3/24/2009
Completed Date/Time: 3/24/2009
Inspector: Unassigned
Result: APPROVED
Remarks:
Notes:

Inspection Type: R BLDG FOUND & TEMP SVC POLE
Scheduled Date/Time: 3/24/2009
Completed Date/Time: 3/24/2009
Inspector: Unassigned
Result: APPROVED
Remarks:
Notes:



Harnett County
420 McKinney Pkwy

LILLINGTON, NC 27546
Phone:
Fax:

Inspection Type: R PLUMB UNDER SLAB
Scheduled Date/Time: 3/30/2009
Completed Date/Time: 3/30/2009
Inspector: Unassigned
Result: DISAPPROVED
Remarks:
Notes: 1. no plans on site 2. water test with 10' head required

Inspection Type: R PLUMB UNDER SLAB
Scheduled Date/Time: 3/31/2009
Completed Date/Time: 3/31/2009
Inspector: Unassigned
Result: APPROVED
Remarks:
Notes:

Inspection Type: R BLDG SLAB INSP/TEMP SVC POLE
Scheduled Date/Time: 4/3/2009
Completed Date/Time: 4/3/2009
Inspector: Unassigned
Result: APPROVED
Remarks:
Notes:

Inspection Type: ENVIR. OPERATIONS PERMIT
Scheduled Date/Time: 4/20/2009
Completed Date/Time: 4/20/2009
Inspector: Unassigned
Result: APPROVED
Remarks:
Notes:

Inspection Type: FOUR TRADE ROUGH IN >2500
Scheduled Date/Time: 4/22/2009
Completed Date/Time: 4/22/2009
Inspector: Unassigned
Result: DISAPPROVED
Remarks:
Notes: OK to install brick siding



Harnett County
420 McKinney Pkwy

LILLINGTON, NC 27546
Phone:
Fax:

Inspection Type: FOUR TRADE ROUGH IN >2500
Scheduled Date/Time: 4/23/2009
Completed Date/Time: 4/23/2009
Inspector: Unassigned
Result: DISAPPROVED

Remarks:
Notes: 1. trusses a2,a2a are not supported at all points 2. fireblock and draftstop all walls 3. washer in basement is crown vented 4. temp win dows needed at final in mbr bath 5. draft stop basement ac room ceiling ok to insul.

Inspection Type: R INSULATION INSPECTION
Scheduled Date/Time: 4/28/2009
Completed Date/Time: 4/28/2009
Inspector: Unassigned
Result: APPROVED

Remarks:
Notes:

Inspection Type: FOUR TRADE ROUGH IN >2500
Scheduled Date/Time: 4/28/2009
Completed Date/Time: 4/28/2009
Inspector: Unassigned
Result: APPROVED

Remarks:
Notes:

Inspection Type: FOUR TRADE FINAL >2500
Scheduled Date/Time: 7/7/2009
Completed Date/Time: 7/7/2009
Inspector: Unassigned
Result: CANCELLED

Remarks:
Notes: T/S: 07/07/2009 01:01 PM MREARIC -----

Inspection Type: TWO TRADE FINAL >2500
Scheduled Date/Time: 7/8/2009
Completed Date/Time: 7/8/2009
Inspector: Unassigned
Result: APPROVED

Remarks:
Notes: T/S: 07/08/2009 12:56 PM MREARIC ----- co issued





Harnett County
420 Mckinney Pkwy

LILLINGTON, NC 27546

Phone:

Fax:

Inspection Type: ADDRESS CONFIRMATION

Scheduled Date/Time: 11/6/2012

Completed Date/Time: 11/6/2012

Inspector: Unassigned

Result: APPROVED

Remarks:

Notes:

T/S: 11/06/2012 11:39 AM DJOHNSON ----- T/S: 11/06/2012 11:40 AM TWARD
----- 125 DUCK LN LOT 421 SANFORD 27332 NOTE: APPROVED
PREVIOUSLY BY MR/INSPECTOR AS 153 DUCK LN WHICH WAS INCCORECT. RECORDS UPDATED
ACCORDINGLY 11/06/12
T/S: 11/06/2012 11:41 AM TWARD -----

