

ADDRESS . . : 50 ALBAN ROW  
CONTRACTOR : DAIL BUILDERS INC  
OWNER . . . : DAIL BUILDERS INC #24  
PARCEL . . . : 08-0655- - -0067- -25-  
APPL NUMBER: 08-50019481 CP NEW RESIDENTIAL (SFD)

SUBDIV: MAGNOLIA CREST 29LOTS  
PHONE : (919) 524-2915  
PHONE : (919) 524-2915

STRUCTURE: 000 000 61X60 3BR CRAWL W/GARAGE & DECK  
FLOOD ZONE . . . . : FLOOD ZONE X

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	4/04/08 <u>4408</u>	TI <u>ABS</u>	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001588458

COMMENTS AND NOTES

-----  
ADDRESS . : 50 ALBAN ROW SUBDIV: MAGNOLIA CREST 29LOTS  
CONTRACTOR : DAIL BUILDERS INC PHONE : (919) 524-2915  
OWNER . . : DAIL BUILDERS INC #24 PHONE : (919) 524-2915  
PARCEL . . : 08-0655- - -0067- -25-  
APPL NUMBER: 08-50019481 CP NEW RESIDENTIAL (SFD)  
-----

STRUCTURE: 000 000 61X60 3BR CRAWL W/GARAGE & DECK  
FLOOD ZONE . . . . : FLOOD ZONE X  
-----

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	4/04/08	BS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001588458
	4/04/08	AP	
A814 01	4/11/08	TI	ADDRESS CONFIRMATION VRU #: 001591833
B103 01	4/11/08	TI	R*BLDG FOUND & TEMP SVC POLE VRU #: 001591841

*AP-MR*

----- COMMENTS AND NOTES -----

ADDRESS : 50 ALBAN ROW  
CONTRACTOR : DAIL BUILDERS INC  
OWNER : DAIL BUILDERS INC #24  
PARCEL : 08-0655- - -0067- -25-  
APPL NUMBER: 08-50019481 CP NEW RESIDENTIAL (SFD)

SUBDIV: MAGNOLIA CREST 29LOTS  
PHONE : (919) 524-2915  
PHONE : (919) 524-2915

STRUCTURE: 000 000 61X60 3BR CRAWL W/GARAGE & DECK  
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	4/04/08 4/04/08	BS AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001588458
B103 01	4/11/08 4/11/08	MR AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001591841
A814 01	4/11/08 4/11/08	TI AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001591833 50 alban row lot 24
B105 01	4/18/08 4/18/08	BS AE	R*OPEN FLOOR VRU #: 001595560 Brick up vents at cantilever on front. ok to cover, check at rough in
E207 01	5/30/08 <u>5-30-08</u>	TI <u>AP</u>	R*ELEC TEMP SERVICE POLE TIME: 17:00 VRU #: 001617125 PREMISE # 54397615 *****

COMMENTS AND NOTES

ADDRESS : 50 ALBAN ROW SUBDIV: MAGNOLIA CREST 29LOTS  
CONTRACTOR : DAIL BUILDERS INC PHONE : (919) 524-2915  
OWNER : DAIL BUILDERS INC #24 PHONE : (919) 524-2915  
PARCEL : 08-0655- - -0067- -25-  
APPL NUMBER: 08-50019481 CP NEW RESIDENTIAL (SFD)

STRUCTURE: 000 000 61X60 3BR CRAWL W/GARAGE & DECK  
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	4/04/08 4/04/08	BS AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001588458
B103 01	4/11/08 4/11/08	MR AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001591841
A814 01	4/11/08 4/11/08	TI AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001591833 50 alban row lot 24
B105 01	4/18/08 4/18/08	BS AE	R*OPEN FLOOR VRU #: 001595560 Brick up vents at cantilever on front. ok to cover, check at rough in
E207 01	5/30/08 5/30/08	BS AP	R*ELEC TEMP SERVICE POLE TIME: 17:00 VRU #: 001617125 PREMISE #. 54397615 *****
R427 01	6/11/08 <u>6-11-08</u>	TI <u>APB</u>	FOUR TRADE ROUGH IN >2500 VRU #: 001623842

----- COMMENTS AND NOTES -----

ADDRESS : 50 ALBAN ROW SUBDIV: MAGNOLIA CREST 29LOTS  
 CONTRACTOR : DAIL BUILDERS INC PHONE : (919) 524-2915  
 OWNER : DAIL BUILDERS INC #24 PHONE : (919) 524-2915  
 PARCEL : 08-0655- - -0067- -25-  
 APPL NUMBER: 08-50019481 CP NEW RESIDENTIAL (SFD)

STRUCTURE: 000 000 61X60 3BR CRAWL W/GARAGE & DECK  
 FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	4/04/08	BS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001588458
	4/04/08	AP	
B103 01	4/11/08	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 001591841
	4/11/08	AP	
A814 01	4/11/08	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001591833
	4/11/08	AP	50 alban row lot 24
B105 01	4/18/08	BS	R*OPEN FLOOR VRU #: 001595560
	4/18/08	AE	Brick up vents at cantilever on front. ok to cover, check at rough in
E207 01	5/30/08	BS	R*ELEC TEMP SERVICE POLE TIME: 17:00 VRU #: 001617125
	5/30/08	AP	PREMISE # 54397615 *****
R427 01	6/11/08	BS	FOUR TRADE ROUGH IN >2500 VRU #: 001623842
	6/11/08	AP	
I129 01	6/16/08	TI	R*INSULATION INSPECTION VRU #: 001625888
	<u>6-16-08</u>	<u>AOR</u>	

COMMENTS AND NOTES

ADDRESS : 50 ALBAN ROW  
 CONTRACTOR : FRED PUGH BUILDER, LLC  
 OWNER : CRESCENT STATE BANK  
 PARCEL : 08-0655- - -0067- -25-  
 APPL NUMBER: 08-50019481 CP NEW RESIDENTIAL (SFD)

SUBDIV: MAGNOLIA CREST 29LOTS  
 PHONE : (919) 625-0413  
 PHONE :

**STRUCTURE: 000 000 61X60 3BR CRAWL W/GARAGE & DECK**

FLOOD ZONE : FLOOD ZONE X  
 # BEDROOMS : 3.00 PROPOSED USE : SFD  
 SEPTIC - EXISTING? : NEW

**PERMIT: CPSF 00 CP \* SFD**

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	4/04/08	BS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001588458
	4/04/08	AP	
B103 01	4/11/08	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 001591841
	4/11/08	AP	
A814 01	4/11/08	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001591833
	4/11/08	AP	50 alban row lot 24
B105 01	4/18/08	BS	R*OPEN FLOOR VRU #: 001595560
	4/18/08	AE	Brick up vents at cantilever on front. ok to cover, check at rough in
E207 01	5/30/08	BS	R*ELEC TEMP SERVICE POLE TIME: 17:00 VRU #: 001617125
	5/30/08	AP	PREMISE # 54397615 *****
R427 01	6/11/08	BS	FOUR TRADE ROUGH IN >2500 VRU #: 001623842
	6/11/08	AP	
I129 01	6/16/08	BS	R*INSULATION INSPECTION VRU #: 001625888
	6/16/08	AP	
H824 01	9/16/08	JM	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001678358
	9/16/08	AP	
R431 01	5/11/09	TI	FOUR TRADE FINAL >2500 TIME: 17:00 VRU #: 001766070

5-11-09 DPBS

COMMENTS AND NOTES

ADDRESS : 50 ALBAN ROW SUBDIV: MAGNOLIA CREST 29LOTS  
 CONTRACTOR : FRED PUGH BUILDER, LLC PHONE : (919) 625-0413  
 OWNER : CRESCENT STATE BANK PHONE :  
 PARCEL : 08-0655- -0067- -25-  
 APPL NUMBER: 08-50019481 CP NEW RESIDENTIAL (SFD)

STRUCTURE: 000 000 61X60 3BR CRAWL W/GARAGE & DECK  
 FLOOD ZONE : FLOOD ZONE X  
 # BEDROOMS : 3.00 PROPOSED USE : SFD  
 SEPTIC - EXISTING? : NEW

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	4/04/08	BS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001588458
	4/04/08	AP	
B103 01	4/11/08	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 001591841
	4/11/08	AP	
A814 01	4/11/08	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001591833
	4/11/08	AP	✓50 alban row lot 24
B105 01	4/18/08	BS	R*OPEN FLOOR VRU #: 001595560
	4/18/08	AE	Brick up vents at cantilever on front. ok to cover, check at rough in
E207 01	5/30/08	BS	R*ELEC TEMP SERVICE POLE TIME: 17:00 VRU #: 001617125
	5/30/08	AP	PREMISE # 54397615 *****
R427 01	6/11/08	BS	FOUR TRADE ROUGH IN >2500 VRU #: 001623842
	6/11/08	AP	
I129 01	6/16/08	BS	R*INSULATION INSPECTION VRU #: 001625888
	6/16/08	AP	
H824 01	9/16/08	JM	✓ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001678358
	9/16/08	AP	
R431 01	5/11/09	BS	FOUR TRADE FINAL >2500 TIME: 17:00 VRU #: 001766070
	5/11/09	DP	1. Windows over master tub must be marked tempered (etched in glass). Cannot use aftermarket films or other products 2. Sheetrock to a min of 36 inches high around open side of stairs at top. 3. Caulk all plumbing fixtures to floors/walls 4. plastic under house must be full coverage and all joints lapped 12 inches.
R431 02	5/13/09	TI	FOUR TRADE FINAL >2500 TIME: 17:00 VRU #: 001767250
	5-13-09	APBS	CUSTOMER REQUEST AM INSP. ALSO THE DOOR CODE LOCK BOX NUMBER IS RDM***** T/S: 05/12/2009 12:21 PM VBROWN

COMMENTS AND NOTES

