

HTE# 08-5-19553

Harnett County Department of Public Health 24565

Improvement Permit

A building permit cannot be issued with only an Improvement Permit

ISSUED TO: Joseph M. Gardner PROPERTY LOCATION: SR 1441
 NEW REPAIR EXPANSION SUBDIVISION: Dexterfield LOT # 48
 Type of Structure: SFD 50x54 Site Improvements required prior to Construction Authorization Issuance: _____
 Proposed Wastewater System Type: Pump to Accepted System
 Projected Daily Flow: 360 GPD
 Number of bedrooms: 3 Number of Occupants: 6 max
 Basement Yes No
 Pump Required: Yes No May be required based on final location and elevations of facilities
 Type of Water Supply: Community Public Well Distance from well _____ feet Permit valid for: Five years
 Permit conditions: _____ No expiration

Authorized State Agent: Bryan M. Jones, P.E. Date: 3/13/2008 SEE ATTACHED SITE SKETCH
 The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.

Construction Authorization

(Required for Building Permit)

The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout.

ISSUED TO: Joseph M. Gardner PROPERTY LOCATION: SR 1441
 SUBDIVISION: Dexterfield LOT # 48
 Facility Type: SFD 50x54 New Expansion Repair
 Basement? Yes No Basement Fixtures? Yes No
 Type of Wastewater System** Pump to Accepted System (Initial) Wastewater Flow: 360 GPD
 (See note below, if applicable
Pump to Accepted System (Repair)

Installation Requirements/Conditions

Septic Tank Size 1000 gallons Exact length of each trench 2x50 feet Trench Spacing: 9 Feet on Center
 Pump Tank Size 1000 gallons Trenches shall be installed on contour at a Soil Cover: 6-24 inches
 Maximum Trench Depth of: 18-36 inches (Maximum soil cover shall not exceed 36" above the trench bottom)
 (Trench bottoms shall be level to +/-1/4" in all directions)
 Pump Requirements: _____ ft. TDH vs. _____ GPM Aggregate Depth: _____ inches below pipe
 _____ inches above pipe
 _____ inches total

Conditions: Drain lines to be placed in Septic Easement, Water line will need to be left open to verify set back. Start line at 22" go 60ft. step down to 26" line.

**If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.
 Owner/Legal Representative Signature: _____ Date: _____

This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit.

Authorized State Agent: Bryan M. Jones, P.E. Date: 3/13/2008 SEE ATTACHED SITE SKETCH
 Construction Authorization Expiration Date: 3/13/2013

HTE# 08-5-19553

Permit # 24565

Harnett County Department of Public Health Site Sketch

ISSUED TO: Joseph M. Gardner

PROPERTY LOCATOR: SR 1441

SUBDIVISION Dexterfield

LOT # 48

Authorized State Agent:

Ryan McSwain, P.E.

Date: 3/12/2008

