
ADDRESS . : 54 WOODRIDGE CT SUBDIV: ROGER LARRY & BARBARA MILLER
CONTRACTOR : LIGHTHOUSE CUSTOM HOMES INC PHONE : (919) 553-4564
OWNER . . : MATTHEWS RAY J & JANIS R PHONE : (919) 331-4182
PARCEL . . : 04-0674- - -0042- -05-
APPL NUMBER: 08-50019558 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : 44 WOODRIDGE COURT, WOODRIDGE SEC 1 LOT
#3.
210 TO ANGIER, LEFT ON 55, LEFT ON
RAWLS CH RD, DEV IS 0.25 MI PAST
INTERSECTION WITH KENNEBEC CH RD ON
RIGHT

STRUCTURE: 000 000 45X60 3BDR 2.5BATH SFD
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	7/18/08 <u>7.18.08</u>	TI <u>APBS</u>	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001644517

----- COMMENTS AND NOTES -----

ADDRESS : 54 WOODRIDGE CT
CONTRACTOR : LIGHTHOUSE CUSTOM HOMES INC
OWNER : MATTHEWS RAY J & JANIS R
PARCEL : 04-0674- - -0042- -05-
APPL NUMBER: 08-50019558 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : 44 WOODRIDGE COURT, WOODRIDGE SEC 1 LOT
#3.
210 TO ANGIER, LEFT ON 55, LEFT ON
RAWLS CH RD, DEV IS 0.25 MI PAST
INTERSECTION WITH KENNEBEC CH RD ON
RIGHT

SUBDIV: ROGER LARRY & BARBARA MILLER
PHONE : (919) 553-4564
PHONE : (919) 331-4182

STRUCTURE: 000 000 45X60 3BDR 2.5BATH SFD
FLOOD ZONE . . . : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	7/18/08	BS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001644517
	7/18/08	AP	
B103 01	7/24/08	BS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001647619
	7/24/08	AP	
A814 01	7/24/08	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001647601
	7/24/08	AP	54 WOODRIDGE CT LOT 3 # BY DRIVE & ON HOUSE
B105 01	7/30/08	TI	R*OPEN FLOOR VRU #: 001651554
	<u>7-30-08</u>	<u>APBS</u>	

COMMENTS AND NOTES

ADDRESS : 54 WOODRIDGE CT SUBDIV: ROGER LARRY & BARBARA MILLER
CONTRACTOR : LIGHTHOUSE CUSTOM HOMES INC PHONE : (919) 553-4564
OWNER : MATTHEWS RAY J & JANIS R PHONE : (919) 331-4182
PARCEL : 04-0674- - -0042- -05-
APPL NUMBER: 08-50019558 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : 44 WOODRIDGE COURT, WOODRIDGE SEC 1 LOT
#3.
210 TO ANGIER, LEFT ON 55, LEFT ON
RAWLS CH RD, DEV IS 0.25 MI PAST
INTERSECTION WITH KENNEBEC CH RD ON
RIGHT

STRUCTURE: 000 000 45X60 3BDR 2.5BATH SFD
FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3.00 PROPOSED USE : SFD
SEPTIC - EXISTING? : NEW SEPTIC

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	7/18/08	BS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001644517
	7/18/08	AP	
B103 01	7/24/08	BS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001647619
	7/24/08	AP	
A814 01	7/24/08	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001647601
	7/24/08	AP	54 WOODRIDGE CT LOT 3 # BY DRIVE & ON HOUSE
B105 01	7/30/08	BS	R*OPEN FLOOR VRU #: 001651554
	7/30/08	AP	
R427 01	9/19/08	TI	FOUR TRADE ROUGH IN >2500 VRU #: 001679767
	9-19-08	DARS	VOICE MESSAGE LEFT

----- COMMENTS AND NOTES -----

ADDRESS : 54 WOODRIDGE CT SUBDIV: ROGER LARRY & BARBARA MILLER
 CONTRACTOR : LIGHTHOUSE CUSTOM HOMES INC PHONE : (919) 553-4564
 OWNER : MATTHEWS RAY J & JANIS R PHONE : (919) 331-4182
 PARCEL : 04-0674- - -0042- -05-
 APPL NUMBER: 08-50019558 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : 44 WOODRIDGE COURT, WOODRIDGE SEC 1 LOT
 #3.
 210 TO ANGIER, LEFT ON 55, LEFT ON
 RAWLS CH RD, DEV IS 0.25 MI PAST
 INTERSECTION WITH KENNEBEC CH RD ON
 RIGHT

STRUCTURE: 000 000 45X60 3BDR 2.5BATH SFD
 FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW SEPTIC

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	7/18/08	BS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001644517
	7/18/08	AP	
B103 01	7/24/08	BS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001647619
	7/24/08	AP	
A814 01	7/24/08	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001647601
	7/24/08	AP	54 WOODRIDGE CT LOT 3 # BY DRIVE & ON HOUSE
B105 01	7/30/08	BS	R*OPEN FLOOR VRU #: 001651554
	7/30/08	AP	
R427 01	9/19/08	BS	FOUR TRADE ROUGH IN >2500 VRU #: 001679767
	9/19/08	DA	VOICE MESSAGE LEFT 1. Change fixture box over garage to metal. Make sure it is fastened to framing when installed in final location . 2. Sheet garage walls w/ osb per plan 3. SE wire feeding panel must be concealed in stud wall to exterior, or change to 4 wire wth outside main. 4.Oval window in stairway must be tempered (before final) 5. Rodent proof tub drain in master with sheetmetal and firecaulk. 6. No water in standpipe. OK TO SIDE/INSULATE
I129 01	9/26/08	TI	R*INSULATION INSPECTION VRU #: 001683002
	9-26-08	APBS	
R427 02	9/26/08	TI	FOUR TRADE ROUGH IN >2500 VRU #: 001682995
			VOICE MESSAGE LEFT

COMMENTS AND NOTES

ADDRESS : 54 WOODRIDGE CT
CONTRACTOR : LIGHTHOUSE CUSTOM HOMES INC
OWNER : MATTHEWS RAY J & JANIS R
PARCEL : 04-0674- - -0042- -05-
APPL NUMBER: 08-50019558 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : 44 WOODRIDGE COURT, WOODRIDGE SEC 1 LOT #3.
210 TO ANGIER, LEFT ON 55, LEFT ON RAWLS CH RD, DEV IS 0.25 MI PAST INTERSECTION WITH KENNEBEC CH RD ON RIGHT

SUBDIV: ROGER LARRY & BARBARA MILLER
PHONE : (919) 553-4564
PHONE : (919) 331-4182

STRUCTURE: 000 000 45X60 3BDR 2.5BATH SFD

FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3.00 PROPOSED USE : SFD
SEPTIC - EXISTING? : NEW SEPTIC

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	7/18/08	BS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001644517
	7/18/08	AP	
B103 01	7/24/08	BS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001647619
	7/24/08	AP	
A814 01	7/24/08	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001647601
	7/24/08	AP	✓ 54 WOODRIDGE CT LOT 3 # BY DRIVE & ON HOUSE
B105 01	7/30/08	BS	R*OPEN FLOOR VRU #: 001651554
	7/30/08	AP	
R427 01	9/19/08	BS	FOUR TRADE ROUGH IN >2500 VRU #: 001679767
	9/19/08	DA	VOICE MESSAGE LEFT 1. Change fixture box over garage to metal. Make sure it is fastened to framing when installed in final location . 2. Sheet garage walls w/ osb per plan 3. SE wire feeding panel must be concealed in stud wall to exterior, or change to 4 wire wth outside main. 4.Oval window in stairway must be tempered (before final) 5. Rodent proof tub drain in master with sheetmetal and firecaulk. 6. No water in standpipe. OK TO SIDE/INSULATE
I129 01	9/26/08	BS	R*INSULATION INSPECTION VRU #: 001683002
	9/26/08	AP	
R427 02	9/26/08	BS	FOUR TRADE ROUGH IN >2500 VRU #: 001682995
	9/26/08	AP	VOICE MESSAGE LEFT
H824 01	11/23/08	JM	✓ ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001710540
	11/23/08	AP	
P307 01	12/08/08	TI	R*PLUMB WATER CONNECTION TIME: 17:00 VRU #: 001713957
	12/04/08	CA	
R431 01	12/12/08	TI	FOUR TRADE FINAL >2500 VRU #: 001716361
	12-12	AP	

9795.1614

COMMENTS AND NOTES

**COUNTY OF HARNETT
DEPARTMENT OF BUILDING INSPECTION
AND PLANNING/DEVELOPMENT
CERTIFICATE OF OCCUPANCY**

This certificate issued pursuant to the requirements of Section 105 of the North Carolina State Building Code and the Harnett County Zoning Ordinance certifies at the time of issuance this structure was in compliance with the various ordinances of the County of Harnett regulating development and building construction or use. For the following:

Use Classification: Residential

PERMIT NUMBERS

Owner: Lighthouse Custora Home

Building Permit No.: _____

911 Address: _____

Electrical Permit No.: _____

54 Woodridge Ct.

Insulation Permit No.: _____

Plumbing Permit No.: _____

State: _____ Zip Code: _____

Mech. Permit No.: _____

MFG. Home: _____

Date: 12-12-08

K. Slath

Building Official

08-500-1955