

HTE# 08-500-19615

Harlan County Department of Public Health

24675

Improvement Permit

A building permit cannot be issued with only an Improvement Permit

ISSUED TO: Cumberland Home PROPERTY LOCATION: 1125
NEW REPAIR EXPANSION SUBDIVISION: Woodshire LOT # 158

Type of Structure: SFD-56x36-3BR
Proposed Wastewater System Type: Pump to 25% Red. sys.
Projected Daily Flow: 360 GPD
Number of bedrooms: 3 Number of Occupants: 6 max

Basement Yes No
Pump Required: Yes No May be required based on final location and elevations of facilities
Type of Water Supply: Community Public Well Distance from well 50 feet Permit valid for: Five years
Permit conditions: Meet on site for final layout maintain all set backs No expiration
STUB OUT PLUMBING shall be at ground level or higher where shown
and pump may not be required

Authorized State Agent: J. L. W. R. I. Date: 03-27-08 SEE ATTACHED SITE SKETCH
The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.

Construction Authorization

(Required for Building Permit)

The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout.

ISSUED TO: Cumberland Home PROPERTY LOCATION: 1125
SUBDIVISION: Woodshire LOT # 158

Facility Type: SFD-56x36-3BR New Expansion Repair
Basement? Yes No Basement Fixtures? Yes No
Type of Wastewater System** Pump to 25% Red. sys. (Initial) Wastewater Flow: 360 GPD
(See note below, if applicable) 25% Reduction system (Repair)

Installation Requirements/Conditions

Septic Tank Size 1000 gallons Exact length of each trench 1x150 feet Trench Spacing: 9 Feet on Center
Pump Tank Size 1000 gallons Trenches shall be installed on contour at a Soil Cover: 6 inches
if needed Maximum Trench Depth of: 18-24 inches (Maximum soil cover shall not exceed 36" above the trench bottom)
Pump Requirements: _____ ft. TDH vs. _____ GPM Aggregate Depth: _____ inches below pipe
Conditions: _____ inches above pipe
_____ inches total

**If applicable: *I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.*

Owner/Legal Representative Signature: _____ Date: _____

This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit.

Authorized State Agent: J. L. W. R. I. Date: 03-27-08 SEE ATTACHED SITE SKETCH
Construction Authorization Expiration Date: 03-27-2013

HTE# 08-500 19615

Permit # 24675

Harnett County Department of Public Health Site Sketch

ISSUED TO: Cumberland Homes PROPERTY LOCATOR: 1125
SUBDIVISION Woodshire LOT # 158

Authorized State Agent: Joe Laro Date: 03-27-08

Meet onsite
 Maintain all
 Set Backs
 STUB out Plumbing
 Shallow, At ground
 Level or higher
 Where shown incl
 IF 18 to 24" Ditch
 Depth can be maintained
 Pump may not be required
 Install 1x150 1/2 25%
 Reduction system At
 18 to 24" Deep.

