
ADDRESS . . : 675 COKESBURY PARK LN SUBDIV: COKESBURY PARK
 CONTRACTOR : STANCIL BUILDERS INC. PHONE : (919) 639-2073
 OWNER . . : DUNCAN DEVELOPMENT LLC #57 PHONE :
 PARCEL . . : 05-0635- - -0124- -19-
 APPL NUMBER: 08-50019733 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : COKESBURY PARK III #57.
 HWY 401N TO CHRISTIAN LIGHT RD, TO
 COKESBURY RD, TO COKESBURY PARK SUB DIV
 ON RIGHT.
 T/S: 03/25/2008 04:21 PM VBROWN ----
 *****PREMISE NO. 83652683*****
 T/S: 07/28/2008 08:24 AM DJOHNSON --

STRUCTURE: 000 000 59X53 3BDR 2BATH SFD
 FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW SEPTIC

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	7/29/08 <u>7-29-08</u>	TI <u>APBS</u>	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001650373 PLEASE INSPECT TSP ALSO.

----- COMMENTS AND NOTES -----

ADDRESS . : 675 COKESBURY PARK LN SUBDIV: COKESBURY PARK
 CONTRACTOR : STANCIL BUILDERS INC. PHONE : (919) 639-2073
 OWNER . . : DUNCAN DEVELOPMENT LLC #57 PHONE :
 PARCEL . . : 05-0635- - -0124- -19-
 APPL NUMBER: 08-50019733 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : COKESBURY PARK III #57.
 HWY 401N TO CHRISTIAN LIGHT RD, TO
 COKESBURY RD, TO COKESBURY PARK SUB DIV
 ON RIGHT.
 T/S: 03/25/2008 04:21 PM VBROWN ----
 *****PREMISE NO. 83652683*****
 T/S: 07/28/2008 08:24 AM DJOHNSON --

STRUCTURE: 000 000 59X53 3BDR 2BATH SFD
 FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	7/29/08	BS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001650373
	7/29/08	AP	PLEASE INSPECT TSP ALSO.
A814 01	8/12/08	TI	ADDRESS CONFIRMATION VRU #: 001660117
B103 01	8/12/08 <i>8.12.08</i>	TI <i>APB</i>	R*BLDG FOUND & TEMP SVC POLE VRU #: 001660125

----- COMMENTS AND NOTES -----

ADDRESS : 675 COKESBURY PARK LN
CONTRACTOR : STANCIL BUILDERS INC.
OWNER : DUNCAN DEVELOPMENT LLC #57
PARCEL : 05-0635- - -0124- -19-
APPL NUMBER: 08-50019733 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : COKESBURY PARK III #57.
HWY 401N TO CHRISTIAN LIGHT RD, TO
COKESBURY RD, TO COKESBURY PARK SUB DIV
ON RIGHT.
T/S: 03/25/2008 04:21 PM VBROWN ----
*****PREMISE NO. 83652683*****
T/S: 07/28/2008 08:24 AM DJOHNSON --

SUBDIV: COKESBURY PARK
PHONE : (919) 639-2073
PHONE :

STRUCTURE: 000 000 59X53 3BDR 2BATH SFD
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	7/29/08	BS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001650373
	7/29/08	AP	PLEASE INSPECT TSP ALSO.
B103 01	8/12/08	BS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001660125
	8/13/08	AP	
A814 01	8/12/08	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001660117
	8/12/08	AP	675 COKESBURY PARK LN LOT 57
B105 01	8/18/08	TI	R*OPEN FLOOR VRU #: 001662832
	<u>8-18-08</u>	<u>APR</u>	

COMMENTS AND NOTES

ADDRESS : 675 COKESBURY PARK LN SUBDIV: COKESBURY PARK
CONTRACTOR : STANCIL BUILDERS INC. PHONE : (919) 639-2073
OWNER : DUNCAN DEVELOPMENT LLC #57 PHONE :
PARCEL : 05-0635- - -0124- -19-
APPL NUMBER: 08-50019733 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : COKESBURY PARK III #57.
HWY 401N TO CHRISTIAN LIGHT RD, TO
COKESBURY RD, TO COKESBURY PARK SUB DIV
ON RIGHT.
T/S: 03/25/2008 04:21 PM VBROWN ----
*****PREMISE NO. 83652683*****
T/S: 07/28/2008 08:24 AM DJOHNSON --

STRUCTURE: 000 000 59X53 3BDR 2BATH SFD
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	7/29/08	BS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001650373
	7/29/08	AP	PLEASE INSPECT TSP ALSO.
B103 01	8/12/08	BS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001660125
	8/13/08	AP	
A814 01	8/12/08	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001660117
	8/12/08	AP	675 COKESBURY PARK LN LOT 57
B105 01	8/18/08	BS	R*OPEN FLOOR VRU #: 001662832
	8/18/08	AP	
R425 01	9/02/08	TI	FOUR TRADE ROUGH IN VRU #: 001669910
	<u>9-2-08</u>	<u>DPBS</u>	

----- COMMENTS AND NOTES -----

ADDRESS . : 675 COKESBURY PARK LN SUBDIV: COKESBURY PARK
 CONTRACTOR : STANCIL BUILDERS INC. PHONE : (919) 639-2073
 OWNER . . : DUNCAN DEVELOPMENT LLC #57 PHONE :
 PARCEL . . : 05-0635- - -0124- -19-
 APPL NUMBER: 08-50019733 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : COKESBURY PARK III #57.
 HWY 401N TO CHRISTIAN LIGHT RD, TO
 COKESBURY RD, TO COKESBURY PARK SUB DIV
 ON RIGHT.
 T/S: 03/25/2008 04:21 PM VBROWN ----
 *****PREMISE NO. 83652683*****
 T/S: 07/28/2008 08:24 AM DJOHNSON --

STRUCTURE: 000 000 59X53 3BDR 2BATH SFD.
 FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW SEPTIC

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	7/29/08	BS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001650373
	7/29/08	AP	PLEASE INSPECT TSP ALSO.
B103 01	8/12/08	BS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001660125
	8/13/08	AP	
A814 01	8/12/08	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001660117
	8/12/08	AP	675 COKESBURY PARK LN LOT 57
B105 01	8/18/08	BS	R*OPEN FLOOR VRU #: 001662832
	8/18/08	AP	
R425 01	9/02/08	BS	FOUR TRADE ROUGH IN VRU #: 001669910
	9/02/08	DP	1. No firestop. 2. No baffles. 3. No roof boots installed. House not ready. 4. Insulate trap and water lines in garage ceiling from top plate to above insulation level. \$50 re fee
R425 02	9/04/08 <i>9-4-08</i>	TI <i>DABS</i>	FOUR TRADE ROUGH IN VRU #: 001671007

----- COMMENTS AND NOTES -----

ADDRESS : 675 COKESBURY PARK LN SUBDIV: COKESBURY PARK
 CONTRACTOR : STANCIL BUILDERS INC. PHONE : (919) 639-2073
 OWNER : DUNCAN DEVELOPMENT LLC #57 PHONE :
 PARCEL : 05-0635- - -0124- -19-
 APPL NUMBER: 08-50019733 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : COKESBURY PARK III #57.
 HWY 401N TO CHRISTIAN LIGHT RD, TO
 COKESBURY RD, TO COKESBURY PARK SUB DIV
 ON RIGHT.
 T/S: 03/25/2008 04:21 PM VBROWN ----
 *****PREMISE NO. 83652683*****
 T/S: 07/28/2008 08:24 AM DJOHNSON --

STRUCTURE: 000 000 59X53 3BDR 2BATH SFD
 FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW SEPTIC

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	7/29/08	BS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001650373
	7/29/08	AP	PLEASE INSPECT TSP ALSO.
B103 01	8/12/08	BS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001660125
	8/13/08	AP	
A814 01	8/12/08	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001660117
	8/12/08	AP	675 COKESBURY PARK LN LOT 57
B105 01	8/18/08	BS	R*OPEN FLOOR VRU #: 001662832
	8/18/08	AP	
R425 01	9/02/08	BS	FOUR TRADE ROUGH IN VRU #: 001669910
	9/02/08	DP	1. No firestop. 2. No baffles. 3. No roof boots installed. House not ready. 4. Insulate trap and water lines in garage ceiling from top plate to above insulation level. \$50 re fee
R425 02	9/04/08	BS	FOUR TRADE ROUGH IN VRU #: 001671007
	9/04/08	DA	1. No water on drain test standpipe 2. Seal floor joists where "panned" for return air (before final) OK TO SIDE/INSULATE
I129 01	9/10/08	TI	R*INSULATION INSPECTION VRU #: 001674431
	9/09/08	CA	
I129 02	9/11/08	TI	R*INSULATION INSPECTION VRU #: 001674449
R425 03	9/11/08	TI	FOUR TRADE ROUGH IN VRU #: 001674464

----- COMMENTS AND NOTES -----

ADDRESS : 675 COKESBURY PARK LN SUBDIV: COKESBURY PARK
 CONTRACTOR : STANCIL BUILDERS INC. PHONE : (919) 639-2073
 OWNER : DUNCAN DEVELOPMENT LLC #57 PHONE :
 PARCEL : 05-0635- - -0124- -19-
 APPL NUMBER: 08-50019733 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : COKESBURY PARK III #57.
 HWY 401N TO CHRISTIAN LIGHT RD, TO
 COKESBURY RD, TO COKESBURY PARK SUB DIV
 ON RIGHT.
 T/S: 03/25/2008 04:21 PM VBROWN ----
 *****PREMISE NO. 83652683*****
 T/S: 07/28/2008 08:24 AM DJOHNSON --

STRUCTURE: 000 000 59X53 3BDR 2BATH SFD
 FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW SEPTIC

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	7/29/08	BS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001650373
	7/29/08	AP	PLEASE INSPECT TSP ALSO.
B103 01	8/12/08	BS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001660125
	8/13/08	AP	
A814 01	8/12/08	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001660117
	8/12/08	AP	✓ 675 COKESBURY PARK LN LOT 57
B105 01	8/18/08	BS	R*OPEN FLOOR VRU #: 001662832
	8/18/08	AP	
R425 01	9/02/08	BS	FOUR TRADE ROUGH IN VRU #: 001669910
	9/02/08	DP	1. No firestop. 2. No baffles. 3. No roof boots installed. House not ready. 4. Insulate trap and water lines in garage ceiling from top plate to above insulation level. \$50 re fee.
R425 02	9/04/08	BS	FOUR TRADE ROUGH IN VRU #: 001671007
	9/04/08	DA	1. No water on drain test standpipe 2. Seal floor joists where "panned" for return air (before final) OK TO SIDE/INSULATE
I129 01	9/10/08	TI	R*INSULATION INSPECTION VRU #: 001674431
	9/09/08	CA	
I129 02	9/11/08	BS	R*INSULATION INSPECTION VRU #: 001674449
	9/11/08	AP	
R425 03	9/11/08	BS	FOUR TRADE ROUGH IN VRU #: 001674464
	9/11/08	AP	
H824 01	10/08/08	JM	✓ ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001690213
	10/08/08	AP	
R429 01	10/13/08	TI	FOUR TRADE FINAL VRU #: 001690734

10-13-08 APBS

COMMENTS AND NOTES

**COUNTY OF HARNETT
DEPARTMENT OF BUILDING INSPECTION
AND PLANNING/DEVELOPMENT
CERTIFICATE OF OCCUPANCY**

This certificate issued pursuant to the requirements of Section 105 of the North Carolina State Building Code and the Harnett County Zoning Ordinance certifies at the time of issuance this structure was in compliance with the various ordinances of the County of Harnett regulating development and building construction or use. For the following:

Use Classification: SFD

Owner: Stewart Builders

911 Address: 1075 Cokesburg Pl LN

State: NC Zip Code: _____

Date: 10-13-08

Brad Sutton

Building Official

PERMIT NUMBERS

Building Permit No.: _____

Electrical Permit No.: _____

Insulation Permit No.: _____

Plumbing Permit No.: _____

Mech. Permit No.: _____

MFG. Home: _____

08-5-19-733