## HTE# 08-5-19733R Harnett County Department of Public Health

24804

## **Improvement Permit** A building permit cannot be issued with only an Improvement Permit

ISSUED TO: STANCE | BUEIDERS INC SUBDIVISION Cokes bury Roberty LOCATION: 51/403 Cokes bury Rob

NEW REPAIR | EXPANSION | Site Improvements required prior to Construction Authorization Issuance: Type of Structure: 5FD Proposed Wastewater System Type: 2590 RESULTIVE Projected Daily Flow: 360 GPD

Number of bedrooms: 3 Number of Occupants: 6 max Pump Required: Tes No May be required based on final location and elevations of facilities Type of Water Supply: 

Community Public Well Distance from well feet Permit valid for: Permit conditions: ☐ No expiration Authorized State Agent: Date: 6-6-08 SEE ATTACHED SITE SKETCH

The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit. Construction Authorization (Required for Building Permit) The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout. PROPERTY LOCATION: Sr. 1403 Cokes bury CS

SUBDIVISION Cokes bury Park

New Expansion Repair

Basement Fixtures? Yes No ISSUED TO: STANCE I BUILDERS INC Basement? Yes No Type of Wastewater System\*\* ZSOBREDUCTION System (Initial) Wastewater Flow: 360 GPD (See note below, if applicable []) (See note below, if applicable 

) 25% REDUCTION System (Repair)

Number of trenches 3 Installation Requirements/Conditions Septic Tank Size 1000 gallons Pump Tank Size \_\_\_\_\_ gallons Maximum Trench Depth of: 28-218 inches (Maximum soil cover shall not exceed (Trench bottoms shall be level to +/-1/4" 36" above the trench bottom) in all directions) Pump Requirements: \_\_\_\_\_ft. TDH vs. \_\_\_\_GPM \*\*If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit. Owner/Legal Representative Signature: This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit. Date: 6-6-08

Construction Authorization Expiration Date: 6-6-13

HTE# <u>08-5-19733R</u>

Permit # <u>24804</u>

## Harnett County Department of Public Health Site Sketch

PROPERTY LOCATON: 51/403 Cokesbury RD

ISSUED TO: STANCI BUILDERS INC SUBDIVISION Cokesbury Pank LOT # 57

Authorized State Agent American Date: 6-6-08

