

Property ID:
 Lot #:
 File #:
 Code:

**SOIL/SITE EVALUATION
 for ON-SITE WASTEWATER SYSTEM**

Owner:

Applicant: **19733**

Address:

Date Evaluated: **5-15-08**

Proposed Facility: **SFP**

Design Flow (.1949): **360**

Property Size:

Location of Site:

Property Recorded:

Water Supply: Public Individual Well Spring Other

Evaluation Method: Auger Boring Pit Cut

Type of Wastewater: Sewage Industrial Process Mixed

P R O F I L E #	.1940 Landscape Position/ Slope%	Horizon Depth (IN.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1	L 7%	0-44	SL	FR GR NSNP					. 4
		44-48	SCL	2 ^{1/2} Prm / 5 ^{1/2} Gr S.P.					
2	L 6%	0-36	SL	FR GR NSNP					. 4
		36-48	SCL	2 ^{1/2} Prm / 5 ^{1/2} Gr S.P.	44" to Prm	44"		Prm	
3	L 7%	0-24	SL	FR GR NSNP.					. 4
		24-44	SCL	2 ^{1/2} Prm / 5 ^{1/2} Gr S.P.	42" 2.5% 42"				

Description	Initial System	Repair System
Available Space (.1945)	/	/
System Type(s)	25 ⁰⁰	28 ⁰⁰
Site LTAR	. 4	. 4

Other Factors (.1946): _____
 Site Classification (.1948): **28**
 Evaluated By: **[Signature]**
 Others Present: