

**SOIL/SITE EVALUATION
 for ON-SITE WASTEWATER SYSTEM**

Owner: 08-500-19795R

Applicant:

Address:

Date Evaluated:

Proposed Facility: SFA
 Location of Site: Nr 2

Design Flow (.1949): 36

Property Size:

Property Recorded:

Water Supply: Public [] Individual [] Well [] Spring [] Other
 Evaluation Method: [] Auger Boring Pit [] Cut
 Type of Wastewater: Sewage [] Industrial Process [] Mixed

P R O F I L E #	.1940 Landscape Position/ Slope%	Horizon Depth (IN.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
S 3/		0-20	Gn SL	VFA J=					4
		20-25	SFA SL	FA J=					4
		0-28	Gn SL	VFA J=					4
		28-30	SFA SL	FA J=					4
		0-30	Gn SL	VFA J=					4
		30-35	SFA SL	FA J=					4
		0-12	Gn SL	VFA J=					Dry
		12-26	SFA SL	FA J=	CG 22				
		0-12	Gn SL	VFA J=					Dry
		12-26	SFA SL	FA J=					
		0-12	Gn SL	VFA J=					Dry
		12-26	SFA SL	FA J=	CG 22				

Description	Initial System	Repair System
Available Space (.1945)	-	
System Type(s)	25%	Dry
Site LTAR	.4	.

Other Factors (.1946): _____
 Site Classification (.1948): P1
 Evaluated By: GV
 Others Present: CG 70 MG


COMMENTS: _____

<u>LANDSCAPE POSITIONS</u>	<u>GROUP</u>	<u>TEXTURES</u>	<u>.1955 LTAR</u>	<u>CONSISTENCE MOIST</u>	<u>WET</u>
R-RIDGE	I	S-SAND	1.2 - 0.8	VFR-VERY FRIABLE	NS-NON-STICKY
S-SHOULDER SLOPE		LS-LOAMY SAND			
L-LINEAR SLOPE	II	SL-SANDY LOAM	0.8 - 0.6	FR-FRIABLE	SS-SLIGHTLY STICKY
FS-FOOT SLOPE		L-LOAM			
N-NOSE SLOPE	III	SI-SILT-	0.6 - 0.3	FI-FIRM	S-STICKY
H-HEAD SLOPE		SIL-SILT LOAM			
CC-CONCLAVE SLOPE		CL-CLAY LOAM			
CV-CONVEX SLOPE		SCL-SANDY CLAY LOAM			
T-TERRACE		SIC-SILTY CLAY			
FP-FLOOD PLAN	IV	C-CLAY	0.4 - 0.1	EFI-EXTREMELY FIRM	VS-VERY STICKY
		SC-SANDY CLAY			NP-NON-PLASTIC
					SP-SLIGHTLY STICKY
					P-PLASTIC
					VP-VERY PLASTIC

STRUCTURE
 SG-SINGLE GRAIN
 M-MASSIVE
 CR-CRUMB
 GR-GRANULAR
 SBK-SUBANGULAR BLOCKY
 ABK-ANGULAR BLOCKY
 PL-PLATY
 PR-PRISMATIC

MINERALOGY
 SLIGHTLY EXPANSIVE
 EXPANSIVE

Show profile locations and other site features (dimensions, reference or benchmark, and North).



S21°07'49"E 134.12

117.19


(11)

(10)

N78°11'20"E
242.95

N65°07'35"E
233.88

(12)



SWORD LOOP
50' PUBLIC R/W

Revised

SITE PLAN APPROVAL
DISTRICT *LA202* USE *SFD*

4.3.08
ZONING A...STATOR

OTHER SOURCES PROVIDED BY THE OWNER. THIS IS A PRELIMINARY SITE PLAN, INTENDED FOR PLANNING USE ONLY AND IN NO WAY REPRESENTS A SURVEY MADE BY THIS COMPANY. THIS MAP IS NOT INTENDED FOR RECORDATION, CONVEYANCES, OR SALES.

Charlie T. Carpenter, P.L.S.
Professional Land Surveyor
1940 Juniper Church Road
Four Oaks, NC 27524
(919) 963-2909
(919) 320-5281



PRELIMINARY SITE PLAN FOR:
WYNN CONSTRUCTION

PIN 9597-26-9031.000
PARCEL ID 039576 0088 11
LOT 11 TINGEN POINTE S/D
PB2007 PG711-718
5/30/08
1"=40'

178 SWORD LOOP
BROADWAY, NC 27505