

**SOIL/SITE EVALUATION
 for ON-SITE WASTEWATER SYSTEM**

Owner: 06.500 19798

Applicant:

Address:

Date Evaluated:

Proposed Facility: 3 FD

Design Flow (.1949): 36

Property Size:

Location of Site: NC 27

Property Recorded:

Water Supply: Public Individual Well

Spring Other

Evaluation Method: Auger Boring Pit

Cut

Type of Wastewater: Sewage Industrial Process

Mixed

P R O F I L E #	.1940 Landscape Position/ Slope%	Horizon Depth (IN.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
S 3%		0Y	GR SL	VFA SE					UP .3
		8-12	SPK SCL	FA SE					
		12-26	SPK SC	FA SE					
		026	GR SL	VFA SE					.5
		26-48	SPK SCL	FA SE					
		030	GR SL	VFA SE					.5
		30-38	SPK SCL	FA SE					
		030	GR SL	VFA SE					.5
		30-38	SPK SCL	FA SE					
		030	GR SL	VFA SE					.5
		30-38	SPK SCL	FA SE					

Description	Initial System	Repair System
Available Space (.1945)	✓	✓
System Type(s)	2 1/2"	2 5/8"
Site LTAR	.5	.5

Other Factors (.1946): _____
 Site Classification (.1948): PS
 Evaluated By: GW
 Others Present: CG


COMMENTS: _____

<u>LANDSCAPE POSITIONS</u>	<u>GROUP</u>	<u>TEXTURES</u>	<u>.1955 LTAR</u>	<u>CONSISTENCE MOIST</u>	<u>WET</u>
R-RIDGE	I	S-SAND	1.2 - 0.8	VFR-VERY FRIABLE	NS-NON-STICKY
S-SHOULDER SLOPE		LS-LOAMY SAND			
L-LINEAR SLOPE	II	SL-SANDY LOAM	0.8 - 0.6	FR-FRIABLE	SS-SLIGHTLY STICKY
FS-FOOT SLOPE		L-LOAM			
N-NOSE SLOPE					
H-HEAD SLOPE	III	SI-SILT-	0.6 - 0.3	FI-FIRM	S-STICKY
CC-CONCLAVE SLOPE		SIL-SILT LOAM			
CV-CONVEX SLOPE		CL-CLAY LOAM			
T-TERRACE		SCL-SANDY CLAY LOAM			
FP-FLOOD PLAN		SICL-SILTY CLAY LOAM			
	IV	SIC-SILTY CLAY	0.4 - 0.1	EFI-EXTREMELY FIRM	VS-VERY STICKY
		C-CLAY			
		SC-SANDY CLAY			

STRUCTURE
 SG-SINGLE GRAIN
 M-MASSIVE
 CR-CRUMB
 GR-GRANULAR
 SBK-SUBANGULAR BLOCKY
 ABK-ANGULAR BLOCKY
 PL-PLATY
 PR-PRISMATIC

MINERALOGY
 SLIGHTLY EXPANSIVE
 EXPANSIVE

Show profile locations and other site features (dimensions, reference or benchmark, and North).





PLAN APPROVAL
 DISTRICT RAZOR USE SFD
 #BEDROOMS 3
4/4/08 [Signature]
 PLANNING ADMINISTRATOR



33
 +13
 46

OMAHA DRIVE
 50' PUBLIC R/W

THIS MAP WAS PREPARED FROM RECORDED DATA, AS NOTED, AND FROM OTHER SOURCES PROVIDED BY THE OWNER. THIS IS A PRELIMINARY SITE PLAN, INTENDED FOR PLANNING USE ONLY AND IN NO WAY REPRESENTS A SURVEY MADE BY THIS COMPANY. THIS MAP IS NOT INTENDED FOR RECORDATION, CONVEYANCES, OR SALES.

Charlie T. Carpenter, P.L.S.
 Professional Land Surveyor
 1940 Juniper Church Road
 Four Oaks, NC 27524
 (919) 963-2909
 (919) 320-5281

PRELIMINARY SITE PLAN FOR:
WYNN CONSTRUCTION

PIN 9597-36-2181.000
 PARCEL ID 039576 0088 18
 LOT 18 TINGEN POINTE S/D
 PB2007 PG711-718
 3/18/08
 1"=40'

270 OMAHA DRIVE
 BROADWAY, NC 27505