

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

Owner: 08.500 1980 J Lot 52

Applicant:

Address:

Date Evaluated:

Proposed Facility: SFO
 Location of Site: NC??

Design Flow (.1949): 760

Property Size:

Water Supply: Public Individual Well

Property Recorded:

Spring Other

Evaluation Method: Auger Boring Pit

Cut

Type of Wastewater: Sewage Industrial Process

Mixed

P R O F I L E #	.1940 Landscape Position/ Slope%	Horizon Depth (IN.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
S 7%		0-20	GA JL	VFA SE					.5
		20-26	SDK SL	FR SE					
		0-21	GA JL	VFA SE					.4
		21-30	SDK SL	FR SL					
		30-38	SDK SL	FI SE					
		0-21	GA JL	VFA SE					.5
		21-26	SDK SL	FR SE					
		0-28	GA JL	VFA SE					.5
		28-30	SDK SL	FR SL					
		0-21	GA SL	VFA SE					.4
		21-30	SDK SL	FR SE					
		30-38	SDK SL	FI SE					

Description	Initial System	Repair System
Available Space (.1945)	-	-
System Type(s)	25%	LPI
Site LTAR	.4	.2

Other Factors (.1946): _____
 Site Classification (.1948): P1
 Evaluated By: GWA
 Others Present: Cory G.


COMMENTS: _____

<u>LANDSCAPE POSITIONS</u>	<u>GROUP</u>	<u>TEXTURES</u>	<u>.1955 LTAR</u>	<u>CONSISTENCE MOIST</u>	<u>WET</u>
R-RIDGE	I	S-SAND	1.2 - 0.8	VFR-VERY FRIABLE	NS-NON-STICKY
S-SHOULDER SLOPE		LS-LOAMY SAND			
L-LINEAR SLOPE	II	SL-SANDY LOAM	0.8 - 0.6	FI-FIRM	SS-SLIGHTLY STICKY
FS-FOOT SLOPE		L-LOAM			
N-NOSE SLOPE	III	SI-SILT-	0.6 - 0.3	EFI-EXTREMELY FIRM	VS-VERY STICKY
H-HEAD SLOPE		SIL-SILT LOAM			
CC-CONCLAVE SLOPE		CL-CLAY LOAM			
CV-CONVEX SLOPE		SCL-SANDY CLAY LOAM			
T-TERRACE	IV	SIC-SILTY CLAY	0.4 - 0.1		NP-NON-PLASTIC
FP-FLOOD PLAN		C-CLAY			
		SC-SANDY CLAY			
		SICL-SILTY CLAY LOAM			SP-SLIGHTLY STICKY
					P-PLASTIC
					VP-VERY PLASTIC


STRUCTURE
 SG-SINGLE GRAIN
 M-MASSIVE
 CR-CRUMB
 GR-GRANULAR
 SBK-SUBANGULAR BLOCKY
 ABK-ANGULAR BLOCKY
 PL-PLATY
 PR-PRISMATIC

MINERALOGY
 SLIGHTLY EXPANSIVE
 EXPANSIVE

Show profile locations and other site features (dimensions, reference or benchmark, and North).



PLAN APPROVAL
 DISTRICT RA20R USE SFD
 #BEDROOMS 4/4/8 3
 JTC



L=134.03'
 R=925.00
 JUNO DRIVE
 50' PUBLIC R/W

THIS MAP WAS PREPARED FROM RECORDED DATA, AS NOTED, AND FROM OTHER SOURCES PROVIDED BY THE OWNER. THIS IS A PRELIMINARY SITE PLAN, INTENDED FOR PLANNING USE ONLY AND IN NO WAY REPRESENTS A SURVEY MADE BY THIS COMPANY. THIS MAP IS NOT INTENDED FOR RECORDATION, CONVEYANCES, OR SALES.

Charlie T. Carpenter, P.L.S.
 Professional Land Surveyor
 1940 Juniper Church Road
 Four Oaks, NC 27524
 (919) 963-2909
 (919) 320-5281

PRELIMINARY SITE PLAN FOR:
WYNN CONSTRUCTION

PIN 9597-34-7923.000
 PARCEL ID 039576 0088 52
 LDT 52 TINGEN POINTE S/D
 PB2007 PG711-718
 3/28/08
 1"=40'

174 JUNO DRIVE
 BROADWAY, NC 27505