
ADDRESS . : 225 WOODFIELD CT SUBDIV:
CONTRACTOR : PALMETTO DESIGN BUILD PHONE : (919) 795-0211
OWNER . . : BILLY E ANDERSON HOMEBUILDER PHONE : (919) 422-8918
PARCEL . . : 08-0664- - -0112- -25-
APPL NUMBER: 08-50019812 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : LEGACY AT RAWLS #24-401N LEFT RAWLS CH
RD 2MIELS LEFT INTO S/D ON RIVERWOOD DR
LOT ON LEFT AT END OF WOODFIELD CT &
OAK BLUFF CT, DRIVEWAY OFF OAK BLUFF.JD

STRUCTURE: 000 000 50X63 3BR CRAWL W/GARAGE & DECK
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED	INSP	DESCRIPTION
	COMPLETED	RESULT	RESULTS/COMMENTS
B101 01	5/30/08 <u>5-30-08</u>	TI <u>ADRS</u>	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001617026

----- COMMENTS AND NOTES -----

09892599

ADDRESS . : 225 WOODFIELD CT SUBDIV:
CONTRACTOR : PALMETTO DESIGN BUILD PHONE : (919) 795-0211
OWNER . . : BILLY E ANDERSON HOMEBUILDER PHONE : (919) 422-8918
PARCEL . . : 08-0664- - -0112- -25-
APPL NUMBER: 08-50019812 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : LEGACY AT RAWLS #24-401N LEFT RAWLS CH
RD 2MIELS LEFT INTO S/D ON RIVERWOOD DR
LOT ON LEFT AT END OF WOODFIELD CT &
OAK BLUFF CT, DRIVEWAY OFF OAK BLUFF.JD

STRUCTURE: 000 000 50X63 3BR CRAWL W/GARAGE & DECK
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	5/30/08	BS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001617026
	5/30/08	AP	premise # 09892599
B103 01	6/04/08 <u>6-4-08</u>	TI <u>DPBS</u>	R*BLDG FOUND & TEMP SVC POLE VRU #: 001619386

----- COMMENTS AND NOTES -----

ADDRESS : 225 WOODFIELD CT SUBDIV:
CONTRACTOR : PALMETTO DESIGN BUILD PHONE : (919) 795-0211
OWNER : BILLY E ANDERSON HOMEBUILDER PHONE : (919) 422-8918
PARCEL : 08-0664- - -0112- -25-
APPL NUMBER: 08-50019812 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : LEGACY AT RAWLS #24-401N LEFT RAWLS CH
RD 2MIELS LEFT INTO S/D ON RIVERWOOD DR
LOT ON LEFT AT END OF WOODFIELD CT &
OAK BLUFF CT, DRIVEWAY OFF OAK BLUFF.JD

STRUCTURE: 000 000 50X63 3BR CRAWL W/GARAGE & DECK
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	5/30/08	BS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001617026
	5/30/08	AP	premise # 09892599
B103 01	6/04/08	BS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001619386
	6/04/08	DP	Foundation near garage entry door is off footing on interior side. Dig out all of the mortar that was packed under wall, dig down to original footing depth, drill # 4 rebar into existing footing @ 16 oc, and call for reinspection \$50 re fee Do not frame.
A814 01	6/05/08	TI	ADDRESS CONFIRMATION VRU #: 001620350
B103 02	6/05/08	TI	R*BLDG FOUND & TEMP SVC POLE VRU #: 001620368

Per Brach

COMMENTS AND NOTES

ADDRESS . . : 225 WOODFIELD CT SUBDIV:
 CONTRACTOR : PALMETTO DESIGN BUILD PHONE : (919) 795-0211
 OWNER . . . : BILLY E ANDERSON HOMEBUILDER PHONE : (919) 422-8918
 PARCEL . . . : 08-0664- - -0112- -25-
 APPL NUMBER: 08-50019812 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : LEGACY AT RAWLS #24-401N LEFT RAWLS CH
 RD 2MIELS LEFT INTO S/D ON RIVERWOOD DR
 LOT ON LEFT AT END OF WOODFIELD CT &
 OAK BLUFF CT, DRIVEWAY OFF OAK BLUFF.JD

STRUCTURE: 000 000 50X63 3BR CRAWL W/GARAGE & DECK
 FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	5/30/08	BS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001617026
	5/30/08	AP	premise # 09892599
B103 01	6/04/08	BS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001619386
	6/04/08	DP	Foundation near garage entry door is off footing on interior side. Dig out all of the mortar that was packed under wall, dig down to original footing depth, drill # 4 rebar into existing footing @ 16 oc, and call for reinspection \$50 re fee Do not frame.
B103 02	6/05/08	BS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001620368
	6/05/08	AP	
A814 01	6/05/08	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001620350
	6/05/08	AP	225 WOODFIELD CT LOT 24 (OK DRIVE ON OAKBLUFF CT)
B105 01	6/09/08	TI	R*OPEN FLOOR VRU #: 001621820

698 APBS

----- COMMENTS AND NOTES -----

ADDRESS . : 225 WOODFIELD CT SUBDIV:
CONTRACTOR : PALMETTO DESIGN BUILD PHONE : (919) 795-0211
OWNER . . : BILLY E ANDERSON HOMEBUILDER. PHONE : (919) 422-8918
PARCEL . . : 08-0664- - -0112- -25-
APPL NUMBER: 08-50019812 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : LEGACY AT RAWLS #24-401N LEFT RAWLS CH
RD 2MIELS LEFT INTO S/D ON RIVERWOOD DR
LOT ON LEFT AT END OF WOODFIELD CT &
OAK BLUFF CT, DRIVEWAY OFF OAK BLUFF.JD

STRUCTURE: 000 000 50X63 3BR CRAWL W/GARAGE & DECK
FLOOD ZONE . . . : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	5/30/08 5/30/08	BS AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001617026 premise # 09892599
B103 01	6/04/08 6/04/08	BS DP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001619386 Foundation near garage entry door is off footing on interior side. Dig out all of the mortar that was packed under wall, dig down to original footing depth, drill # 4 rebar into existing footing @ 16 oc, and call for reinspection \$50 re fee Do not frame.
B103 02	6/05/08 6/05/08	BS AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001620368
A814 01	6/05/08 6/05/08	TI AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001620350 225 WOODFIELD CT LOT 24 (OK DRIVE ON OAKBLUFF CT)
B105 01	6/09/08 6/09/08	BS AP	R*OPEN FLOOR VRU #: 001621820
R427 01	6/27/08 <u>6-27-08</u>	TI <u>JPBS</u>	FOUR TRADE ROUGH IN >2500 VRU #: 001632835

----- COMMENTS AND NOTES -----

ADDRESS : 225 WOODFIELD CT SUBDIV:
 CONTRACTOR : PALMETTO DESIGN BUILD PHONE : (919) 795-0211
 OWNER : BILLY E ANDERSON HOMEBUILDER PHONE : (919) 422-8918
 PARCEL : 08-0664- - -0112- -25-
 APPL NUMBER: 08-50019812 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : LEGACY AT RAWLS #24-401N LEFT RAWLS CH
 RD 2MIELS LEFT INTO S/D ON RIVERWOOD DR
 LOT ON LEFT AT END OF WOODFIELD CT &
 OAK BLUFF CT, DRIVEWAY OFF OAK BLUFF.JD

STRUCTURE: 000 000 50X63 3BR CRAWL W/GARAGE & DECK
 FLOOD ZONE . . . : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	5/30/08	BS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001617026
	5/30/08	AP	premise # 09892599
B103 01	6/04/08	BS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001619386
	6/04/08	DP	Foundation near garage entry door is off footing on interior side. Dig out all of the mortar that was packed under wall, dig down to original footing depth, drill # 4 rebar into existing footing @ 16 oc, and call for reinspection \$50 re fee Do not frame.
B103 02	6/05/08	BS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001620368
	6/05/08	AP	
A814 01	6/05/08	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001620350
	6/05/08	AP	225 WOODFIELD CT LOT 24 (OK DRIVE ON OAKBLUFF CT)
B105 01	6/09/08	BS	R*OPEN FLOOR VRU #: 001621820
	6/09/08	AP	
R427 01	6/27/08	BS	FOUR TRADE ROUGH IN >2500 VRU #: 001632835
	6/27/08	DP	1. Block and nail all joints in OSB 4 feet from corners. Joint must be nailed 6" OC. 2 All firestopping for holes in top and bottom plate must be done before insulation. 3. Insulation baffles must be installed in all cathedrals at rough in. 4. Sheet inside garage wall with osb. 5 Flash front and rear porches. DO NOT SIDE/INSULATE \$50. re fee
R427 02	7/01/08	TI	FOUR TRADE ROUGH IN >2500 VRU #: 001634815
	<u>7-1-08</u>	<u>APB</u>	

COMMENTS AND NOTES

ADDRESS : 225 WOODFIELD CT SUBDIV:
 CONTRACTOR : PALMETTO DESIGN BUILD PHONE : (919) 795-0211
 OWNER : BILLY E ANDERSON HOMEBUILDER PHONE : (919) 422-8918
 PARCEL : 08-0664- - -0112- -25-
 APPL NUMBER: 08-50019812 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : LEGACY AT RAWLS #24-401N LEFT RAWLS CH
 RD 2MIELS LEFT INTO S/D ON RIVERWOOD DR
 LOT ON LEFT AT END OF WOODFIELD CT &
 OAK BLUFF CT, DRIVEWAY OFF OAK BLUFF.JD

STRUCTURE: 000 000 50X63 3BR CRAWL W/GARAGE & DECK

FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	5/30/08	BS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001617026
	5/30/08	AP	premise # 09892599
B103 01	6/04/08	BS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001619386
	6/04/08	DP	Foundation near garage entry door is off footing on interior side. Dig out all of the mortar that was packed under wall, dig down to original footing depth, drill # 4 rebar into existing footing @ 16 oc, and call for reinspection \$50 re fee Do not frame.
B103 02	6/05/08	BS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001620368
	6/05/08	AP	
A814 01	6/05/08	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001620350
	6/05/08	AP	225 WOODFIELD CT LOT 24 (OK DRIVE ON OAKBLUFF CT)
B105 01	6/09/08	BS	R*OPEN FLOOR VRU #: 001621820
	6/09/08	AP	
R427 01	6/27/08	BS	FOUR TRADE ROUGH IN >2500 VRU #: 001632835
	6/27/08	DP	1. Block and nail all joints in OSB 4 feet from corners. Joint must be nailed 6" OC. 2 All firestopping for holes in top and bottom plate must be done before insulation. 3. Insulation baffles must be installed in all cathedrals at rough in. 4. Sheet inside garage wall with osb. 5 Flash front and rear porches. DO NOT SIDE/INSULATE \$50. re fee
R427 02	7/01/08	BS	FOUR TRADE ROUGH IN >2500 VRU #: 001634815
	7/01/08	AP	
I129 01	7/03/08	TI	R*INSULATION INSPECTION VRU #: 001636570
	<u>7-3</u>	<u>AP</u>	

COMMENTS AND NOTES

ADDRESS : 225 WOODFIELD CT SUBDIV:
CONTRACTOR : PALMETTO DESIGN BUILD PHONE : (919) 795-0211
OWNER : BILLY E ANDERSON HOMEBUILDER PHONE : (919) 422-8918
PARCEL : 08-0664- - -0112- -25-
APPL NUMBER: 08-50019812 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : LEGACY AT RAWLS #24-401N LEFT RAWLS CH
RD 2MIELS LEFT INTO S/D ON RIVERWOOD DR
LOT ON LEFT AT END OF WOODFIELD CT &
OAK BLUFF CT, DRIVEWAY OFF OAK BLUFF.JD

STRUCTURE: 000 000 50X63 3BR CRAWL W/GARAGE & DECK
FLOOD ZONE . . . : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	5/30/08	BS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001617026
	5/30/08	AP	premise #. 09892599
B103 01	6/04/08	BS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001619386
	6/04/08	DP	Foundation near garage entry door is off footing on interior side. Dig out all of the mortar that was packed under wall, dig down to original footing depth, drill # 4 rebar into existing footing @ 16 oc, and call for reinspection \$50 re fee Do not frame.
B103 02	6/05/08	BS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001620368
	6/05/08	AP	
A814 01	6/05/08	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001620350
	6/05/08	AP	225 WOODFIELD CT LOT 24 (OK DRIVE ON OAKBLUFF CT)
B105 01	6/09/08	BS	R*OPEN FLOOR VRU #: 001621820
	6/09/08	AP	
R427 01	6/27/08	BS	FOUR TRADE ROUGH IN >2500 VRU #: 001632835
	6/27/08	DP	1. Block and nail all joints in OSB 4 feet from corners. Joint must be nailed 6" OC. 2 All firestopping for holes in top and bottom plate must be done before insulation. 3. Insulation baffles must be installed in all cathedrals at rough in. 4. Sheet inside garage wall with osb. 5 Flash front and rear porches. DO NOT SIDE/INSULATE \$50. re fee
R427 02	7/01/08	BS	FOUR TRADE ROUGH IN >2500 VRU #: 001634815
	7/01/08	AP	
I129 01	7/03/08	KS	R*INSULATION INSPECTION VRU #: 001636570
	7/03/08	AP	
H824 01	8/13/08	JM	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001662360
	8/13/08	AP	
R431 01	8/25/08	TI	FOUR TRADE FINAL >2500 VRU #: 001667344
	8-25-08	DRBS	

COMMENTS AND NOTES

ADDRESS : 225 WOODFIELD CT SUBDIV:
 CONTRACTOR : PALMETTO DESIGN BUILD PHONE : (919) 795-0211
 OWNER : BILLY E ANDERSON HOMEBUILDER PHONE : (919) 422-8918
 PARCEL : 08-0664- - -0112- -25-
 APPL NUMBER: 08-50019812 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : LEGACY AT RAWLS #24-401N LEFT RAWLS CH
 RD 2MIELS LEFT INTO S/D ON RIVERWOOD DR
 LOT ON LEFT AT END OF WOODFIELD CT &
 OAK BLUFF CT, DRIVEWAY OFF OAK BLUFF.JD

STRUCTURE: 000 000 50X63 3BR CRAWL W/GARAGE & DECK
 FLOOD ZONE . . . : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	5/30/08	BS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001617026
	5/30/08	AP	premise # 09892599
B103 01	6/04/08	BS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001619386
	6/04/08	DP	Foundation near garage entry door is off footing on interior side. Dig out all of the mortar that was packed under wall, dig down to original footing depth, drill # 4 rebar into existing footing @ 16 oc, and call for reinspection \$50 re fee Do not frame.
B103 02	6/05/08	BS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001620368
	6/05/08	AP	
A814 01	6/05/08	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001620350
	6/05/08	AP	✓ 225 WOODFIELD CT LOT 24 (OK DRIVE ON OAKBLUFF CT)
B105 01	6/09/08	BS	R*OPEN FLOOR VRU #: 001621820
	6/09/08	AP	
R427 01	6/27/08	BS	FOUR TRADE ROUGH IN >2500 VRU #: 001632835
	6/27/08	DP	1. Block and nail all joints in OSB 4 feet from corners. Joint must be nailed 6" OC. 2 All firestopping for holes in top and bottom plate must be done before insulation. 3. Insulation baffles must be installed in all cathedrals at rough in. 4. Sheet inside garage wall with osb. 5 Flash front and rear porches. DO NOT SIDE/INSULATE \$50. re fee
R427 02	7/01/08	BS	FOUR TRADE ROUGH IN >2500 VRU #: 001634815
	7/01/08	AP	
I129 01	7/03/08	KS	R*INSULATION INSPECTION VRU #: 001636570
	7/03/08	AP	
H824 01	8/13/08	JM	✓ ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001662360
	8/13/08	AP	
R431 01	8/25/08	BS	FOUR TRADE FINAL >2500 VRU #: 001667344
	8/25/08	DP	1. Insulate water lines on water heater 2.No strainer on master shower drain 3. Cap plumbing in attic (test caps are ok). 4 No receptacle on peninsula in kitchen. \$50. re fee
R431 02	8/27/08	TI	FOUR TRADE FINAL >2500 VRU #: 001668052
	8-27-08	APBS	

COMMENTS AND NOTES

**COUNTY OF HARNETT
DEPARTMENT OF BUILDING INSPECTION
AND PLANNING/DEVELOPMENT
CERTIFICATE OF OCCUPANCY**

This certificate issued pursuant to the requirements of Section 105 of the North Carolina State Building Code and the Harnett County Zoning Ordinance certifies at the time of issuance this structure was in compliance with the various ordinances of the County of Harnett regulating development and building construction or use. For the following:

Use Classification: SFD

Owner: Billy Anderson

911 Address: 225 Wood Field Ct

FU

State: NC Zip Code: 27526

Date: 8-27-08

Brad Smith

Building Official

PERMIT NUMBERS

Building Permit No.: _____

Electrical Permit No.: _____

Insulation Permit No.: _____

Plumbing Permit No.: _____

Mech. Permit No.: 08-15-19812

MFG. Home: _____