
ADDRESS : 190 NATURES WAY SUBDIV: BENNETT PLACE
CONTRACTOR : KEN DAWSON HOMES INC PHONE : (919) 207-9876
OWNER : BLACKMAN PERNELLA PHONE :
PARCEL : 02-1528- - -0073- -09-
APPL NUMBER: 08-50019841 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : HWY 210 S TO DUNN LEFT ON HWY 301 N
LEFT ON NEIGHBORS RD LEFT ON NATURES
WAY LOT 9 JB
LAND NOTES : LXMN 6/18/04 BENNETT PLACE S/D LOT#9
SPLIT FROM MAIN PARCEL

STRUCTURE: 000 000 50X47.5 3BDR (CRAWL)
FLOOD ZONE . . . : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	5/30/08 <u>5-30</u>	TI <u>AP</u>	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001617101

per

COMMENTS AND NOTES

Pole OK

ADDRESS . : 190 NATURES WAY SUBDIV: BENNETT PLACE
CONTRACTOR : KEN DAWSON HOMES INC PHONE : (919) 207-9876
OWNER . . : BLACKMAN PERNELLA PHONE :
PARCEL . . : 02-1528- - -0073- -09-
APPL NUMBER: 08-50019841 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : HWY 210 S TO DUNN LEFGT ON HWY 301 N
LEFT ON NEIGHBORS RD LEFT ON NATURES
WAY LOT 9 JB
PREMISE # 62384692 *****
LAND NOTES : LXMN 6/18/04 BENNETT PLACE S/D LOT#9
SPLIT FROM MAIN PARCEL

STRUCTURE: 000 000 50X47.5 3BDR (CRAWL)
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	5/30/08	KS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001617101
	5/30/08	AP	
B103 01	6/12/08	TT	R*BLDG FOUND & TEMP SVC POLE VRU #: 001622703
	<u>6-12</u>	<u>DA</u>	

----- COMMENTS AND NOTES -----

ADDRESS : 190 NATURES WAY
CONTRACTOR : KEN DAWSON HOMES INC
OWNER : BLACKMAN PERNELLA
PARCEL : 02-1528- - -0073- -09-
APPL NUMBER: 08-50019841 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : HWY 210 S TO DUNN LEFGT ON HWY 301 N
LEFT ON NEIGHBORS RD LEFT ON NATURES
WAY LOT 9 JB
PREMISE # 62384692 *****

SUBDIV: BENNETT PLACE
PHONE : (919) 207-9876
PHONE :

LAND NOTES : LXMN 6/18/04 BENNETT PLACE S/D LOT#9
SPLIT FROM MAIN PARCEL

STRUCTURE: 000 000 50X47.5 3BDR (CRAWL)
FLOOD ZONE : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	5/30/08	KS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001617101
	5/30/08	AP	
B103 01	6/12/08	KS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001622703
	6/12/08	DA	1. Front wall not on footing. Dig out, epoxy #4 rebar in footing and call for inspection prior to pouring.
B103 02	6/13/08	TI	R*BLDG FOUND & TEMP SVC POLE VRU #: 001624996
	<u>6-13</u>	<u>AT</u>	

COMMENTS AND NOTES

5801

ADDRESS : 190 NATURES WAY SUBDIV: BENNETT PLACE
 CONTRACTOR : KEN DAWSON HOMES INC PHONE : (919) 207-9876
 OWNER : BLACKMAN PERNELLA PHONE :
 PARCEL : 02-1528- - -0073- -09-
 APPL NUMBER: 08-50019841 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : HWY 210 S TO DUNN LEFGT ON HWY 301 N
 LEFT ON NEIGHBORS RD LEFT ON NATURES
 WAY LOT 9 JB
 PREMISE # 62384692 *****
 LAND NOTES : LXMN 6/18/04 BENNETT PLACE S/D LOT#9
 SPLIT FROM MAIN PARCEL

STRUCTURE: 000 000 50X47.5 3BDR (CRAWL)
 FLOOD ZONE . . . : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	5/30/08	KS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001617101
	5/30/08	AP	
B103 01	6/12/08	KS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001622703
	6/12/08	DA	1. Front wall not on footing. Dig out, epoxy #4 rebar in footing and call for inspection prior to pouring.
B103 02	6/13/08	KS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001624996
	6/13/08	AP	
B105 01	6/17/08	TI	R*OPEN FLOOR VRU #: 001626068
	<u>6-17</u>	<u>AP</u>	A.M. Inspection if at all possible.

COMMENTS AND NOTES

ADDRESS : 190 NATURES WAY SUBDIV: BENNETT PLACE
 CONTRACTOR : KEN DAWSON HOMES INC PHONE : (919) 207-9876
 OWNER : BLACKMAN PERNELLA PHONE :
 PARCEL : 02-1528- - -0073- -09-
 APPL NUMBER: 08-50019841 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : HWY 210 S TO DUNN LEFT ON HWY 301 N
 LEFT ON NEIGHBORS RD LEFT ON NATURES
 WAY LOT 9 JB
 PREMISE # 62384692 *****
 LAND NOTES : LXMN 6/18/04 BENNETT PLACE S/D LOT#9
 SPLIT FROM MAIN PARCEL

STRUCTURE: 000 000 50X47.5 3BDR (CRAWL)
 FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	5/30/08	KS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001617101
	5/30/08	AP	
B103 01	6/12/08	KS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001622703
	6/12/08	DA	1. Front wall not on footing. Dig out, epoxy #4 rebar in footing and call for inspection prior to pouring.
B103 02	6/13/08	KS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001624996
	6/13/08	AP	
B105 01	6/17/08	KS	R*OPEN FLOOR VRU #: 001626068
	6/17/08	AP	A.M. Inspection if at all possible.
R427 01	7/03/08	TI	FOUR TRADE ROUGH IN >2500 VRU #: 001636281

7-3 ~~DA~~ DA

----- COMMENTS AND NOTES -----

**Violation Notice
Do Not Remove**

**Harnett County Inspection Department
102 East Front St P.O. Box 65
Lillington, NC 27546
Phone (910) 893-7525 Fax (910) 893-2793**

08-50019841

7-03-08

1. Fire block top of dead space area next to front bedroom and bathroom
 2. Need uplift connector at joint 8 capable of 999 pounds on trus A6.
 3. Hurricane tie missing at joint 11 on truss A1
 4. Web 2 14 not braced at midpoint.
 5. Rear porch has vents to main crawl space. Need to be removed.
- OK to side and insulate.

Signature Ken Slattum 910-984-4766 _____

ADDRESS : 190 NATURES WAY
 CONTRACTOR : KEN DAWSON HOMES INC
 OWNER : BLACKMAN PERNELLA
 PARCEL : 02-1528- - -0073- -09-
 APPL NUMBER: 08-50019841 CP NEW RESIDENTIAL (SFD)

SUBDIV: BENNETT PLACE
 PHONE : (919) 207-9876
 PHONE :

DIRECTIONS : HWY 210 S TO DUNN LEFGT ON HWY 301 N
 LEFT ON NEIGHBORS RD LEFT ON NATURES
 WAY LOT 9 JB
 PREMISE # 62384692 *****
 LAND NOTES : LXMN 6/18/04 BENNETT PLACE S/D LOT#9
 SPLIT FROM MAIN PARCEL

STRUCTURE: 000 000 50X47.5 3BDR (CRAWL)
 FLOOD ZONE . . . : FLOOD ZONE X

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	5/30/08	KS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001617101
	5/30/08	AP	
B103 01	6/12/08	KS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001622703
	6/12/08	DA	1. Front wall not on footing. Dig out, epoxy #4 rebar in footing and call for inspection prior to pouring.
B103 02	6/13/08	KS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001624996
	6/13/08	AP	
B105 01	6/17/08	KS	R*OPEN FLOOR VRU #: 001626068
	6/17/08	AP	A.M. Inspection if at all possible.
R427 01	7/03/08	KS	FOUR TRADE ROUGH IN >2500 VRU #: 001636281
	7/03/08	DA	1. Fire block chase by front bedroom 2. Need uplift hanger at joint 8 capable of 999 pounds. 3. Hurricane tie missing at joint 11 on truss A1 4. Web 2' 14 not braced at midpoint. 5. Rear porch vents open to crawl space
H824 01	7/07/08	JM	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001637552
	7/07/08	AP	
R427 02	7/09/08	TI	FOUR TRADE ROUGH IN >2500 VRU #: 001637214
	<u>7-9</u>	<u>AP</u>	Insulation inspection needed as well. Corrections made on original rough-in.
A814 01	7/09/08	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001638964
I129 01	7/09/08	TI	R*INSULATION INSPECTION TIME: 17:00 VRU #: 001638972
	<u>7-9</u>	<u>AP</u>	<i>gnage ceiling insulated</i>

COMMENTS AND NOTES

ADDRESS : 190 NATURES WAY SUBDIV: BENNETT PLACE
 CONTRACTOR : KEN DAWSON HOMES INC PHONE : (919) 207-9876
 OWNER : BLACKMAN PERNELLA PHONE :
 PARCEL : 02-1528- - -0073- -09-
 APPL NUMBER: 08-50019841 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : HWY 210 S TO DUNN LEFT ON HWY 301 N
 LEFT ON NEIGHBORS RD LEFT ON NATURES
 WAY LOT 9 JB
 PREMISE # 62384692 *****
 LAND NOTES : LXMN 6/18/04 BENNETT PLACE S/D LOT#9
 SPLIT FROM MAIN PARCEL

STRUCTURE: 000 000 50X47.5 3BDR (CRAWL)
 FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	5/30/08	KS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001617101
	5/30/08	AP	
B103 01	6/12/08	KS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001622703
	6/12/08	DA	1. Front wall not on footing. Dig out, epoxy #4 rebar in footing and call for inspection prior to pouring.
B103 02	6/13/08	KS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001624996
	6/13/08	AP	
B105 01	6/17/08	KS	R*OPEN FLOOR VRU #: 001626068
	6/17/08	AP	A.M. Inspection if at all possible.
R427 01	7/03/08	KS	FOUR TRADE ROUGH IN >2500 VRU #: 001636281
	7/03/08	DA	1. Fire block chase by front bedroom 2. Need uplift hanger at joint 8 capable of 999 pounds. 3. Hurricane tie missing at joint 11 on truss A1 4. Web 2 14 not braced at midpoint. 5. Rear porch vents open to crawl space
H824 01	7/07/08	JM	✓ ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001637552
	7/07/08	AP	
R427 02	7/09/08	KS	FOUR TRADE ROUGH IN >2500 VRU #: 001637214
	7/09/08	AP	Insulation inspection needed as well. Corrections made on original rough-in.
AB14 01	7/09/08	KS	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001638964
	7/09/08	AP	
I129 01	7/09/08	KS	R*INSULATION INSPECTION TIME: 17:00 VRU #: 001638972
	7/09/08	AP	
R429 01	9/30/08	TI	FOUR TRADE FINAL VRU #: 001684117
	<u>9-30</u>	<u>AP</u>	

COMMENTS AND NOTES

190 Natures Way

**COUNTY OF HARNETT
DEPARTMENT OF BUILDING INSPECTION
AND PLANNING/DEVELOPMENT
CERTIFICATE OF OCCUPANCY**

This certificate issued pursuant to the requirements of Section 105 of the North Carolina State Building Code and the Harnett County Zoning Ordinance certifies at the time of issuance this structure was in compliance with the various ordinances of the County of Harnett regulating development and building construction or use. For the following:

Use Classification: Residential

Owner: Ken Dausa

911 Address: 150 Naturas Way

State: _____ Zip Code: _____

Date: 9-30-08
Ken Slatt

Building Official

PERMIT NUMBERS

Building Permit No.: _____

Electrical Permit No.: _____

Insulation Permit No.: _____

Plumbing Permit No.: _____

Mech. Permit No.: _____

MFG. Home: _____

08-50019841